

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF NUCLEAR REACTOR REGULATION  
WASHINGTON, DC 20555-0001

May 8, 2009

**NRC REGULATORY ISSUE SUMMARY 2009-02, REV. 1,  
USE OF CONTAINMENT ATMOSPHERE GASEOUS RADIOACTIVITY  
MONITORS AS REACTOR COOLANT SYSTEM LEAKAGE DETECTION  
EQUIPMENT AT NUCLEAR POWER REACTORS**

**ADDRESSEES**

All holders of operating licenses for nuclear power reactors under the provisions of Title 10 of the Code of Federal Regulations (10 CFR) Part 50, "Domestic Licensing of Production and Utilization Facilities," except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

All current and potential applicants for a combined license, manufacturing license, standard design certification, or standard design approval for a nuclear power plant under the provisions of 10 CFR Part 52, "Licenses, Certifications, and Approvals for Nuclear Power Plants".

All holders of and applicants for nuclear power plant construction permits and operating licenses under the provisions of 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities."

**INTENT**

The U.S. Nuclear Regulatory Commission (NRC) is issuing this revised regulatory issue summary (RIS) to clarify expectations regarding licensee operability determinations and communicate the NRC plan to address the situation created when some containment atmosphere gaseous radioactivity monitors are unable to meet technical specification (TS) requirements. The plan consists of integrating a streamlined license amendment process with the use of enforcement discretion, where appropriate. This RIS requires no action or written response on the part of an addressee. RIS 2009-02 was originally issued on January 29, 2009.

**BACKGROUND INFORMATION**

In order to meet General Design Criterion 30, "Quality of reactor coolant pressure boundary," of Appendix A to 10 CFR Part 50, licensees typically include RCS leakage detection equipment in their plant designs because the equipment can be used to detect reactor coolant pressure boundary (RCPB) leakage. A typical RCS leakage detection system consists of a combination of the following:

- a containment atmosphere particulate radioactivity monitoring system
- a containment atmosphere gaseous radioactivity monitoring system
- containment sump-level and sump-pump instrumentation

**ML090850574**

- containment cooler condensate monitoring instrumentation
- Containment atmosphere gaseous radioactivity monitoring systems measure RCS leakage indirectly by detecting airborne radioactivity released from RCS leakage. Response time is the length of time required for these monitoring systems to detect a given volume of RCS leakage. Response time is dependant on RCS radioactivity concentration, as well as other variables. For a given volume of leakage, with all other variables held constant, a higher RCS radioactivity concentration will yield a shorter response time for these monitoring systems. The design analyses for the containment atmosphere gaseous radioactivity monitoring systems used in the licensing bases for most plants typically assume a RCS radioactivity concentration approximately equivalent to 0.1 percent failed fuel in the core. Improvements in fuel cladding integrity and RCS chemistry controls have significantly reduced RCS radioactivity concentration at most plants. As a result, the monitors for operating units may have longer response times than they would with 0.1 percent failed fuel in the core because the actual RCS radioactivity concentration is less than it would be with 0.1 percent failed fuel in the core.

Most plants have TS Limiting Conditions for Operation requirements for containment atmosphere gaseous radioactivity monitoring systems used as part of RCS leakage detection equipment. The TS requirements for the monitoring systems' response times are based on the design analysis that is part of a plant's licensing basis. Whether the monitors are operable depends on the licensing basis and TS requirements. When the monitors are inoperable the licensee is required to take remedial actions as permitted by their TS or to shut down the reactor.

Information Notice (IN) 2005-24, "Nonconservatism in Leakage Detection Sensitivity" (ADAMS Accession No. ML051780073), communicated the issue created by differences between actual and assumed RCS radioactivity concentrations to all licensees. The purpose of IN 2005-24 was to have licensees review information related to problems with containment atmosphere gaseous radioactivity monitors used as part of RCS leakage detection equipment and consider appropriate actions as applicable to their plants. Information Notices do not require any action by licensees.

In September 2008, NRC inspectors at the Diablo Canyon Power Plant identified a non-cited violation for not complying with TS requirements for RCS leakage detection equipment. In November 2008, the licensee for the Watts Bar Nuclear Plant and the Sequoyah Nuclear Plant requested exigent license amendments from the NRC after taking remedial actions as permitted by their TS because of a concern that the containment atmosphere gaseous radioactivity monitor channels of the RCS leakage detection system were inoperable.

To address the issue, licensees working through the industry-sponsored Technical Specifications Task Force (TSTF) have attempted to create generic TS changes, model License Amendment Requests (LARs), model safety evaluations, and model proposed no-significant-hazards consideration determinations using the NRC TS Consolidated Line Item Improvement Process (CLIIP). See RIS 2000-06, "Consolidated Line Item Improvement Process For Adopting Standard Technical Specifications Changes for Power Reactors" (ADAMS Accession No. ML003693442) for more information on the NRC CLIIP.

RIS 2009-02 was originally issued on January 29, 2009. NRC received several responses and

inquiries regarding NRC's expectations with respect to operability determinations for the containment atmosphere gaseous radioactivity monitors. Some responders incorrectly interpreted the original RIS to mean that NRC was declaring their site specific containment atmosphere gaseous radiation monitors to be inoperable. The NRC does not make generic operability determinations. As stated in NRC Inspection Manual Part 9900: Technical Guidance, "Operability Determinations And Functionality Assessments For Resolution Of Degraded Or Nonconforming Conditions Adverse To Quality Or Safety" (ADAMS Accession No. ML081360529), licensees determine operability of equipment based on their plant-specific licensing basis.

## **SUMMARY OF ISSUE**

Improvements in fuel cladding integrity and RCS chemistry controls result in lower RCS radioactivity concentrations during operational activities, including situations where there is RCS leakage. Thus, containment atmosphere gaseous radioactivity monitoring systems which are designed on the basis of higher assumed RCS radioactivity concentrations may not provide accurate indication of RCS leakage in the required length of time due to the longer response time of the monitoring system. If this occurs each licensee must determine the operability of their gaseous radioactivity monitoring system based on their plant-specific licensing basis.

The NRC considers the longer response times of the containment atmosphere gaseous radioactivity monitors to be of very low safety significance. The monitors would still be able to detect degradation in the RCPB long before components fail in a manner that would affect plant safety. Additionally, plants also have multiple diverse and redundant methods available to detect RCS leakage and to provide licensees with a means to detect significant RCPB degradation and to take appropriate action to ensure the continued protection of public health and safety. Finally, nuclear power plants are designed to provide adequate core cooling following postulated loss-of-coolant accidents up to and including a break equivalent in size to the double-ended rupture of the largest pipe in the RCS. This design feature, coupled with the extremely low likelihood of unstable crack growth resulting in a loss-of-coolant accident, leads the NRC to conclude that the risk significance of this issue is very low.

The NRC plans to address the containment atmosphere gaseous radioactivity monitoring system issue in an integrated fashion by: (i) working with the TSTF to develop revised generic TS for the monitoring system, and facilitating licensee implementation of the revised generic TS through a streamlined license amendment process; and (ii) using guidance on NRC's exercise of enforcement discretion involving inoperable containment atmosphere gaseous radioactivity monitoring systems issued in EGM-09-001 (ADAMS Accession No. ML090300467).

The NRC will review the generic TS changes that the TSTF proposes for pressurized-water reactors (PWRs) and boiling-water reactors (BWRs). If the generic TS changes are found to be acceptable, the NRC will make the generic model LARs, model safety evaluations, and model no-significant-hazards consideration determinations available to licensees using the NRC CLIIP. The revised TS would clarify the licensing basis for the leakage detection system in order to prevent further confusion in the future. Licensees are free to submit LARs for TS changes to address the issue. If licensees make a determination that their containment atmosphere gaseous radioactivity monitors are operable after examining their plant-specific licensing basis, they can choose to take no action.

On February 18, 2009, the TSTF submitted TSTF-513, Revision 1 “Revise PWR Operability Requirements and Actions for RCS Leakage Instrumentation” and TSTF-514, Revision 0 “Revise BWR Operability Requirements and Actions for RCS Leakage Instrumentation” to the NRC for review. Licensees are free to submit LARs to address the issue using TSTF-513 or TSTF-514; or they can propose alternative solutions.

In certain circumstances involving inoperable containment atmosphere gaseous radioactivity monitoring systems, enforcement discretion is available. Specific guidance for this enforcement discretion is described in EGM-09-001 (ADAMS Accession No. ML090300467) and is available on the NRC’s web site at [www.nrc.gov](http://www.nrc.gov).

## **BACKFIT DISCUSSION**

The intent of this revised RIS is to inform addressees of the NRC’s plan to address the failure of containment atmosphere gaseous radioactivity monitors used as RCS leakage detection equipment to meet TS requirements and clarify expectations regarding licensee operability determinations.

The staff is not imposing any new positions on licensees. This revised RIS is not providing any new regulatory positions. This revised RIS only conveys the NRC’s plan to address the issue of RCS leakage detection equipment failing to meet TS requirements because of the difference between actual and assumed RCS radioactivity concentrations. This revised RIS requires no action or written response and, therefore, is not a backfit under 10 CFR 50.109, “Backfitting.” Consequently, the staff did not perform a backfit analysis.

## **FEDERAL REGISTER NOTIFICATION**

A notice of opportunity for public comment on this RIS was not published in the *Federal Register* because it is informational and pertains to a staff position that does not represent a departure from current regulatory requirements and practice. However, a public meeting to discuss this RIS was held on April 14, 2009. The meeting summary is available under ADAMS Accession No. ML091050669. The NRC also posted the RIS on the “Draft Generic Communications for Comment” portion of its website, which is publicly accessible. No comments were received from the posting. The NRC intends to work with industry representatives, members of the public, and other stakeholders in developing final guidance and in modifying related guidance documents.

## **CONGRESSIONAL REVIEW ACT**

This RIS is not a rule as designated by the Congressional Review Act (5 U.S.C. §§ 801–808) and, therefore, is not subject to the Act.

## **PAPERWORK REDUCTION ACT STATEMENT**

This RIS does not contain any information collections and, therefore, is not subject to the

requirements of the Paperwork Reduction Act of 1995 (44 U.S.C. 3501, et seq.).

#### PUBLIC PROTECTION NOTIFICATION

The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid OMB control number.

#### **CONTACT**

Please direct any questions about this matter to the technical contact listed below or to the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

*/RA/*

Timothy J. McGinty, Director  
Division of Policy and Rulemaking  
Office of Nuclear Reactor Regulation

Technical Contact: Matthew Hamm, NRR  
301-415-1472  
e-mail: [matthew.hamm@nrc.gov](mailto:matthew.hamm@nrc.gov)

Note: NRC generic communications may be found on the NRC public Web site, <http://www.nrc.gov>, under Electronic Reading Room/Document Collections.

PUBLIC PROTECTION NOTIFICATION

The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid OMB control number.

**CONTACT**

Please direct any questions about this matter to the technical contact listed below or to the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

*/RA/*

Timothy J. McGinty, Director  
Division of Policy and Rulemaking  
Office of Nuclear Reactor Regulation

Technical Contact: Matthew Hamm, NRR  
301-415-1472  
e-mail: [matthew.hamm@nrc.gov](mailto:matthew.hamm@nrc.gov)

Note: NRC generic communications may be found on the NRC public Web site, <http://www.nrc.gov>, under Electronic Reading Room/Document Collections.

**ADAMS ACCESSION No. ML090850574**

OFFICE	ITSB:DIRS	BC:ITSBDIRS	D:DIRS	D:DORL	OE	OGC (NLO)
NAME	MHamm	RElliott	FBrown	JGitter	NHilton	GMizuno
DATE	3/26/2009	3/26/2009	3/27/2009	4/20/2009	4/1/2009	4/10/2009
OFFICE	OGC (CRA)	PMDA	OIS	LA:PGCB	PGCB	BC: PGCB
NAME	SCroston	LHill	DBurnette for GTrussell	CHawes	SStuchell via email	MMurphy
DATE	4/08/2009	4/01/2009	4/17/2009	4/29/2009	4/29/2009	05/07/2009
OFFICE	D:DPR					
NAME	TMcGinty					
DATE	05/08/2009					

**OFFICIAL RECORD COPY**