

Summary of 2/11/09 NRC - PINGP License Renewal Conference Call

NRC Attendees: Rick Plasse, Bob Jackson

PINGP Attendees: Gene Eckholt, Bill O'Brien, Bill Roman, Bob Vincent

NRC requested clarification on a line item in Table 3.4.2-4 on page 3.4-75 for Flex Connections of stainless steel in an Outdoor Air - Sheltered environment. The line item has Note G (environment not in GALL) but points to a GALL Table 1 line for Indoor Air - Uncontrolled. Reviewer asked what the external environment actually is.

PINGP responded that the outdoor air sheltered environment is not in GALL. Reviewer was referred to Table 3.0-1 for the definition of the environment. The line in question is insulated and sheltered. As used in the LRA, the environments Outdoor Air - Sheltered and Indoor Air - Uncontrolled are equivalent. The humidity experienced in both environments would be the same. The LRA was confirmed to be correct as written.

PINGP understands the question and agreed to provide this clarification in a supplemental letter. RAIs will not be issued.