Rancho Seco

# Final Status Survey Summary Report

July 4, 2008

## Turbine Building (+) 0' El., Main Feed Pump Area

Prepared By:_	D. Anderoon	_Date:_	7/4/2008
	FSS Engineer		
Reviewed By:	Robut F Duln Lead FSS Engineer	_ Date:_	11/25/08
Approved By:	5-7 nantlement Superintendent	_ Date:_	2-27-09

### FINAL STATUS SURVEY SUMMARY REPORT

#### Survey Unit:

F8260032, Turbine Building (+) 0' El., Main Feed Pump Area

### Survey Unit Description:

Operating History: The reinforced concrete and steel structure contained the turbinegenerator and supporting systems. The building contained five main elevations. Residual radioactive material was known to be present on all levels of the interior of the building. Operating records and the HSA document several events with the potential for a release of radioactivity inside this structure.

Site Characterization: Direct measurements were made of each of the interior elevation surfaces as well as the exterior surfaces of the structure. These measurements confirmed the presence of plant-derived radionuclides. Direct measurements in the condenser pit elevation showed a mean gross activity level of 3,077 dpm/100 cm<sup>2</sup> and a maximum value of 24,900 dpm/100 cm<sup>2</sup>. Direct measurements on the grade elevation showed a mean gross activity level of 2,035 dpm/100 cm<sup>2</sup> and a maximum value of 6,980 dpm/100 cm<sup>2</sup>. Direct measurements on the grade elevation showed a mean gross activity level of 2,035 dpm/100 cm<sup>2</sup> and a maximum value of 6,980 dpm/100 cm<sup>2</sup>. Direct measurements on the mezzanine elevation showed a mean gross activity level of 1,566 dpm/100 cm<sup>2</sup> and a maximum value of 2,626 dpm/100 cm<sup>2</sup>. Direct measurements on the +40° elevation showed a mean gross activity level of 2,843 dpm/100 cm<sup>2</sup> and a maximum value of 3,615 dpm/100 cm<sup>2</sup>. Direct measurements on the building exterior showed a mean gross activity level of 1,984 dpm/100 cm<sup>2</sup> and a maximum value of 10,312 dpm/100 cm<sup>2</sup>. Based on the classification procedure (DSIP-0020) and levels of gross activity reported, the interior of the turbine building was determined to be Class 1, 2, & 3 areas and the exterior was a Class 3.

During FSS surveys of F8260032 (Turbine Building (+) 0' El., Main Feed Pump Area, Class 2), beta measurements identified activity within a 1-meter by 5-meter area that exceeded the DCGL of 43,000 dpm/100 cm<sup>2</sup>. The area was subsequently removed from this survey package, remediated and reclassified as a Class 1 structure, based on the classification procedure (DSIP-0020). Final surveys of the Class 1 area will be performed under survey package F8260171.

HSA Events: HSA Report pg. 63.

### Survey Unit Design Information:

The Survey Unit Design Parameters are presented in Table 1 below. The survey unit and measurement locations are depicted on the maps in Attachment 1. Direct measurement locations were determined using a random-start, fixed grid pattern and 100 m<sup>2</sup> were scanned for approximately 54% coverage. Samples of removable contamination were collected at each direct measurement location. The instrumentation used for the survey along with the MDC values are listed in Tables 2-1 and 2-2 in Attachment 2.

Survey Design Parameter	Value	Comment
Survey Area:	F826	Turbine Building (+) 0' El.,
		Main Feed Pump Area
Survey Unit:	0032	Structure Surface
Class:	. 2	LTP Table 5-4
<b>SU Area</b> (m <sup>2</sup> ):	186.2	
Evaluator:	D. Anderson	
<b>DCGL</b> (dpm/100 cm <sup>2</sup> ):	43,000	Gross Activity DCGL
Area Factor:	N/A	Class 2
Design DCGLemc	N/A	Class 2
$(dpm/100 cm^2)$ :		
<b>LBGR</b> (dpm/100 cm <sup>2</sup> ):	25,030	Adjusted
<b>Design Sigma</b> (dpm/100 cm <sup>2</sup> ):	5,990	
Type I Error:	0.05	
Type II Error:	0.05	· · ·
Predominant Nuclide:	Cs-137	
Sample Area (m <sup>2</sup> ):	13.3	Class 2
Scan Area $(m^2)$ :	100	
Scan Coverage (%):	54%	Class 2
$\mathbf{Z}_{1-\alpha}$ :	1.645	
$\mathcal{L}_{1-\beta}$ :	1.043	
Sign P:	0.99865	
Calculated Relative Shift:	3	Uses 2.0 :f Deleting Shift is
Relative Shift Used:		Uses 3.0 If Relative Shift is
NI Val-	11	>3
N = v  alue:	11	NUPEC 1575 Table 5 5
Design Min Samples No	. 14	Close 2
Crid Spacing I	3.0	
Griu Spacing L:	5.0	Ciass 2

# Table 1. Survey Unit Design Parameters

### **Survey Results:**

A total of 15 direct measurements were made in F8260032. The results including mean, median, standard deviation and range are shown in Table 2. All direct measurements were less than the DCGL. Two of the beta scan measurements indicated areas of elevated activity. Scan activity ranged from 4,218 to 68,000 dpm/100 cm<sup>2</sup>, based on a surveyor efficiency of 0.5 and no background subtracted. The scan grids indicating elevated activity were removed from the survey unit, remediated and resurveyed under FSS Package F8260171. As left beta scan measurements ranged from 4,218 dpm/100 cm<sup>2</sup> to 8,818 dpm/100 cm<sup>2</sup>. Samples for removable surface activity were all less than 10% of the DCGL as shown in Table 3. Removable surface activity samples were counted for alpha activity and none was detected at the MDC shown in Table 2-1 of Attachment 2.

Measurement ID	Gross Activity (dpm/100 cm²)
F8260032-C0001BD	2,552
F8260032-C0002BD	1,712
F8260032-C0003BD	1,577
F8260032-C0004BD	1,784
F8260032-C0005BD	1,644
F8260032-C0006BD	2,485
F8260032-C0007BD	2,329
F8260032-C0008BD	2,111
F8260032-C0009BD	1,930
F8260032-C0010BD	2,288
F8260032-C0011BD	2,770
F8260032-C0012BD	1,686
F8260032-C0013BD	1,924
F8260032-C0014BD	1,867
F8260032-C0015BD	2,039
Mean:	2,047
Median:	1,930
Standard Deviation:	365
Range:	1,577 – 2,770

#### **Table 2. Direct Measurement Results**

Measurement ID	Surface Beta Activity (dpm/100 cm²)
F8260032C0001SM	-2.24
F8260032C0002SM	-0.95
F8260032C0003SM	5.51
F8260032C0004SM	1.64
F8260032C0005SM	10.68
F8260032C0006SM	-3.53
F8260032C0007SM	-2.24
F8260032C0008SM	-3.53
F8260032C0009SM	2.93
F8260032C0010SM	-0.95
F8260032C0011SM	1.64
F8260032C0012SM	-0.95
F8260032C0013SM	-4.82
F8260032C0014SM	-0.95
F8260032C0015SM	0.34
Mean:	0.17
Median:	-0.95
Standard Deviation:	3.96
Range:	-4.82 to 10.68

## Table 3. Removable Surface Activity Results

### **Survey Unit Data Assessment:**

The survey design required 15 direct measurements for the Sign Test. The critical value and the results of the Sign Test are presented in Table 4. The sample mean and median values were less than the DCGL. The sample standard deviation was less than the design standard deviation so no additional samples were required.

Survey Results Parameter	Value	Comment
Material Background Used (dpm/100 cm <sup>2</sup> ):	N/A	
Ambient Background Used (dpm/100 cm <sup>2</sup> ):	N/A	Average Ambient BKG = 0
Actual Direct Measurements (N):	15	
<b>Median</b> (dpm/100 cm <sup>2</sup> ):	1,930	
<b>Mean</b> (dpm/100 cm <sup>2</sup> ):	2,047	
<b>Direct Measurement Standard Deviation</b>	365	
(dpm/100 cm <sup>2</sup> ):		
Total Standard Deviation (dpm/100 cm <sup>2</sup> ):	365	Based on samples and backgrounds.
Maximum (dpm/100 cm <sup>2</sup> ):	2,770	
Material Type:	N/A	Background Subtract Not
		Applied
Sign Test Final N Value:	15	
S+ Value:	15	
Critical Value:	11	
Sufficient Samples Collected:	Yes	
Maximum Value < DCGL:	Yes	
Median Value < DCGL:	Yes	
Mean Value < DCGL:	Yes	
Maximum Value < DCGLemc:	N/A	Class 2
Total Standard Deviation <= Sigma:	Yes	
Pass the Sign Test?	Yes	
<b>Reject the Null Hypothesis?</b>	Yes	
<b>Does the Survey Unit Pass All Criteria?</b>	Yes	

### Table 4. Data Assessment Results

## FSS Summary Report

### Survey Unit Investigations and Results:

Two investigations (scan grids 102 and 103) were required for the scan measurements and the results are reported in Attachment 3. As a result of the investigation measurements, Grids 102 through 106 were removed from the survey unit package and will be surveyed as a Class 1 structure under F8260171.

### ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL (i.e. the survey unit average activity is less than the DCGL and the EMC criterion has been met), the ALARA criterion has been met.

### Changes in Initial Survey Unit Assumptions:

The survey unit was designed as a Class 2 structure survey and the sample results are consistent with that classification. The variability of the survey results was less than the characterization data used for survey design. Two potential areas of elevated activity were detected and evaluated as shown in Attachment 3.

### Conclusion:

The FSS of this survey unit was properly designed as a Class 2 survey based on Table 5-4 of the LTP. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. No direct measurements exceeded the DCGL of 43,000 dpm/100 cm<sup>2</sup> and none of the removable surface activity measurements exceeded 10% of the DCGL. Two investigations were required.

The direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.

It is concluded that survey unit F8260032 meets the release criteria of 10CFR20.1402.

Attachment 1

Maps

July 4, 2008





Att. 1 Maps

Page 4 of 12

Att. 1 Maps















Page 9 of 12

Att. 1 Maps



Page 10 of 12

Att. 1 Maps

Page 11 of 12

ਭੂ 79BS step 78BS 77BS 76BS 75BS 74BS 73BS 72BS 24BS 36BS 👘 35BS **1** 70<u>\$S</u> 67BS 68BS 69BS 80BS 71BS ۲ 23BS ٠ 33BS 22BS 34BS 66BS 65BS 64BS 63**B**S 81BS 62BS 21BS 20BS \$7BS 58BS 59BS \_\_\_60₿S 82BS 61BS 19BS 53BS 56BS 55BS 54BS 18BS 17BS 15BS 16BS 48BS 46BS 47BS 45BS 49BS 50BS **51BS** 52BS 4185 44BS 42BS 40**B**S 38BS 37<u>BS</u> 83**B**S 39**B**S 43BS 3BS 10BS 101B 94BS 88BS 93BS 91BS 1BS 90BS 92BS 96BS 89BS 1.19 (-) 3' El. 🧱 (-) 6' El. 🔯 (-) 3.5' El. 🎆 istasba5 èdèstà Map F8260032-10, Turbine Building Main Feed Pump Area Beta Scan Measurements F8260032C0004000 (-) 1' El. 🎆 (-) 1.5' El. (+) 0' El. 🏼 F8260032C0001BS to F8260032C0101BS 0.5 1.0 1.5 Distance in Meters 2.0 0 0.5 Approximate Scan Area: 100 sq. meters

1 Maps

Att.

Page 12 of 12

Att. 1 Maps



Attachment 2

Instrumentation

July 4, 2008

Instrument Model; Serial No.	Detector Model; Serial No.	MDC Static (dpm/100 cm²)	MDC Scan (dpm/100 cm²)
M2350; 193700	43-68B; 190294	433	1,033
Tennelec; 0401171	N/A	5.88 dpm α, 11.71 dpm β	N/A

 Table 2-1. Survey Unit Instrumentation

## Table 2-2. Investigation Criteria and DCGL

Parameter	Value (dpm/100 cm²)		
Investigation Criteria - Direct	43,000		
Investigation Criteria – Scan	43,000		
DCGL <sub>W</sub>	43,000		
DCGL <sub>EMC</sub>	N/A		

Attachment 3

Investigation

July 4, 2008

Grid	Investigation Level (cpm)	Initial Value (cpm)	Investigation Result (cpm)	Elevated Area (m²)	Area Factor	DCGL <sub>emc</sub>	Investigation Result (dpm/100cm²)	DCGL <sub>emc</sub> Unity Fraction
102	5,860	9,278	8,633	0.1	N/A	N/A	44,780	N/A <sup>1</sup>
103	5,860	6,653	7,107	0.1	N/A	N/A	36,865	N/A <sup>1</sup>
					•			
			•.			•		
				_				
Survey Unit RemainderDCGL = 43,000SU Mean = 2,047					0.05			
EMC Unity Sum					0.05			

Table 3-1 Survey Unit Investigation

<sup>1</sup>Investigation measurements indicated activity exceeding the DCGL of 43,000 dpm/100 cm<sup>2</sup> for a Class 2 area. Grids 102 through106 were deleted from the survey unit and will be surveyed under FSS package F8260171.

Attachment 4

### Data Assessment

July 4, 2008



Page 2 of 4

Att. 4 Data Assessment

Page 3 of 4

Att. 4 Data Assessment





Page 4 of 4

Att. 4 Data Assessment