

ArevaEPRDCPEm Resource

From: Getachew Tesfaye
Sent: Tuesday, April 07, 2009 2:35 PM
To: 'usepr@areva.com'
Cc: Sara Bernal; Timothy Frye; Jason Jennings; Surinder Arora; Joseph Colaccino; ArevaEPRDCPEm Resource
Subject: Draft - U.S. EPR Design Certification Application RAI No. 214 (2525), FSAR Ch. 12
Attachments: Draft RAI_214_CHPB_2525.doc

Attached please find draft RAI No. 214 regarding your application for standard design certification of the U.S. EPR. If you have any question or need clarifications regarding this RAI, please let me know as soon as possible, I will have our technical Staff available to discuss them with you.

Please also review the RAI to ensure that we have not inadvertently included proprietary information. If there are any proprietary information, please let me know within the next ten days. If I do not hear from you within the next ten days, I will assume there are none and will make the draft RAI publicly available.

Thanks,
Getachew Tesfaye
Sr. Project Manager
NRO/DNRL/NARP
(301) 415-3361

Hearing Identifier: AREVA_EPR_DC_RAIs
Email Number: 380

Mail Envelope Properties (C56E360E9D804F4B95BC673F886381E71DBF4F50E1)

Subject: Draft - U.S. EPR Design Certification Application RAI No. 214 (2525), FSAR Ch.
12
Sent Date: 4/7/2009 2:35:14 PM
Received Date: 4/7/2009 2:35:16 PM
From: Getachew Tesfaye

Created By: Getachew.Tesfaye@nrc.gov

Recipients:

"Sara Bernal" <Sara.Bernal@nrc.gov>
Tracking Status: None
"Timothy Frye" <Timothy.Frye@nrc.gov>
Tracking Status: None
"Jason Jennings" <Jason.Jennings@nrc.gov>
Tracking Status: None
"Surinder Arora" <Surinder.Arora@nrc.gov>
Tracking Status: None
"Joseph Colaccino" <Joseph.Colaccino@nrc.gov>
Tracking Status: None
"ArevaEPRDCPEm Resource" <ArevaEPRDCPEm.Resource@nrc.gov>
Tracking Status: None
"usepr@areva.com" <usepr@areva.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	727	4/7/2009 2:35:16 PM
Draft RAI_214_CHPB_2525.doc		27642

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Draft

Request for Additional Information No. 214 (2525), Revision 0

4/7/2009

U. S. EPR Standard Design Certification

AREVA NP Inc.

Docket No. 52-020

SRP Section: 12.05 - Operational Radiation Protection Program

Application Section: Section 12.5, Operational Radiation Protection Program

QUESTIONS for Health Physics Branch (CHPB)

12.05-2

In response to RAI 192, Question No. 12.05-1, the applicant stated that COL information Item 12.5-1 and Table 1.8-2 would be updated to delete outdated RGs 8.20, 8.26 and 8.32. In addition, the reference to Part 72 was changed to Part 71. These changes are satisfactory. However, the RGs listed in Table 1.8-2 for COL information item 12.5-1 and the RGs listed in the COL item itself in section 12.5 of the FSAR are not consistent. Please modify COL item 12.5-1 in Table 1.8-2 so that it is identical to the COL item in Section 12.5 of the FSAR.