



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

April 13, 2009

Vice President, Operations
Entergy Operations, Inc.
Grand Gulf Nuclear Station
P.O. Box 756
Port Gibson, MS 39150

SUBJECT: GRAND GULF NUCLEAR STATION, UNIT 1 - CORRECTION TO AMENDMENT
NO. 182, SURVEILLANCE REQUIREMENTS FOR DIESEL GENERATOR
SLOW-START TESTING (TAC NO. MD9641)

Dear Sir or Madam:

On March 4, 2009, the Nuclear Regulatory Commission issued Amendment No. 182 to Facility Operating License No. NPF-29 for the Grand Gulf Nuclear Station, Unit 1. The amendment consisted of changes to the Technical Specifications (TSs) in response to your application dated September 11, 2008.

The amendment revised several surveillance requirements (SRs) and added SR 3.8.1.21 in Technical Specification (TS) 3.8.1, "AC [alternating current] Sources - Operating," and TS 3.8.2, "AC Sources - Shutdown."

An administrative error was discovered on TS page 3.8-16 of the amendment. In order to be consistent with the format of the TSs, the criteria listed in new SR 3.8.1.21 should be labeled as "a" and "b" instead of "1" and "2." The correct formatting was included in the marked-up version of the TS page included in your application.

A copy of the corrected TS page 3.8-16 is enclosed. If you have any questions regarding this matter, please contact me at 301-415-2296.

Sincerely,

A handwritten signature in black ink, appearing to read "C. Lyon".

Carl F. Lyon, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-416

Enclosure:
As stated

cc w/encl: Distribution via Listserv

ENCLOSURE

GRAND GULF NUCLEAR STATION, UNIT 1

CORRECTED TS PAGE 3.8-16 FOR AMENDMENT NO. 182

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.20 -----NOTE----- All DG starts may be preceded by an engine prelube period. -----</p> <p>Verify, when started simultaneously from standby condition, each DG achieves:</p> <ul style="list-style-type: none"> a. in ≤ 10 seconds, voltage ≥ 3744 V and frequency ≥ 58.8 Hz; and b. steady state voltage ≥ 3744 V and ≤ 4576 V and frequency ≥ 58.8 Hz and ≤ 61.2 Hz. 	<p>10 years</p>
<p>SR 3.8.1.21 -----NOTE----- All DG starts may be preceded by an engine prelube period and followed by a warmup period prior to loading. -----</p> <p>Verify each DG starts from standby conditions and achieves:</p> <ul style="list-style-type: none"> a. in ≤ 10 seconds, voltage ≥ 3744 V and frequency ≥ 58.8 Hz; and b. steady state voltage ≥ 3744 V and ≤ 4576 V and frequency ≥ 58.8 Hz and ≤ 61.2 Hz. 	<p>184 days</p>

April 13, 2009

Vice President, Operations
Entergy Operations, Inc.
Grand Gulf Nuclear Station
P.O. Box 756
Port Gibson, MS 39150

SUBJECT: GRAND GULF NUCLEAR STATION, UNIT 1 - CORRECTION TO AMENDMENT
NO. 182, SURVEILLANCE REQUIREMENTS FOR DIESEL GENERATOR
SLOW-START TESTING (TAC NO. MD9641)

Dear Sir or Madam:

On March 4, 2009, the Nuclear Regulatory Commission issued Amendment No. 182 to Facility Operating License No. NPF-29 for the Grand Gulf Nuclear Station, Unit 1. The amendment consisted of changes to the Technical Specifications (TSs) in response to your application dated September 11, 2008.

The amendment revised several surveillance requirements (SRs) and added SR 3.8.1.21 in Technical Specification (TS) 3.8.1, "AC [alternating current] Sources - Operating," and TS 3.8.2, "AC Sources - Shutdown."

An administrative error was discovered on TS page 3.8-16 of the amendment. In order to be consistent with the format of the TSs, the criteria listed in new SR 3.8.1.21 should be labeled as "a" and "b" instead of "1" and "2." The correct formatting was included in the marked-up version of the TS page included in your application.

A copy of the corrected TS page 3.8-16 is enclosed. If you have any questions regarding this matter, please contact me at 301-415-2296.

Sincerely,
/RA/
Carl F. Lyon, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-416

Enclosure:
As stated

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC
LPLIV r/f
RidsAcraAcnw_MailCTR Resource
RidsNrrDorLpl4 Resource
RidsNrrLAJBurkhardt Resource
RidsNrrPMGrandGulf Resource
RidsOgcRp Resource
RidsRgn4MailCenter Resource

ADAMS Accession No. ML090980429

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/LPL4/BC	NRR/LPL4/PM
NAME	FLyon	JBurkhardt	MMarkley BSingal for	FLyon
DATE	4/9/09	4/9/09	4/9/09	4/13/09

OFFICIAL RECORD COPY