MITSUBISHI HEAVY INDUSTRIES, LTD.

16-5, KONAN 2-CHOME, MINATO-KU

TOKYO, JAPAN

April 17, 2009

Document Control Desk U.S. Nuclear Regulatory Commission Washington, DC 20555-0001

Attention: Mr. Jeffrey A. Ciocco

Docket No. 52-021 MHI Ref: UAP-HF-09175

Subject: MHI's Amended Response to US-APWR DCD RAI No.225-2029 Revision 1

Reference: 1) "MHI's Response to US-APWR DCD RAI No.225-2029 Revision 1," MHI Ref: UAP-HF-09104, dated March 26, 2009.

> 2) "Request for Additional Information No. 225-2029 Revision 1, SRP Section: 05.03.03 - Reactor Vessel Integrity," dated February 26, 2009.

With this letter, Mitsubishi Heavy Industries, Ltd. ("MHI") transmits to the U.S. Nuclear Regulatory Commission ("NRC") a document entitled "Amended Response to Request for Additional Information No. 225-2029 Revision 1." This amended response is submitted to correct the typographical error of the DCD subsection referenced in the response and DCD subsection 5.3.3.5 revision proposed in Reference 1.

Enclosed is the amended response to Question 05.03.03-1 contained within Reference 2. MHI replaces the previous letter (Reference 1) with this amended response letter.

Please contact Dr. C. Keith Paulson, Senior Technical Manager, Mitsubishi Nuclear Energy Systems, Inc. if the NRC has questions concerning any aspect of the submittals. His contact information is below.

Sincerely,

y. Og utu

Yoshiki Ogata, General Manager- APWR Promoting Department Mitsubishi Heavy Industries, LTD.

Enclosure:

1. Amended Response to Request for Additional Information No. 225-2029 Revision 1

CC: J. A. Ciocco C. K. Paulson **Contact Information**

C. Keith Paulson, Senior Technical Manager Mitsubishi Nuclear Energy Systems, Inc. 300 Oxford Drive, Suite 301 Monroeville, PA 15146 E-mail: ck_paulson@mnes-us.com Telephone: (412) 373-6466

Docket No. 52-021 MHI Ref: UAP-HF-09175

Enclosure 1

UAP-HF-09175 Docket No. 52-021

Amended Response to Request for Additional Information No. 225-2029 Revision 1

April 2009

RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

4/17/2009

US-APWR Design Certification Mitsubishi Heavy Industries Docket No. 52-021

RAI NO.:	NO. 225-2029 REVISION 1
SRP SECTION:	05.03.03 - REACTOR VESSEL INTEGRITY
APPLICATION SECTION:	05.03.03
DATE OF RAI ISSUE:	2/26/2009

QUESTION NO. : 05.03.03-1

Section 5.3.3.5 of the US-APWR DCD, Tier 2, Revision 1 describes methods used to protect the integrity of the reactor vessel (RV) during shipping, arrival on-site, and installation. However, the DCD does not describe measures taken to ensure the proper cleanliness and freedom from contamination of the RV prior to shipment. Please describe the methods used to ensure the proper cleanliness and freedom from contamination of the RV prior to shipment.

ANSWER:

Measures taken to ensure proper cleanliness and freedom from contamination of the reactor vessel prior to shipment are discussed in DCD Subsection 5.3.1.4.3. A reference to this subsection will be added in DCD Subsection 5.3.3.5.

In addition, the outer surfaces of the reactor vessel are protected with temporary coverings prior to shipment. A description of this will also be added to DCD Subsection 5.3.3.5.

Impact on DCD

The third paragraph of DCD Subsection 5.3.3.5, Shipment and Installation, will be revised as follows:

Prior to shipment, the reactor vessel is cleaned and protected from contamination as described in Subsection 5.3.1.4.3. Outer surfaces of the reactor vessel are also normally protected with temporary coverings prior to shipment. Further details concerning the C_cleanliness and protection against contamination for austenitic stainless steel parts of the reactor vessel are discussed in Subsection 5.2.3.4.

Impact on COLA

There is no impact on the COLA.

Impact on PRA

There is no impact on the PRA.

2