

PrairieIslandNPEm Resource

From: Vincent, Robert [Robert.Vincent@xenuclear.com]
Sent: Wednesday, April 15, 2009 3:49 PM
To: Richard Plasse
Cc: Eckholt, Gene F.; Lindberg, Philip
Subject: PINGP Turbine Valve Testing TRM 3.7.3 .pdf
Attachments: Turbine Valve Testing TRM 3.7.3 .pdf

As you requested - here is the TRM section addressing turbine valve testing.

Bob Vincent

Hearing Identifier: Prairie_Island_NonPublic
Email Number: 1002

Mail Envelope Properties (9FA1D9F2F220C04F95D9394E3CF02DAB013A725A)

Subject: PINGP Turbine Valve Testing TRM 3.7.3 .pdf
Sent Date: 4/15/2009 3:49:20 PM
Received Date: 4/15/2009 3:49:25 PM
From: Vincent, Robert

Created By: Robert.Vincent@xenuclear.com

Recipients:

"Eckholt, Gene F." <Gene.Eckholt@xenuclear.com>
Tracking Status: None
"Lindberg, Philip" <Philip.Lindberg@xenuclear.com>
Tracking Status: None
"Richard Plasse" <Richard.Plasse@nrc.gov>
Tracking Status: None

Post Office: enex02.ft.nmcco.net

Files	Size	Date & Time
MESSAGE	92	4/15/2009 3:49:25 PM
Turbine Valve Testing TRM 3.7.3 .pdf		651685

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

TRM 3.7 PLANT SYSTEMS

TRM 3.7.3 Turbine Overspeed Protection

TLCO 3.7.3 Turbine stop valves, governor valves and intercept valves shall be stroke tested.

APPLICABILITY: MODES 1 and 2

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Testing not performed within prescribed time	A.1 Perform testing	7 days
B. Required Actions and associated Completion Times of Condition A not met.	B.1 Be in MODE 3	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
TSR 3.7.3.1 Perform valve stroke testing.	Frequency of testing shall be consistent with the methodology presented in WCAP-11525 "Probabilistic Evaluation of Reduction in Turbine Valve test Frequency", and in accordance with the established NRC acceptance criteria for the probability of a turbine missile ejection incident of 1.0×10^{-5} per year. In no case shall the turbine valve test interval exceed one year.