

Valve Alignment - generate SAP report on administration day; ensure terminal available

NCO watchstanding duties – unacceptable, non-discriminatory, replace

Non-Emergency Diesel Ops – add steps for EDG S/D

Containment Isolation - Add 12 ½ " isolations, add one additional valve out of position

Open MSIVs – add cues for pressure equalization

Manually Start Core Spray – add note to remind examiner when CS will actually inject