

SER Appendix A: Commitments for License Renewal Of Oyster Creek Generating Station

Commitment No. 27, ASME Section XI, Subsection IWE

- UFSAR Supplement Section A.1.27
- LRA Section B.1.27
- Existing program is credited. The program will be enhanced to include:

Commitment No. 27, Item (3) The reactor cavity seal leakage trough drains and the drywell sand bed region drains will be monitored for leakage. (Periodically)

Commitment No. 27, Item (13) The reactor cavity concrete trough drain will be verified to be clear from blockage once per refueling cycle. Any identified issues will be addressed via the corrective action process. (Once per refueling cycle)