

PMSTPCOL PEmails

From: Adrian Muniz
Sent: Tuesday, April 07, 2009 9:56 AM
To: rhbense@stpegs.com
Cc: STPCOL
Subject: Draft RAI for Section 8.1
Attachments: Draft RAI 2286.doc

Richard:

I have attached to this electronic communication a draft request for additional information (RAI) for Section 8.1 of the STP COLA. Contact me to schedule a conference call to ensure that STP's understanding of the RAI is clear.

Adrian Muñiz, Project Manager
NRC

Hearing Identifier: SouthTexas34Public_EX
Email Number: 1181

Mail Envelope Properties (3DF2506A7257014AAC5857E5E852DEAC05E2D61DFF)

Subject: Draft RAI for Section 8.1
Sent Date: 4/7/2009 9:56:12 AM
Received Date: 4/7/2009 9:56:13 AM
From: Adrian Muniz

Created By: Adrian.Muniz@nrc.gov

Recipients:
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"rhbense@stpegs.com" <rhbense@stpegs.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	297	4/7/2009 9:56:13 AM
Draft RAI 2286.doc	28154	

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Draft Request for Additional Information No. 2286 Revision 2

South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013
SRP Section: 08.01 - Electric Power - Introduction
Application Section: SRP 8.1

QUESTIONS for Electrical Engineering Branch (EEB)

08.01-***

FSAR Section 8.1, Table 8.1-1 does not include the following Regulatory Guides: RG 1.160, "Monitoring the effectiveness of Maintenance at Nuclear Power Plants;" RG 1.180, "Guidelines for Evaluating Electromagnetic and Radio-Frequency Interference in Safety-Related Instrumentation and Control Systems," RG 1.182, "Assessing and Managing Risk before Maintenance Activities at Nuclear Power Plants;" and RG 1.204, "Guideline for Lightning Protection at Nuclear Power Plants." Discuss their applicability to STP.