

NATIONAL AMUSEMENTS

April 24, 2009

Director, Office of Federal and State Materials and
Environmental Management Programs
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Dear Director:


As a response to your Demand for Information letter dated January 16, 2009, National Amusements provides the following information per section III:

- A. All handling of transfer and disposal of Tritium exit signs are by 3rd party licensed electrical and emergency lighting contractors. Twice yearly inspections are done by these 3rd party contractors and local management of our facilities do daily routine checks of all areas of the theatres. I am the person responsible for ensuring day to day compliance with these requirements.
- B. Our survey shows 1579 Tritium exit signs in our possession with no signs missing.
- C. There are no discrepancies noted.
- D. We plan to notify the NRC when any specific signs are noted missing. Local management will notify me and local authorities (as appropriate) of the missing sign(s) including the relevant serial number(s). Local management will also notify our 3rd party contractors of the missing sign so that a replacement can be obtained and new serial numbers filed.
- E. In our experience, any signs that go missing are stolen by theatre patrons in the rear exits of the theatre. While we are diligent in our security measures (including closed circuit TV and security details), we are unable to fully prevent all such losses.

I attest that, to the best of my knowledge, the above statements and information are true and correct.

Please feel free to contact me with any questions you may have.

Kindest regards,



Steven Horton
Assistant Vice President, Operations
shorton@national-amusements.com
(781) 461-1600 x370