

John Richmond

From: John Richmond, R I
Sent: Tuesday, November 11, 2008 9:09 AM
To: 'stevie.dupont@exeloncorp.com'
Cc: Calvin.Taylor@exeloncorp.com
Subject: RE: Open Item Close-out

I have reviewed the posted items.

Please close the following items:

- 71331
- 71351
- 71361
- 71461
- 71861

That leaves two open items [71371 & 71431]

ONE Follow-up Question.

Regarding the moisture barrier seal inside the drywell, between the floor curb and steel liner. Portions of the seal had to be removed (interference) to allow the UT's to be performed on elev 11 ft. After portions of the seal was re-installed, it should have been re-inspected. Please provide the post repair/re-installation inspection record.

Thanks
John Richmond

From: stevie.dupont@exeloncorp.com [mailto:stevie.dupont@exeloncorp.com]
Sent: Monday, November 10, 2008 4:46 PM
To: John Richmond
Cc: Calvin.Taylor@exeloncorp.com
Subject: posted

Posted reports for 71351 & 71361 and report for 71331. Status of open items pasted as Open Status Report 11-10

***** This e-mail and any of its attachments may contain Exelon Corporation proprietary information, which is privileged, confidential, or subject to copyright belonging to the Exelon Corporation family of Companies. This e-mail is intended solely for the use of the individual or entity to which it is addressed. If you are not the intended recipient of this e-mail, you are hereby notified that any dissemination, distribution, copying, or action taken in relation to the contents of and attachments to this e-mail is strictly prohibited and may be unlawful. If you have received this e-mail in error, please notify the sender immediately and permanently delete the original and any copy of this e-mail and any printout. Thank You. *****

B/71

Received: from R1CLSTR01.nrc.gov ([148.184.99.7]) by R1MS01.nrc.gov
([148.184.99.10]) with mapi; Tue, 11 Nov 2008 09:08:55 -0500
Content-Type: application/ms-tnef; name="winmail.dat"
Content-Transfer-Encoding: binary
From: John Richmond <John.Richmond@nrc.gov>
To: "stevie.dupont@exeloncorp.com" <stevie.dupont@exeloncorp.com>
CC: "Calvin.Taylor@exeloncorp.com" <Calvin.Taylor@exeloncorp.com>
Date: Tue, 11 Nov 2008 09:08:55 -0500
Subject: RE: Open Item Close-out
Thread-Topic: Open Item Close-out
Thread-Index: AclDfbVBnlZfB76qQEyrriyCJnILGgAiA64w
Message-ID: <2856BC46F6A308418F033D973BB0EE72AA43632901@R1CLSTR01.nrc.gov>
References:
<53EC8803AC832C4198D6C456E8C3300C020D09A7@CCCMSXCH02.energy.power.corp>
In-Reply-To:
<53EC8803AC832C4198D6C456E8C3300C020D09A7@CCCMSXCH02.energy.power.corp>
Accept-Language: en-US
Content-Language: en-US
X-MS-Has-Attach:
X-MS-Exchange-Organization-SCL: -1
X-MS-TNEF-Correlator:
<2856BC46F6A308418F033D973BB0EE72AA43632901@R1CLSTR01.nrc.gov>
MIME-Version: 1.0