

From: Bhalchandra Vaidya
Sent: Thursday, April 23, 2009 2:46 PM
To: 'dlfilchner@pplweb.com'; 'O'Rourke, Brenda W'; 'ckhoffman@pplweb.com'
Cc: Douglas Pickett; John Boska; Richard Guzman
Subject: Supplemental Information Required for Acceptance Review - Amd Application, PLA-6480 (Re: T-20)

Subject: Amendment Request Re: one-time Extension of AOT for Replacement of T-20 Transformer, TAC Nos. ME0969 & ME0970

Electrical Engineering Branch (EEEB) requires the following topic addressed in order to complete its acceptance review:

=====

GDC 17 requires two offsite circuits and the licensee's LAR does not mention a compensatory measure to replace the circuit normally provided by the ST 20 transformer during this extended outage time. Each of these two circuits shall be designed to be available in sufficient time following a loss of all onsite alternating current power supplies and the other offsite electric power circuit, to assure that specified acceptable fuel design limits and design conditions of the reactor coolant pressure boundary are not exceeded (safe shutdown). The ST 10 circuit satisfies the requirement that one of these circuits shall be designed to be available within a few seconds following a loss-of-coolant accident to assure that core cooling, containment integrity, and other vital safety functions are maintained.

=====

Please note that the time is an important factor. Please let me know when we can have the teleconference to clarify the supplemental information requirement. The reviewer is going to be out-of-office next week, so tomorrow AM (I am leaving at 10:30am) is most preferred. Otherwise, it may be delayed until end of next week.

Bhalchandra K. Vaidya
Licensing Project Manager
NRC/NRR/DORL/LPL1-1
(301)-415-3308 (O)
bhalchandra.vaidya@nrc.gov

E-mail Properties

Mail Envelope Properties ()

Subject: Supplemental Information Required for Acceptance Review - Amd Application, PLA-6480 (Re: T-20)
Sent Date: 04/23/2009 1:10:39 PM
Received Date: 04/23/2009 2:45:00 PM
From: Bhalchandra Vaidya

Created By: Bhalchandra.Vaidya@nrc.gov

Recipients:

dlfilchner@pplweb.com ('dlfilchner@pplweb.com')
Tracking Status: None
BWORourke@pplweb.com ('O'Rourke, Brenda W')
Tracking Status: None
ckhoffman@pplweb.com ('ckhoffman@pplweb.com')
Tracking Status: None
Douglas.Pickett@nrc.gov (Douglas Pickett)
Tracking Status: None
John.Boska@nrc.gov (John Boska)
Tracking Status: None
Richard.Guzman@nrc.gov (Richard Guzman)
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	13641	04/23/2009

Options

Expiration Date:

Priority: olImportanceNormal

ReplyRequested: False

Return Notification: False

Sensitivity: olNormal

Recipients received: