

PMSTPCOL PEmails

From: Tom Tai
Sent: Thursday, May 07, 2009 1:46 PM
To: STPCOL
Subject: STP RAI 2701 Telecon
Attachments: RAI 2701 03.05.01-xx.doc

STP requested a telephone conference on the subject RAI.

Tom Tai
DNRL/NRO
(301) 415-8484
Tom.Tai@NRC.GOV

Hearing Identifier: SouthTexas34Public_EX
Email Number: 1217

Mail Envelope Properties (C56E360E9D804F4B95BC673F886381E71F4088BAE1)

Subject: STP RAI 2701 Telecon
Sent Date: 5/7/2009 1:46:04 PM
Received Date: 5/7/2009 1:46:05 PM
From: Tom Tai

Created By: Tom.Tai@nrc.gov

Recipients:
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	138	5/7/2009 1:46:05 PM
RAI 2701 03.05.01-xx.doc		25154

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 2701 Revision 2

South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013
SRP Section: 03.05.01.02 - Internally Generated Missiles (Inside Containment)
Application Section: FSAR 3.5

QUESTIONS for Balance of Plant Branch 2 (ESBWR/ABWR) (SBPB)

03.05.01.02-***

In Subsection 3.5.4.6, "Maintenance Equipment Missile Prevention Inside Containment," of the STP 3/4 COL application FSAR, Revision 2, STPNOC (applicant) commits to establish procedural controls to ensure that unsecured maintenance equipment will be removed from containment prior to operation, moved to a safe location, or restrained to prevent it from becoming a missile. However, STPNOC has not provided a schedule as when these procedural controls will be implemented. Therefore, provide the schedule for when the procedural controls will be implemented. The NRC staff believes that these procedural controls should be in-place prior to fuel load.