

John Richmond

From: Darrell Roberts, *DR*
Sent: Thursday, October 30, 2008 7:30 PM
To: John Richmond
Cc: Richard Conte; Ronald Bellamy
Subject: RE: OC LRI Daily Update Oct 30

John,

Please keep me updated on the feasibility of my coming up there next week. I know Dave L. has been in the drywell, and if you are considering delaying the exit meeting, I want to get a feel for whether you think it's worthwhile for me to still come. I can always schedule another visit later - at a time commensurate with your exit, and which presents less burden to the licensee (since a regional executive has already been there this week).

Rich C. or Ron B. feel free to weigh in as well.

DJR

From: John Richmond
Sent: Thursday, October 30, 2008 6:14 PM
To: Richard Conte; Darrell Roberts; Ronald Bellamy
Cc: Jeffrey Kulp; Stephen Pindale; Michael Modes; Glenn Meyer; Marjorie McLaughlin; Justin Heinly; Timothy OHara; Diane Screnci; Joseph Schoppy
Subject: OC LRI Daily Update Oct 30

OC LRI Outage Commitments Inspection Day 4

Inspection Progress

- 1) Progress remains Slow. Drywell NDE activities are 3 to 4 days behind. Other non-critical path outage work has also slipped.
- 2) Coordination between their LR people and outage work management has improved *slightly*.
- 3) I informed AmerGen if they don't have sufficient NDE data available for our review early next week, I may need to delay the Exit.

Inspection Schedule

- 1) Glenn Meyer left yesterday. Tim O'Hara left today. Michael and I will continue tomorrow (Friday).
- 2) No weekend outage inspection, based on their slow NDE progress.
- 3) I will be here Monday, with Paul Kaufman (he returns for ISI and may also help with LR).

Today's Inspection Activities

- 1) Tim O'Hara inspected 3 sandbeds (plus 1 yesterday for a total of 4). Conditions inside those sandbeds look about the same as 2 years ago. Some questions about cracks in the sandbed cavity floors, outside the scope of a LR commitment or the ASME IWE program requirements.
- 2) Periodic Inspection of a condensate system expansion joint. Nothing noteworthy.

LR Commitment Issues or Concerns

None.

Drywell Structural Integrity Issues or Concerns

None. Initial NDE data is too little to draw any conclusion from.

NJ State Interface

Good. Rich Pinney said he was satisfied with our inspection efforts and had no concerns or issues.

Team Location: OCAB 2nd Floor, Visiting Exec Office, 609-9714830

Received: from R1CLSTR01.nrc.gov ([148.184.99.7]) by R1MS01.nrc.gov
([148.184.99.10]) with mapi; Thu, 30 Oct 2008 19:30:00 -0400
Content-Type: application/ms-tnef; name="winmail.dat"
Content-Transfer-Encoding: binary
From: Darrell Roberts <Darrell.Roberts@nrc.gov>
To: John Richmond <John.Richmond@nrc.gov>
CC: Richard Conte <Richard.Conte@nrc.gov>, Ronald Bellamy
<Ronald.Bellamy@nrc.gov>
Date: Thu, 30 Oct 2008 19:29:58 -0400
Subject: RE: OC LRI Daily Update Oct 30
Thread-Topic: OC LRI Daily Update Oct 30
Thread-Index: Ack4gKEiWwVCI7a9S2m9I7wfCwca0QAyjWwwAGMnHFAAA+Du4A==
Message-ID: <2856BC46F6A308418F033D973BB0EE72AA43774A14@R1CLSTR01.nrc.gov>
References: <2856BC46F6A308418F033D973BB0EE72AA4363288D@R1CLSTR01.nrc.gov>
<2856BC46F6A308418F033D973BB0EE72AA43632890@R1CLSTR01.nrc.gov>
<2856BC46F6A308418F033D973BB0EE72AA436328A3@R1CLSTR01.nrc.gov>
In-Reply-To: <2856BC46F6A308418F033D973BB0EE72AA436328A3@R1CLSTR01.nrc.gov>
Accept-Language: en-US
Content-Language: en-US
X-MS-Has-Attach:
X-MS-Exchange-Organization-SCL: -1
X-MS-TNEF-Correlator:
<2856BC46F6A308418F033D973BB0EE72AA43774A14@R1CLSTR01.nrc.gov>
MIME-Version: 1.0