



# State of New Jersey

## DEPARTMENT OF ENVIRONMENTAL PROTECTION

Division of Environmental Safety and Health  
Radiation Protection and Release Prevention Element  
Bureau of Nuclear Engineering  
P. O. Box 415  
Trenton, New Jersey 08625-0415  
Tel (609) 984-7700  
Fax (609) 984-7513

JON S. CORZINE  
*Governor*

MARK N. MAURIELLO  
*Acting Commissioner*

May 20, 2009

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Dear Commissioners:

Subject: Salem Generating Station Units 1 and 2  
Docket Nos. 50-272 and 50-311  
License Amendment Request S09-01  
Request for Change to Technical Specifications  
Definition of Fully Withdrawn Rod Cluster Control Assemblies

PSEG Nuclear LLC submitted the proposed change to the Salem Technical Specifications by letter to the NRC dated March 22, 2009. The proposed amendment would revise the definition of the fully withdrawn position of the Rod Cluster Control Assemblies (RCCA) to minimize local RCCA wear. This change would revise the definition of fully withdrawn from between 222 and 228 steps above rod bottom to between 222 and 230 steps above rod bottom.

The BNE has no comments on the proposed change. If you need to discuss this subject further, please contact Elliot Rosenfeld at (609) 984-7548.

Sincerely,

Patrick Mulligan, Manager  
Bureau of Nuclear Engineering

A001  
NRB

Distribution

Dr. Jill Lipoti, DEP

Paul Baldauf, DEP

Elliot Rosenfeld, DEP

Nancy McNamara, NRC Region 1

Rick Ennis, NRC Licensing Project Manager

Christine Neely, Director – Regulatory Assurance, PSEG Nuclear LLC

William Mattingly, Regulatory Assurance Manager, Salem Generating Station