

Facility: <b>PALISADES</b>	Scenario No.: <b>ONE</b>	Op-Test No.: <b>1</b>
Examiners: _____		Operators: _____
_____		_____
_____		_____
Initial Conditions: 74% power. P-54A, Containment Spray Pump out of service for seal cooler inspection (SI28).		
Turnover: Shift orders are to continue the power escalation at 4% per hour.		

Event No.	Malf. No.	Event Type*	Event Description
1	N/A	SRO(N) RO(R) BOP(N)	Power escalation
2	CC02	SRO(C) RO(C)	P-52A, Component Cooling Water Pump Trips (STANDBY pumps fail to start)
3	FT01B	SRO(C) BOP(C)	'B' Main Feedwater Pump trips
4	CH03AA	SRO(C)	V-1A, Containment Air Cooling Fan, trips
5	MS03A	ALL (C)	'A' S/G Main Steam Line Leak Inside Containment (small leak requiring a manual plant trip)
6	Override	RO(I) BOP(I)	C-02 Reactor Trip P/B fails (requires trip from C-06)
7	MS03A	ALL (M)	ESDE inside containment (ramped in at time of trip)
8	CH05A	SRO (I) RO (I)	Left Channel Containment Spray fails to actuate

\* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor