


# Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
○						11.7	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
○	B-3002	SS-12	38.5/180.39	11/30/06		SAND, with silty clay (SP-SC)		

Client GPC c/o SNOC	<b>MACTEC ENGINEERING AND CONSULTING, INC.</b>	○ Tested by: EH    Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286      Figure 7660		

# Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0						6.3	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-3002	SS-15	53.5/165.39	11/30/06		SAND, with silty clay (SP-SC)			

Client GPC c/o SNOC	<b>MACTEC ENGINEERING AND CONSULTING, INC.</b>	○ Tested by: EH    Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286      Figure 7661		



# Particle Size Distribution Report



% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.5	33.6	50.2	15.7	


SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-3002	SS-17	63.5/155.39	11/30/06	SC	SAND, clayey (SC)	47.0	137	31

Client GPC c/o SNOC  
 Project Vogtle Units 3 & 4 COL Project  
 Project No. 6141-06-0286      Figure 7662

**MACTEC ENGINEERING  
AND  
CONSULTING, INC.**

Tested by: EH    Reviewed by: HJ

# Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.3	0.8	1.4	97.5	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-3002	SS-22	88.5/130.39	11/30/06	MH	Silt (MH)	47.9	93	46

Client GPC c/o SNOC	<b>MACTEC ENGINEERING AND CONSULTING, INC.</b>	Tested by: EH Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286      Figure 7663		

# Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.0	1.8	28.0	70.2	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-3002	SS-25	108.5/110.39	11/30/06	CH	CLAY with sand (CH)	33.4	93	35

Client GPC c/o SNOC	<b>MACTEC ENGINEERING AND CONSULTING, INC.</b>	○ Tested by: EH    Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286      Figure 7664		

# Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0						75.1	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-3002	UD-1	97.0/121.89	11/30/06		SILT (MH)		94	40

Client GPC c/o SNOC	<b>MACTEC ENGINEERING AND CONSULTING, INC.</b>	○ Tested by: EH    Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286      Figure 7502		

# Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0						46.1	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-3002	UD-2	113.5/105.39	11/30/06		SAND, silty (SM)		85	35

Client GPC c/o SNOC	<b>MACTEC ENGINEERING AND CONSULTING, INC.</b>	○ Tested by: EH    Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286      Lab no. 7503		

# Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
						33.3	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-3003	SS-2	1.5/216.79	11/27/06		SAND, clayey (SC)			

Client GPC c/o SNOC	<b>MACTEC ENGINEERING AND CONSULTING, INC.</b>	○ Tested by: EH    Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286      Figure 7665		



# Particle Size Distribution Report



% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0						18.9	


SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-3003	SS-4	6.0/212.29	11/27/06		SAND, silty (SM)			

Client GPC c/o SNOC  
 Project Vogtle Units 3 & 4 COL Project  
 Project No. 6141-06-0286      Figure 7666

**MACTEC ENGINEERING  
 AND  
 CONSULTING, INC.**

Tested by: EH    Reviewed by: HJ

# Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0						14.7	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-3003	SS-9	23.5/194.79	11/28/06		SAND, silty (SM)			

Client GPC c/o SNOC	<b>MACTEC ENGINEERING AND CONSULTING, INC.</b>	○ Tested by: EH    Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286      Figure 7667		

# Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0						55.3	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-3003	SS-11	33.5/184.79	11/28/06		Silt, sandy (ML)			

Client GPC c/o SNOC	<b>MACTEC ENGINEERING AND CONSULTING, INC.</b>	○ Tested by: EH    Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286      Figure 7668		

# Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
						10.1	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-3003	SS-15	53.5/164.79	11/28/06		SAND, with silt (SP-SM)			

Client GPC c/o SNOC	<b>MACTEC ENGINEERING AND CONSULTING, INC.</b>	○ Tested by: EH    Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286      Figure 7669		

# Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0						15.4	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-3003	SS-16	58.5/159.79	11/28/06		SAND, silty (SM)			

Client GPC c/o SNOC	<b>MACTEC ENGINEERING AND CONSULTING, INC.</b>	<input type="checkbox"/> Tested by: EH    Reviewed by: HJ Test Date: 6/5/07    Review Date: 6/19/07
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286      Figure 7670		

# Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.0	0.3	4.3	95.4	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-3003	SS-22	88.5/129.79	11/28/06	MH	SILT (MH)	42.3	98	45

Client GPC c/o SNOC	<b>MACTEC ENGINEERING AND CONSULTING, INC.</b>	○ Tested by: EH    Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286      Figure 7671		



# Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.2	2.0	9.5	88.3	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-3003	SS-23	93.5/124.79	11/28/06	MH	SILT (MH)	48.8	95	43

Client GPC c/o SNOC	<b>MACTEC ENGINEERING AND CONSULTING, INC.</b>	○ Tested by: EH    Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286      Figure 7672		

# Particle Size Distribution Report



% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	37.0	6.1	4.0	12.1	40.8	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-3003	SS-24	113.5/104.79 ft.	1/30/07	GM	SHELL HASH, silty with sand (GM)	22.0	60	32

Client GPC c/o SNOC	<b>MACTEC ENGINEERING AND CONSULTING, INC.</b>	○ Tested by: EH    Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286      Lab no. 7673		