


Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.3	14.5	56.4	28.8	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4003	SS-10	28.5/190.49	11/16/06		SAND, clayey (SC)	22.4		

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: EH Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286 Figure 7753		

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
○						20.3	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
○ B-4003	SS-14	48.5/170.49	11/16/06		SAND, clayey (SC)			

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	○ Tested by: EH Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286 Figure 7754		

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0						94.1	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4003	SS-24	98.5/120.49	11/27/06		SILT (MH)	50.8	98	51

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: EH	Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project			
Project No. 6141-06-0286		Figure 7755	

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	1.6	0.8	7.4	27.2	63.0	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4003	SS-26	108.5/110.49	12/5/06	MH	SILT, sandy (MH)	30.2	61	32

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: EH	Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project			
Project No. 6141-06-0286		Figure 7756	

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.0	0.8	24.9	74.3	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4003	SS-32	148.5/70.49	12/6/06	CL	CLAY, with sand (CL)	25.5	45	25

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: EH Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286 Figure 7757		

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
○						18.3	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
○	B-4003	UD-5	201.0/17.99	12/8/06	SAND, silty (SM)			

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	○ Tested by: EH Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286 Figure 7566		

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
						17.8	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4003	UD-6	248.5/-29.51	12/12/06		SAND, silty (SM)			

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	○ Tested by: EH Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286 Figure 7567		

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.4	6.7	68.0	24.9	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4004	SS-5	8.5/209.95 / ft.	11/8/2006		SAND, silty (SM)	14.7		

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	○ Tested by: JM/RW Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286 Figure 6814		

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0						22.5	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4004	SS-6	11/207.45	11/8/06		SAND, silty (SM)			

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: EH	Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project			
Project No. 6141-06-0286		Figure 7758	

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.1	44.4	48.3	7.2	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4004	SS-8	18.5/199.95 Ft.	11/8/2006		SAND, with silt (SP-SM)	12.6		

Client GPC c/o SNOC Project Vogtle Units 3 & 4 COL Project Project No. 6141-06-0286	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: JM/RW Reviewed by: HJ
Figure 6815		

Particle Size Distribution Report



% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.0	3.1	40.0	9.3	47.6


SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4004	SS-11	33.5/184.95 Ft.	11/8/2006		CLAY, sandy (CL)			

Client GPC c/o SNOC
 Project Vogtle Units 3 & 4 COL Project
 Project No. 6141-06-0286 Figure 6816

**MACTEC ENGINEERING
AND
CONSULTING, INC.**

Tested by: JM Reviewed by: HJ

Particle Size Distribution Report



% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.0	5.9	68.1	5.8	20.2


SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4004	SS-14	48.5/169.95 Ft.	11/8/2006		SAND, clayey (SC)			

Client GPC c/o SNOC
 Project Vogtle Units 3 & 4 COL Project
 Project No. 6141-06-0286 Figure 6817

**MACTEC ENGINEERING
AND
CONSULTING, INC.**

Tested by: JM Reviewed by: HJ

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0						11.3	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4004	SS-16	58.5/159.95	11/8/06		SAND, with clay (SP-SC)			

Client GPC c/o SNOC Project Vogtle Units 3 & 4 COL Project Project No. 6141-06-0286	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: EH Reviewed by: HJ Figure 7760
---	--	---

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	10.5	4.8	38.8	27.3	18.6	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4004	SS-17	63.5/154.95 Ft.	11/8/2006		SAND, clayey (SC)	31.5		

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: JM/RW Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286 Figure 6818		

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	2.1	9.2	50.8	21.4	16.5	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4004	SS-19	73.5/144.95 Ft.	11/8/2006	SM	SAND, silty (SM)	24.2		

Client GPC c/o SNOC Project Vogtle Units 3 & 4 COL Project Project No. 6141-06-0286	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: JM/RW Reviewed by: HJ
Figure 6819		

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	9.5	29.0	37.8	15.5	8.2	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4004	SS-22	88.5/129.95 Ft.	11/8/2006		SHELL HASH, with silt (SW-SM)	24.0		

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: JM/RW Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286 Lab no. 6820		

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.4	1.1	4.2	94.3	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4004	SS-25	103.5/114.95	11/9/06	MH	SILT, (MH)	50.7	97	50

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: EH	Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project			
Project No. 6141-06-0286		Figure 7761	

Particle Size Distribution Report



% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.2	3.4	22.7	73.7	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4004	SS-34	148.5/69.95	11/10/06	CL	CLAY, with sand (CL)	31.0	49	25

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: EH Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286 Figure 7762		