


Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.0	1.5	61.9	36.6	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4033	UD-2	33.5/186.43	2/8/07	SM	SAND, silty clayey (SC-SM)	22.8		

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	○ Tested by: EH Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286 Figure 7617		

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.1	33.6	52.9	13.4	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4034	UD-1	28.5/194.29	2/17/07	SM	SAND, silty (SM)	18.0		

Client GPC c/o SNOC Project Vogtle Units 3 & 4 COL Project Project No. 6141-06-0286	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: EH Reviewed by: HJ
Figure 7619		

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	23.9	2.3	5.3	12.3	56.2	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4034	UD-5	113.5/109.29 ft.	3/19/07	MH	SILT, with shell hash and sand (MH)		53	31

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: EH	Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project			
Project No. 6141-06-0286		Lab no. 7623	

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.9	4.5	32.7	61.9	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4034	UD-6	143.5/79.29	3/20/07	CL	CLAY, sandy (CL)		47	26

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: EH	Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project			
Project No. 6141-06-0286		Figure 7624	

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0						83.8	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4035	UD-2	103.5/117.02	2/26/07		SILT (MH)		86	50

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: EH Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286 Figure 7587		

Particle Size Distribution Report



% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.2	3.9	29.5	66.4	


SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-4035	UD-3	148.5/72.02	2/27/07	CL	CLAY, sandy (CL)	24.3	43	22

Client GPC c/o SNOC
 Project Vogtle Units 3 & 4 COL Project
 Project No. 6141-06-0286 Figure 7588

**MACTEC ENGINEERING
 AND
 CONSULTING, INC.**

Tested by: EH Reviewed by: HJ

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.8	31.6	38.5	29.1	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-6020	SS-2	1.5/219.98	3/28/07	SC	SAND, clayey (SC)		53	27

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: EH	Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project			
Project No. 6141-06-0286		Figure 7826	

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.0	19.9	70.2	9.9	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-6020	SS-4	6/215.48	3/28/07		SAND with silt (SP-SM)		NV	NP

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	○ Tested by: EH Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286 Figure 7827		

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.1	18.7	57.8	23.4	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-6020	SS-6	11/210.48	3/28/07	SC	SAND, clayey (SC)		47	25

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: EH Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286 Lab no. 7828		

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.0	3.2	55.2	41.6	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-6020	SS-14	48.5/172.98	3/29/07	SM	SAND, silty (SM)	44.3	111	60

Client GPC c/o SNOC Project Vogtle Units 3 & 4 COL Project Project No. 6141-06-0286	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: EH Reviewed by: HJ Figure 7829
---	--	---

Particle Size Distribution Report




% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.0	6.5	59.2	34.3	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-6020	SS-16	58.5/162.98	3/29/07	SM	SAND, silty (SM)	46.1	139	78

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	Tested by: EH Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286 Figure 7830		

Particle Size Distribution Report



% COBBLES	% GRAVEL		% SAND			% FINES	
	COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY
0.0	0.0	0.0	0.0	9.2	64.1	26.7	

SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PL
B-6021	SS-4	6/203.8	4/3/07	SC	SAND, clayey (SC)		41	22

Client GPC c/o SNOC	MACTEC ENGINEERING AND CONSULTING, INC.	○ Tested by: EH Reviewed by: HJ
Project Vogtle Units 3 & 4 COL Project		
Project No. 6141-06-0286 Figure 7831		