



UNITED STATES
NUCLEAR REGULATORY COMMISSION
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
WASHINGTON, DC 20555 - 0001

June 3, 2009

MEMORANDUM TO: Dennis C. Bley, ACRS Member

FROM: H. P. Nourbakhsh, Senior Technical Advisor */RA/*

SUBJECT: ANALYSIS OF EDO RESPONSE TO ACRS
LETTER ON DRAFT FINAL REVISION 2 TO
REGULATORY GUIDE 1.200, "AN APPROACH FOR
DETERMINING THE TECHNICAL ADEQUACY OF
PROBABILISTIC RISK ASSESSMENT RESULTS FOR
RISK-INFORMED ACTIVITIES"

Attached for your perusal is a copy of the EDO's May 8, 2009 letter, responding to the Committee's April 9, 2009 letter to the EDO concerning Draft Final Revision 2 to Regulatory Guide 1.200, "An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities." A copy of the Committee's April 9, 2009, letter to the EDO is also attached.

Committee Letter

In its letter to the EDO, the Committee summarized its recommendations and comments on Draft Final Revision 2 to Regulatory Guide 1.200. Following are the Committee's specific comments and recommendations:

- The Committee agrees with the staff's issuance of Revision 2 to RG 1.200.
- The existing guidance on how to perform probabilistic risk assessments (PRAs) for nuclear power plants should be updated.
- Revision 2 to RG 1.200 refers to NUREG-1855, "Guidance on the Treatment of Uncertainties Associated with PRAs in Risk-Informed Decision Making." In its February 23, 2009, letter, the Committee commented that although NUREG-1855 provides good guidance for the identification of sources of model uncertainty, it lacks guidance on quantification of model uncertainty. The Committee recommended that the staff develop methods for the quantification and integration of model uncertainties in risk-informed decisions.

EDO Response

The EDO's response, dated May 8, 2009, touched on the April 9, 2009 Committee's letter concerning Draft Final Revision 2 to Regulatory Guide 1.200. Following are the staff's responses to the Committee's recommendations:

- The staff has published Revision 2 to RG 1.200.
- With regard to additional PRA guidance, the staff has initiated an effort to review PRA guidance documents including the PRA Procedures Guide, NUREG/CR-2300, and the Fault Tree Handbook, NUREG-0492, with a view to determining what PRA guidance needs to be developed or updated. Part of this assessment will evaluate whether the identified guidance is better suited to be developed as a staff effort, as part of an industry collaborative effort, as a separate industry effort, or as a separate national consensus standard effort. The staff noted that, in addition to NUREG-1855, it has already published several guidance documents on specific topics such as parameter estimation (NUREG/CR-6823), human reliability analysis (NUREG-1792 & NUREG-1842) and fire PRA (NUREG/CR-6850).
- With regard to guidance on quantification of model uncertainty, as noted in the April 14, 2009, staff response to the ACRS letter of February 23, 2009, the staff plans to pursue the feasibility and benefit of developing such guidance.

The EDO response also noted that the staff Plans to continue interact with the Committee as these guidance documents are identified and developed.

Analysis

The staff has generally agreed to the ACRS recommendations. The Committee will be afforded opportunities to discuss the staff's efforts in developing the recommended guidance documents.

Attachments: As Stated

cc w/o attach (via E-mail):

ACRS Members
E. Hackett
J. Flack
C. Santos
A. Dias
S. Duraiswamy
ACRS Technical Staff

May 8, 2009

Dr. Mario V. Bonaca, Chairman
Advisory Committee on Reactor Safeguards
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: DRAFT FINAL REVISION 2 TO REGULATORY GUIDE 1.200, "AN APPROACH FOR DETERMINING THE TECHNICAL ADEQUACY OF PROBABILISTIC RISK ASSESSMENT RESULTS FOR RISK-INFORMED ACTIVITIES"

Dear Dr. Bonaca:

Thank you for your letter dated April 9, 2009, that provides the views of the Advisory Committee on Reactor Safeguards (ACRS) on Draft Final Revision 2 to Regulatory Guide (RG) 1.200, "An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities." The staff's responses to the Committee's recommendations are provided below.

1. ACRS Recommendation: We agree with the staff's issuance of Revision 2 to RG 1.200.

Staff Response: The staff has published Revision 2 to RG 1.200.

2. ACRS Recommendation: The existing guidance on how to perform probabilistic risk assessments (PRAs) for nuclear power plants should be updated. The Committee further notes that although the national consensus PRA standards provide specific guidance on what the risk assessment should include, "the existing guidance on how to perform PRA is spotty. NUREG-6823 provides guidance on current methods for parameter estimation. NUREG-0492, 'Fault Tree Handbook,' is an excellent resource but should be updated to include refinements in fault tree analysis and associated computer codes. NUREG/CR-2300, 'PRA Procedures Guide, A Guide to the Performance of Probabilistic Risk Assessments for Nuclear Power Plants' is archaic; updated guidance for the broad range of PRA activities is sorely needed. Enhanced confidence in PRA increases the quality of risk-informed regulatory decisionmaking. Updating the PRA Procedures Guide and other PRA guidance documents is an important step in that process."

The Committee also notes that in their February 23, 2009, letter on NUREG-1855 they "commented that although NUREG-1855 provides good guidance for the identification of sources of model uncertainty, it lacks guidance on quantification of model uncertainty. We recommended that the staff develop methods for the quantification and integration of model uncertainties in risk-informed decisions."

Staff Response: With regard to additional PRA guidance, the staff has initiated an effort to review PRA guidance documents including the PRA Procedures Guide, NUREG/CR-2300, and the Fault Tree Handbook, NUREG-0492, with a view to determining what PRA guidance needs to be developed or updated. Part of this

assessment will evaluate whether the identified guidance is better suited to be developed as a staff effort, as part of an industry collaborative effort, as a separate industry effort, or as a separate national consensus standard effort. The staff notes that, in addition to NUREG-1855, it has already published several guidance documents on specific topics such as parameter estimation (NUREG/CR-6823), human reliability analysis (NUREG-1792 & NUREG-1842) and fire PRA (NUREG/CR-6850).

This effort is in keeping with the staff plan in achieving the Commission's phased approach to PRA quality (SECY-04-0118 and SECY-070042, ML041470505 and ML063630346, respectively), which includes identification and development of guidance documents for achieving the needed PRA quality for risk-informed activities. Moreover, with regard to guidance on quantification of model uncertainty, as noted in the April 14, 2009, staff response (ML090920755) to the ACRS letter of February 23, 2009, the staff plans to pursue the feasibility and benefit of developing such guidance.

The staff plans to continue to interact with the Committee as these guidance documents are identified and developed.

Sincerely,

/RA/

R. W. Borchardt
Executive Director
for Operations

cc: Chairman Klein
Commissioner Jaczko
Commissioner Lyons
Commissioner Svinicki
SECY



**UNITED STATES
NUCLEAR REGULATORY COMMISSION
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
WASHINGTON, DC 20555 - 0001**

April 9, 2009

Mr. R. W. Borchardt
Executive Director for Operations
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

SUBJECT: DRAFT FINAL REVISION 2 TO REGULATORY GUIDE 1.200, "AN APPROACH FOR DETERMINING THE TECHNICAL ADEQUACY OF PROBABILISTIC RISK ASSESSMENT RESULTS FOR RISK-INFORMED ACTIVITIES"

Dear Mr. Borchardt:

During the 561st meeting of the Advisory Committee on Reactor Safeguards, April 2-4, 2009, we completed our review of the Draft Final Revision 2 to Regulatory Guide (RG) 1.200, "An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities." During our 560th meeting, March 5-7, 2009, we met with representatives of the NRC staff to discuss this Regulatory Guide and related matters. During our review, we had the benefit of the documents referenced.

CONCLUSION AND RECOMMENDATION

1. We agree with the staff's issuance of Revision 2 to RG 1.200.
2. The existing guidance on how to perform probabilistic risk assessments (PRAs) for nuclear power plants should be updated.

DISCUSSION

RG 1.200 describes an acceptable approach for determining the technical adequacy of a PRA to be used for regulatory decisionmaking. It endorses, with certain qualifications and clarifications, the ASME/ANS Consensus PRA Standard and the Nuclear Energy Institute peer review process. RG 1.200 is intended to reduce the need for the NRC staff to perform an in-depth review of the base PRA that is used to support an application.

We reviewed the original version of RG 1.200 (formerly DG-1122) and provided a report to the Commission dated September 22, 2003, recommending that it be issued for trial use. We agreed with the staff's decision to develop a separate regulatory guide on how to perform sensitivity and uncertainty analyses. RG 1.200 was issued for trial use in February 2004 and five trial applications were conducted. In 2006, we reviewed Revision 1 to RG 1.200 that incorporated lessons learned from the trial applications. In our October 23, 2006, letter, we recommended that Revision 1 to RG 1.200 be issued after reconciliation of public comments. Revision 1 was issued in January 2007.

Since the issuance of Revision 1, the PRA standards and industry guidance have been updated (e.g., to include internal fire). Subsequently, the staff prepared a draft Revision 2 to RG 1.200, as DG-1200, which was issued for public comment in June 2008.

Revision 2 to RG 1.200 refers to NUREG-1855, "Guidance on the Treatment of Uncertainties Associated with PRAs in Risk-Informed Decision Making." In our February 23, 2009, letter, we commented that although NUREG-1855 provides good guidance for the identification of sources of model uncertainty, it lacks guidance on quantification of model uncertainty. We recommended that the staff develop methods for the quantification and integration of model uncertainties in risk-informed decisions.

Revision 2 to RG 1.200 is a major step toward the implementation of the Commission's phased approach to PRA quality. Significant progress has been made in the development and staff endorsement of national consensus PRA standards and associated industry guidance documents. Efforts are also under way through the professional societies to develop PRA standards addressing the remaining risk contributors (e.g., low-power and shutdown modes of operation). These national consensus PRA standards provide specific guidance on what the risk assessment should include. However, the existing guidance on how to perform PRA is spotty. NUREG-6823 provides guidance on current methods for parameter estimation. NUREG-0492, "Fault Tree Handbook," is an excellent resource but should be updated to include refinements in fault tree analysis and associated computer codes. NUREG/CR-2300, "PRA Procedures Guide, A Guide to the Performance of Probabilistic Risk Assessments for Nuclear Power Plants," is archaic; updated guidance for the broad range of PRA activities is sorely needed.

Enhanced confidence in PRA increases the quality of risk-informed regulatory decisionmaking. Updating the PRA Procedures Guide and other PRA guidance documents is an important step in that process.

Sincerely,

/RA/

Mario V. Bonaca
Chairman

References:

1. Memorandum from Michael Case, Director, Division of Engineering, Office of Nuclear Regulatory Research, to Edwin M. Hackett, Executive Director, ACRS, Subject: Regulatory Guide 1.200, "An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities" dated February 10, 2009 (ML090410042)
2. U.S. Nuclear Regulatory Commission, Regulatory Guide 1.200, "An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities" Revision 1 January 2007

3. ASME/ANS RA-S-2008, "Standard for Probabilistic Risk Assessment for Nuclear Power Plant Applications," Revision 1 RA-S-2002, ASME, New York, New York dated April 2008
4. NEI 05-04, "Process for Performing Follow-on PRA Peer Reviews Using the ASME PRA Standard," Revision 2, Nuclear Energy Institute, Washington, DC dated November 2008
5. NEI 07-12, "Fire Probabilistic Risk Assessment (FPRA) Peer Review Process Guidelines," Draft Version H, Revision 0, Nuclear Energy Institute, Washington, DC dated November 2008
6. Report from Mario V. Bonaca, Chairman, Advisory Committee on Reactor Safeguards, to Nils J. Diaz, Chairman, U.S. Nuclear Regulatory Commission, Subject: Draft Final Regulatory Guide x.xxx, "An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities (formerly DG-1122)" dated September 22, 2003 (ML032681088)
7. Letter from Graham B. Wallis, Chairman, Advisory Committee on Reactor Safeguards, to Luis Reyes, Executive Director for Operations U.S. Nuclear Regulatory Commission, Subject: Draft Revision 1 to Regulatory Guide 1.200 (DG-1161), "An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities," and SRP Section 19.1, "Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities" dated October 23, 2006 (ML063030068)
8. Letter from Mario V. Bonaca, Chairman, Advisory Committee on Reactor Safeguards, to R. W. Borchardt, Executive Director for Operations U.S. Nuclear Regulatory Commission, Subject: Draft Final NUREG-1855, "Guidance on the Treatment of Uncertainties Associated with PRAs in Risk-Informed Decisionmaking," and Draft Appendix A, "Example Implementation of the Process for the Treatment of PRA Uncertainty in a Risk-Informed Regulatory Application" February 23, 2009 (ML090490652)
9. U.S. Nuclear Regulatory Commission, NUREG-1855, "Guidance on the Treatment of Uncertainties Associated with PRAs in Risk-Informed Decision Making" November 2007 (ML080040199)
10. U.S. Nuclear Regulatory Commission, NUREG/CR-6823, "Handbook of Parameter Estimation for Probabilistic Risk Assessment" September 2003 (ML083540681)
11. U.S. Nuclear Regulatory Commission, NUREG-0492, "Fault Tree Handbook" 1981
12. U.S. Nuclear Regulatory Commission, NUREG/CR-2300, "PRA Procedures Guide, a Guide to the Performance of Probabilistic Risk Assessments for Nuclear Power Plants," Volumes 1 and 2 January 1983 (ML063560439 and ML063560440)

Letter to the Honorable Dale E. Klein, Chairman, NRC, from Mario V. Bonaca, Chairman, ACRS, dated April 9, 2009

SUBJECT: DRAFT FINAL REVISION 2 TO REGULATORY GUIDE 1.200, "AN APPROACH FOR DETERMINING THE TECHNICAL ADEQUACY OF PROBABILISTIC RISK ASSESSMENT RESULTS FOR RISK-INFORMED ACTIVITIES"

Distribution:

ACRS Branch A
ACRS Branch B
E. Hackett
H. Nourbakhsh
J. Flack
C. Jaegers
T. Bloomer
B. Champ
A. Bates
S. McKelvin
L. Mike
J. Ridgely
RidsSECYMailCenter
RidsEDOMailCenter
RidsNMSSOD
RidsNSIROD
RidsFSMEOD
RidsRESOD
RidsOIGMailCenter
RidsOGCMailCenter
RidsOCAAMailCenter
RidsOCAMailCenter
RidsNRROD
RidsNROOD
RidsOPAMail
RidsRGN1MailCenter
RidsRGN2MailCenter
RidsRGN3MailCenter
RidsRGN4MailCenter