

Callaway2COLPEm Resource

From: Surinder Arora
Sent: Wednesday, April 08, 2009 3:09 PM
To: Shafer, David E
Cc: Callaway2COL Resource; Joseph Colaccino; Ann Hodgdon; David Terao; John Honcharik; NPUnit2-EPR@ameren.com; Peter Hearn
Subject: RAI No. 4 (eRAI No. 2433) - Public
Attachments: RAI 2433.doc

Dave,

Attached please find the subject request for additional information (RAI). A draft of this RAI was provided to you on March 24, 2009. Based on the e-mail dated April 6, 2009, from Roger Wink, no phone call was necessary to discuss this RAI.

The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs. For any RAIs that cannot be answered within 30 days, it is expected that a schedule date for submitting your technically correct and complete response will be provided to the staff within the 30 day period so that the staff can assess how this information will impact the review schedule.

Thanks.

SURINDER ARORA, PE
PROJECT MANAGER,
Office of New Reactors
US Nuclear Regulatory Commission

Phone: 301 415-1421
FAX: 301 415-6077
Email: Surinder.Arora@nrc.gov

Hearing Identifier: CallawayPlant_Unit2_COL_Public
Email Number: 26

Mail Envelope Properties (CB87FC66F95637428C5E0D066E756B6FAC7CDBCAB5)

Subject: RAI No. 4 (eRAI No. 2433) - Public
Sent Date: 4/8/2009 3:08:55 PM
Received Date: 4/8/2009 3:08:56 PM
From: Surinder Arora

Created By: Surinder.Arora@nrc.gov

Recipients:

"Callaway2COL Resource" <Callaway2COL.Resource@nrc.gov>

Tracking Status: None

"Joseph Colaccino" <Joseph.Colaccino@nrc.gov>

Tracking Status: None

"Ann Hodgdon" <Ann.Hodgdon@nrc.gov>

Tracking Status: None

"David Terao" <David.Terao@nrc.gov>

Tracking Status: None

"John Honcharik" <John.Honcharik@nrc.gov>

Tracking Status: None

"NPUnit2-EPR@ameren.com" <NPUnit2-EPR@ameren.com>

Tracking Status: None

"Peter Hearn" <Peter.Hearn@nrc.gov>

Tracking Status: None

"Shafer, David E" <DShafer@ameren.com>

Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	914	4/8/2009 3:08:56 PM
RAI 2433.doc	28154	

Options

Priority: Standard

Return Notification: No

Reply Requested: Yes

Sensitivity: Normal

Expiration Date:

Recipients Received:

Request for Additional Information No. 2433 Revision 0

4/08/2009

Callaway Unit 2

AmerenUE

Docket No. 52-037

SRP Section: 10.02.03 - Turbine Rotor Integrity

Application Section: 10.2.3

QUESTIONS for Component Integrity, Performance, and Testing Branch 1 (AP1000/EPR Projects)
(CIB1)

10.02.03-1

The staff notes that the COL applicant does not address the following two COL information items identified in Table 1.8-2 of the U.S. EPR FSAR:

1. COL information item 10.2-1 - A COL applicant that references the U. S EPR design certification will provide the site-specific turbine rotor inservice inspection.
2. COL information item 10.2-5 - A COL applicant will provide the site-specific turbine rotor inservice inspection interval consistent with the manufacturer's turbine missile analysis.

In order for the staff to complete its review, the applicant needs to address these two COL information items in its FSAR. In addition, the supporting turbine missile analysis should also be included in addressing COL information item 10.2-5.