

Callaway2COLPEm Resource

From: Surinder Arora
Sent: Tuesday, April 28, 2009 10:13 AM
To: Shafer, David E
Cc: Callaway2COL Resource; Ronaldo Jenkins; Swagata Som; Joseph Colaccino; Ann Hodgdon; James Steckel; NPUnit2-EPR@ameren.com
Subject: FW: Callaway SCOLA - Draft RAI No. 13 (eRAI No. 2497) - Public
Attachments: RAI 2497.doc

Dave,

Attached is DRAFT RAI No. 13 (eRAI No. 2497). You have until May 12, 2009 to review it and decide whether you need a conference call to discuss it. After the call or after May 12, 2009, the RAI will be finalized and sent to you for response. You will then have 30 days to respond.

SURINDER ARORA, PE
PROJECT MANAGER,
Office of New Reactors
US Nuclear Regulatory Commission

Phone: 301 415-1421
FAX: 301 415-6077
Email: Surinder.Arora@nrc.gov

Hearing Identifier: CallawayPlant_Unit2_COL_Public
Email Number: 37

Mail Envelope Properties (CB87FC66F95637428C5E0D066E756B6FBFFDFCBE4)

Subject: FW: Callaway SCOLA - Draft RAI No. 13 (eRAI No. 2497) - Public
Sent Date: 4/28/2009 10:13:16 AM
Received Date: 4/28/2009 10:13:19 AM
From: Surinder Arora

Created By: Surinder.Arora@nrc.gov

Recipients:

"Callaway2COL Resource" <Callaway2COL.Resource@nrc.gov>
Tracking Status: None
"Ronaldo Jenkins" <Ronaldo.Jenkins@nrc.gov>
Tracking Status: None
"Swagata Som" <Swagata.Som@nrc.gov>
Tracking Status: None
"Joseph Colaccino" <Joseph.Colaccino@nrc.gov>
Tracking Status: None
"Ann Hodgdon" <Ann.Hodgdon@nrc.gov>
Tracking Status: None
"James Steckel" <James.Steckel@nrc.gov>
Tracking Status: None
"NPUnt2-EPR@ameren.com" <NPUnt2-EPR@ameren.com>
Tracking Status: None
"Shafer, David E" <DShafer@ameren.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	493	4/28/2009 10:13:19 AM
RAI 2497.doc	27642	

Options

Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received:

Draft Request for Additional Information No. 2497

4/28/2009

Callaway Unit 2

AmerenUE

Docket No. 52-037

SRP Section: 08.01 - Electric Power - Introduction

Application Section: 8.1

QUESTIONS for Electrical Engineering Branch (EEB)

08.01-1

Callaway FSAR Sections 8.1.4.4 and 8.2.1.1 describe agreements and protocols that are in place between Callaway Unit 2 and the transmission system operator (TSO) to provide safe and reliable operation of the transmission system and equipment at Callaway Unit 2. However, a description of the communication procedures between the TSO and Callaway Unit 2, and the associated training and testing of operators and maintenance personnel as requested in GL 2006-02 questions 1(b), 1(c) and 1(d) are not provided in the COL application. Please provide the requested information and include it in a future revision of the FSAR.