Callaway2COLPEm Resource

From: Surinder Arora
Sent: Tuesday, May 12, 2009 3:13 PM
To: Shafer, David E
Cc: Callaway2COL Resource; Joseph Colaccino; Ann Hodgdon; Ronaldo Jenkins; Swagata Som; James Steckel; NPUnit2-EPR@ameren.com
Subject: Final RAI N0. 13 (eRAI 2497) - Public
Attachments: FINAL RAI 2497.doc

Dave,

Attached please find the subject request for additional information (RAI). A draft of this RAI was provided to you on April 28, 2009. Based on your e-mail of May 6, 2009, no phone call was necessary to discuss this RAI.

The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs. For any RAIs that cannot be answered within 30 days, it is expected that a schedule date for submitting your technically correct and complete response will be provided to the staff within the 30 day period so that the staff can assess how this information will impact the review schedule.

Thanks.

SURINDER ARORA, PE
PROJECT MANAGER,
Office of New Reactors
US Nuclear Regulatory Commission

Phone: 301 415-1421
FAX: 301 415-6077
Email: Surinder.Arora@nrc.gov

Hearing Identifier: CallawayPlant_Unit2_COL_Public
Email Number: 49

Mail Envelope Properties (CB87FC66F95637428C5E0D066E756B6FC0000A2302)

Subject: Final RAI N0. 13 (eRAI 2497) - Public
Sent Date: 5/12/2009 3:12:32 PM
Received Date: 5/12/2009 3:12:34 PM
From: Surinder Arora

Created By: Surinder.Arora@nrc.gov

Recipients:
"Callaway2COL Resource" <Callaway2COL.Resource@nrc.gov>
Tracking Status: None
"Joseph Colaccino" <Joseph.Colaccino@nrc.gov>
Tracking Status: None
"Ann Hodgdon" <Ann.Hodgdon@nrc.gov>
Tracking Status: None
"Ronaldo Jenkins" <Ronaldo.Jenkins@nrc.gov>
Tracking Status: None
"Swagata Som" <Swagata.Som@nrc.gov>
Tracking Status: None
"James Steckel" <James.Steckel@nrc.gov>
Tracking Status: None
"NPUnit2-EPR@ameren.com" <NPUnit2-EPR@ameren.com>
Tracking Status: None
"Shafer, David E" <DShafer@ameren.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	**Size**	**Date & Time**
MESSAGE	945	5/12/2009 3:12:34 PM
FINAL RAI 2497.doc	27642	

Options
Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 2497

5/12/2009

Callaway Unit 2
AmerenUE
Docket No. 52-037
SRP Section: 08.01 - Electric Power - Introduction
Application Section: 8.1

QUESTIONS for Electrical Engineering Branch (EEB)

08.01-1

Callaway FSAR Sections 8.1.4.4 and 8.2.1.1 describe agreements and protocols that are in place between Callaway Unit 2 and the transmission system operator (TSO) to provide safe and reliable operation of the transmission system and equipment at Callaway Unit 2. However, a description of the communication procedures between the TSO and Callaway Unit 2, and the associated training and testing of operators and maintenance personnel as requested in GL 2006-02 questions 1(b), 1(c) and 1(d) are not provided in the COL application. Please provide the requested information and include it in a future revision of the FSAR.