From: Ennis, Rick
Sent: Monday, June 08, 2009 6:51 AM
To: Jeff Keenan
Cc: David, Marshall; Feintuch, Karl; Jones, Steve; Paul Duke
Subject: Acceptance Review for TACs ME1279 & ME1280 - Salem Units 1 and 2 - Relocate Crane TSs

Jeff,

By letter dated April 9, 2009 (ADAMS Accession No. ML091340092), PSEG Nuclear LLC submitted a license amendment request for Salem Nuclear Generating Station, Unit Nos. 1 and 2 (Salem). The proposed amendment would relocate Technical Specification (TS) requirements pertaining to communications during refueling operations (TS 3/4.9.5), manipulator crane operability (TS 3/4.9.6), and crane travel (TS 3/4.9.7) to the Salem Technical Requirements Manual. The purpose of this e-mail is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of this amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), an amendment to the license (including the TSs) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the staff to proceed with its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. If additional information is needed for the staff to complete its technical review, you will be advised by separate correspondence.

If you have any questions, please contact me at (301) 415-1420.

Richard B. Ennis, Senior Project Manager
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

E-mail Properties

Mail Envelope Properties (3D27D29AB75BCD4BAE913B63CBFBBEDFDE3E3CC57E)

Subject: Acceptance Review for TACs ME1279 & ME1280 - Salem Units 1 and 2 - Relocate Crane TSs

Sent Date: 06/08/2009 6:50:38 AM
Received Date: 06/08/2009 6:50:38 AM
From: Ennis, Rick

Created By: Rick.Ennis@nrc.gov

Recipients:
Jeff.Keenan@pseg.com (Jeff Keenan)
Tracking Status: None
Marshall.David@nrc.gov (David, Marshall)
Tracking Status: None
Karl.Feintuch@nrc.gov (Feintuch, Karl)
Tracking Status: None
Steve.Jones@nrc.gov (Jones, Steve)
Tracking Status: None
Paul.Duke@pseg.com (Paul Duke)
Tracking Status: None

Post Office:
HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	13247	06/08/2009

Options
Expiration Date:
Priority: olImportanceNormal
ReplyRequested: False
Return Notification: False

Sensitivity: olNormal
Recipients received: