

June 11, 2009

LICENSEE: Nebraska Public Power District

FACILITY: Cooper Nuclear Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON MAY 27, 2009, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION STAFF AND NEBRASKA PUBLIC POWER DISTRICT, RELATED TO A CLARIFICATION ON CERTAIN REQUESTS FOR ADDITIONAL INFORMATION (RAI 3.3.2.2.3.3-1, RAI 3.3.2.2.7.3-1, RAI 3.3.2.2.7.3-2), FOR COOPER NUCLEAR STATION LICENSE RENEWAL

The U.S. Nuclear Regulatory Commission staff and representatives of Nebraska Public Power District held a telephone conference call on May 27, 2009, to discuss clarifications for certain draft requests for additional information for Cooper Nuclear Station license renewal.

Enclosure 1 provides a listing of the participants, and Enclosure 2 contains a brief description of the telephone conference call.

The applicant had an opportunity to comment on this summary.

**/RA/**

Tam Tran, Project Manager  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosures:  
As stated

cc w/encls: See next page

June 11, 2009

LICENSEE: Nebraska Public Power District

FACILITY: Cooper Nuclear Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON MAY 27, 2009, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION STAFF AND NEBRASKA PUBLIC POWER DISTRICT, RELATED TO A CLARIFICATION ON CERTAIN REQUESTS FOR ADDITIONAL INFORMATION (RAI 3.3.2.2.3.3-1, RAI 3.3.2.2.7.3-1, RAI 3.3.2.2.7.3-2), FOR COOPER NUCLEAR STATION LICENSE RENEWAL

The U.S. Nuclear Regulatory Commission staff and representatives of Nebraska Public Power District held a telephone conference call on May 27, 2009, to discuss clarifications for certain draft requests for additional information for Cooper Nuclear Station license renewal.

Enclosure 1 provides a listing of the participants, and Enclosure 2 contains a brief description of the telephone conference call.

The applicant had an opportunity to comment on this summary.

**/RA/**

Tam Tran, Project Manager  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosures:  
As stated

cc w/encls: See next page

DISTRIBUTION:  
See next page

ADAMS Accession No.: ML091590022

OFFICE	PM:RPB1:DLR	LA:DLR	PM:RPB2:DLR	BC:RPB1:DLR
NAME	TTran	SFigueroa	ESayoc (TTran for)	DPelton (DAshley for)
DATE	06/11/09	06/10/09	6/10/09	6/11/09

OFFICIAL RECORD COPY

Memorandum to Nebraska Public Power District from Tam Tran dated June 11, 2009

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON MAY 27, 2009, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION STAFF AND NEBRASKA PUBLIC POWER DISTRICT, RELATED TO A CLARIFICATION ON CERTAIN REQUESTS FOR ADDITIONAL INFORMATION (RAI 3.3.2.2.3.3-1, RAI 3.3.2.2.7.3-1, RAI 3.3.2.2.7.3-2), FOR COOPER NUCLEAR STATION LICENSE RENEWAL

DISTRIBUTION:

**HARD COPY:**

DLR RF

**E-MAIL:**

PUBLIC

RidsNrrDlr Resource  
RidsNrrDlrRpb1 Resource  
RidsNrrDlrRpb2 Resource  
RidsNrrDlrRer1 Resource  
RidsNrrDlrRer2 Resource  
RidsNrrDlrRerb Resource  
RidsNrrDlrRpob Resource  
RidsNrrDciCvib Resource  
RidsNrrDciCpnb Resource  
RidsNrrDciCsgb Resource  
RidsNrrDraAfpb Resource  
RidsNrrDraApla Resource  
RidsNrrDeEmcb Resource  
RidsNrrDeEeeb Resource  
RidsNrrDssSrxb Resource  
RidsNrrDssSbpb Resource  
RidsNrrDssScvb Resource  
RidsOgcMailCenter Resource

-----  
T. Tran  
E. Sayoc  
F. Lyon  
D. Roth (OGC)  
A. Jones (OGC)  
N. Taylor (RIV)  
E. Collins (RIV)  
C. Casto (RIV)  
B. Maier (RIV)  
V. Dricks (RIV)  
D. Chamberlain (RIV)  
A. Vogel (RIV)  
W. Walker (RIV)  
G. Miller (RIV)  
G. Pick (RIV)

S. Burnell (RIV)

Cooper Nuclear Station

cc:

Mr. Ronald D. Asche  
President and Chief Executive Officer  
Nebraska Public Power District  
1414 15th Street  
Columbus, NE 68601

Mr. Gene Mace  
Nuclear Asset Manager  
Nebraska Public Power District  
P.O. Box 98  
Brownville, NE 68321

Mr. John C. McClure  
Vice President and General Counsel  
Nebraska Public Power District  
P.O. Box 499  
Columbus, NE 68602-0499

Mr. David Van Der Kamp  
Licensing Manager  
Nebraska Public Power District  
P.O. Box 98  
Brownville, NE 68321

Mr. Michael J. Linder, Director  
Nebraska Department of Environmental  
Quality  
P.O. Box 98922  
Lincoln, NE 68509-8922

Chairman  
Nemaha County Board of Commissioners  
Nemaha County Courthouse  
1824 N Street  
Auburn, NE 68305

Ms. Julie Schmitt, Manager  
Radiation Control Program  
Nebraska Health & Human Services R&L  
Public Health Assurance  
301 Centennial Mall, South  
P.O. Box 95007  
Lincoln, NE 68509-5007

Mr. H. Floyd Gilzow  
Deputy Director for Policy  
Missouri Department of Natural Resources  
P.O. Box 176  
Jefferson City, MO 65102-0176

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 218  
Brownville, NE 68321

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
612 E. Lamar Blvd., Suite 400  
Arlington, TX 76011-4125

Director, Missouri State Emergency  
Management Agency  
P.O. Box 116  
Jefferson City, MO 65102-0116

Chief, Radiation and Asbestos  
Control Section  
Kansas Department of Health  
and Environment  
Bureau of Air and Radiation  
1000 SW Jackson, Suite 310  
Topeka, KS 66612-1366

Ms. Melanie Rasmussen  
Radiation Control Program Director  
Bureau of Radiological Health  
Iowa Department of Public Health  
Lucas State Office Building, 5th Floor  
321 East 12th Street  
Des Moines, IA 50319

Mr. Keith G. Henke, Planner  
Division of Community and Public Health  
Office of Emergency Coordination  
930 Wildwood P.O. Box 570  
Jefferson City, MO 65102

Cooper Nuclear Station

- 2 -

cc:

Mr. Art Zaremba, Director of Nuclear  
Safety Assurance  
Nebraska Public Power District  
P.O. Box 98  
Brownville, NE 68321

Mr. John F. McCann, Director  
Licensing, Entergy Nuclear Northeast  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601-1813

Mr. Stewart Minahan  
Vice President  
Nuclear and Chief Nuclear Officer  
Cooper Nuclear Station  
72676 – 648A Avenue  
Brownville, NE 68321

Mr. Mike Boyce  
Cooper Strategic Initiatives Manager  
Cooper Nuclear Station  
72676 – 648A Avenue  
Brownville, NE 68321

Mr. Dave Bremer  
License Renewal Project Manager  
Cooper Nuclear Station  
72676 – 648A Avenue  
Brownville, NE 68321

Mr. Bill Victor  
License Renewal Project Licensing Lead  
Cooper Nuclear Station  
72676 – 648A Avenue  
Brownville, NE 68321

Mr. Jim Loynes  
License Renewal Project Engineer  
Cooper Nuclear Station  
72676 – 648A Avenue  
Brownville, NE 68321

**TELEPHONE CONFERENCE CALL  
COOPER NUCLEAR STATION  
LICENSE RENEWAL APPLICATION**

**LIST OF PARTICIPANTS  
May 27, 2009**

PARTICIPANTS

AFFILIATIONS

Tam Tran	U.S. Nuclear Regulatory Commission (NRC)
Robert Sun	NRC
Dave Bremer	Nebraska Public Power District (NPPD)
Jim Loynes	NPPD
Scott Freborg	NPPD
Dave Lach	Entergy
Alan Cox	Entergy
Don Fronabarger	Entergy
Andrew Taylor	Entergy

**TELEPHONE CONFERENCE CALL  
COOPER NUCLEAR STATION  
LICENSE RENEWAL APPLICATION**

**BRIEF DESCRIPTION  
May 27, 2009**

The U.S. Nuclear Regulatory Commission (NRC) staff and representatives of Nebraska Public Power District held a telephone conference call on May 27, 2009, to discuss clarifications for certain draft requests for additional information listed below.

**Discussion:**

**RAI 3.3.2.2.3.3-1 (Draft)**

**Background:**

Section 3.3.2.2.3.3 "Cracking due to Stress Corrosion Cracking (SCC)" of the SRP-LR identifies SCC as an aging effect requiring management for stainless steel diesel engine exhaust piping, piping components, and piping elements exposed to diesel exhaust. The GALL report identifies this MEAP combination in item VII.H2-1. AMR item AP-33 in Table II.A of NUREG-1833, "Technical Bases for Revision to the License Renewal Guidance Documents," provides a basis for why it is important to identify SCC as an AERM for the internal surfaces of stainless steel emergency diesel generator exhaust piping that are exposed to diesel exhaust. Specifically, NUREG-1833 states that hot diesel engine exhaust may contain moisture and particulates which lead to SCC in stainless steel diesel exhaust components.

**Issue:**

Contrary to the License Renewal Guidance identified above, the applicant states that stainless steel exhaust components are not subject to significant moisture accumulation that would allow cracking to occur. The staff disagrees with this approach, and takes the position that this must be identified as an AERM similar to the GALL item VII.H2-1.

**Request:**

Please provide an AMP and AMR line item to manage the aging effect recommended by GALL VII.H2-1.

The applicant indicated understanding of this request for information and that similar items have been communicated to other applicant(s) previously, in earlier application(s) for other plant(s).

**RAI 3.3.2.2.7.3-1 (Draft)**

Background:

Section 3.3.2.2.7.3, “Loss of Material due to General, Pitting, and Crevice Corrosion” of the SRP-LR identifies loss of material as an aging effect requiring management for steel and stainless steel diesel exhaust piping, piping components, and piping elements exposed to diesel exhaust. The applicant has credited the plant specific AMP, B.1.31, Periodic Surveillance and Preventive Maintenance (PSPM) Program with managing this aging effect for emergency diesel generator exhaust piping, piping components, and piping elements.

Issue:

The PSPM Program identifies the use of visual inspections performed on a “representative sample” of diesel generator exhaust gas components to manage the loss of material aging effect. The AMP indicates that sample size is determined using guidance from EPRI TR-107514, Age-Related Degradation Inspection Method and Demonstration, for a 90% confidence level that 90% of the population does not experience degradation. However, it is not clear what the population and sample size will be for the diesel generator system exhaust components. Additionally, the AMP indicates that “components with the same material-environment combinations at other facilities may be included in the sample.” The inspection of components at other facilities would not necessarily offer an accurate representation of the aging effects at the current facility, and thus brings into question the extent of which this method will be used and the effect of its inclusion on the overall population and sample size.

Request:

- a) Please provide the total actual population and sample size of diesel generator exhaust gas components to manage the loss of material aging effect at Cooper Nuclear Station.
- b) Please clarify the use of “inspection of components at other facilities” as part of the representative sample for diesel generator exhaust gas components to manage the loss of material aging effect at Cooper Nuclear Station, and identify the specific impact this will have on the overall population and sample size.

The applicant indicated understanding of this request for information.

**RAI 3.3.2.2.7.3-2 (Draft)**

Background:

Section 3.3.2.2.7.3, “Loss of Material due to General, Pitting, and Crevice Corrosion” of the SRP-LR identifies loss of material as an aging effect requiring management for steel and stainless steel diesel exhaust piping, piping components, and piping elements exposed to diesel exhaust. The applicant has credited the plant specific AMP, B.1.16, Fire Protection Program with managing this aging effect for the diesel fire pump engine exhaust piping, piping components, and piping elements.



Issue:

LRA AMP, B.1.16, Fire Protection Program states as an enhancement that the diesel fire pump engine carbon steel exhaust components are inspected for evidence of corrosion or cracking. However, the LRA is not clear whether the inspection will be an internal inspection or external only. An internal inspection is necessary to inspect for the aging effects caused by exhaust gas.

Request:

Please clarify whether the inspection conducted by the Fire Protection Program includes the internal surface of the components.

The applicant indicated understanding of this request for information.