



444 South 16th Street Mall  
Omaha NE 68102-2247

May 29, 2009  
LIC-09-0037

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Reference: Docket No. 50-285

**SUBJECT: Transmittal of Fort Calhoun Station (FCS), Unit No. 1, Core Operating Limit Report (COLR), Revision 37**

Pursuant to FCS Technical Specification 5.9.5d, Revision 37 of the FCS COLR is attached. Revision 37, issued on May 22, 2009, revised Figure 9 to reflect only the useable volume of boric acid storage tank (BAST) level at various safety injection refueling water tank (SIRWT) boron concentrations.

No regulatory commitments are contained in this submittal.

If you have any questions, please contact Ms. Susan Baughn at (402) 533-7215.

Sincerely,

T. C. Matthews  
Manager - Nuclear Licensing

TCM/mle

Attachment: TDB-VI -- Technical Data Book -- Core Operating Limit Report -- Revision 37

- c: E. E. Collins, NRC Regional Administrator, Region IV (w/o Attachment)  
A. B. Wang, NRC Project Manager (w/o Attachment)  
J. D. Hanna, NRC Senior Resident Inspector (w/o Attachment)  
J. C. Kirkland, NRC Senior Resident Inspector (w/o Attachment)

A001  
NLR

Fort Calhoun Station  
Unit 1

**TDB-VI**

TECHNICAL DATA BOOK

CORE OPERATING LIMIT REPORT

Change No.	EC 46328
Reason for Change	Revised Figure 9 to reflect only the useable volume of BAST level at various SIRWT boron concentrations.
Requestor	T. Heng
Preparer	L. Hautzinger
Issue Date	05-22-09 1645

**Fort Calhoun Station, Unit 1**

**Core Operating Limit Report**

Due to the critical aspects of the safety analysis inputs contained in this report, changes may not be made to this report without concurrence of the Nuclear Engineering Department.

# TABLE OF CONTENTS

<u>Item</u>	<u>Description</u>	<u>Page</u>
1.	INTRODUCTION.....	6
2.	CORE OPERATING LIMITS .....	6
3.	TM/LP LIMIT .....	8
4.	MAXIMUM CORE INLET TEMPERATURE .....	8
5.	POWER DEPENDENT INSERTION LIMIT .....	8
6.	LINEAR HEAT RATE .....	9
7.	EXCORE MONITORING OF LHR.....	9
8.	PEAKING FACTOR LIMITS .....	9
9.	DNB MONITORING .....	9
10.	$F_R^T$ AND CORE POWER LIMITATIONS .....	9
11.	REFUELING BORON CONCENTRATION .....	9
12.	AXIAL POWER DISTRIBUTION .....	10
13.	SHUTDOWN MARGIN WITH $T_{cold} > 210^\circ\text{F}$ .....	10
14.	MOST NEGATIVE MODERATOR TEMPERATURE COEFFICIENT.....	10
15.	STEAM GENERATOR DIFFERENTIAL PRESSURE .....	10

LIST OF TABLES

<u>Table No.</u>	<u>Title</u>	<u>Page</u>
1	TM/LP Coefficients .....	8
2	Refueling Boron Concentrations .....	9

**LIST OF FIGURES**

<u>Figure No.</u>	<u>Title</u>	<u>Page</u>
1	Thermal Margin/Low Pressure for 4 Pump Operation.....	11
2	Power Dependent Insertion Limit.....	12
3	Allowable Peak Linear Heat Rate vs. Burnup .....	13
4	Excore Monitoring of LHR.....	14
5	DNB Monitoring .....	15
6	$F_R^T$ and Core Power Limitations .....	16
7	Axial Power Distribution LSSS for 4 Pump Operation.....	17
8	Axial Power Distribution Limits for 4 Pump Operation with Incores Inoperable..	18
9	Minimum Boric Acid Storage Tank Level vs. Stored Boric Acid Storage Tank Concentration .....	19

## CORE OPERATING LIMIT REPORT

### 1. INTRODUCTION

This report provides the cycle-specific limits for operation of the Fort Calhoun Station Unit 1 for Cycle 25 operation. It includes limits for:

- TM/LP LSSS for 4 Pump Operation ( $P_{VAR}$ )
- Core Inlet Temperature ( $T_{IN}$ )
- Power Dependent Insertion Limit (PDIL)
- Allowable Peak Linear Heat Rate
- Excore Monitoring of LHR
- Integrated Radial Peaking Factor ( $F_R^T$ )
- DNB Monitoring
- $F_R^T$  versus Power Trade-off Curve
- Refueling Boron Concentration
- Axial Power Distribution (APD)
- Shutdown Margin with  $T_{COLD} > 210^\circ\text{F}$
- Most Negative Moderator Temperature Coefficient

These limits are applicable for the duration of the cycle. For subsequent cycles the limits will be reviewed and revised as necessary. In addition, this report includes a number of cycle-specific coefficients used in the generation of certain reactor protective system trip setpoints or allowable increases in radial peaking factors.

### 2. CORE OPERATING LIMITS

All values and limits in this TDB section apply to Cycle 25 operation. This cycle must be operated within the bounds of these limits and all others specified in the Technical Specifications.

This report has been prepared in accordance with the requirements of Technical Specification 5.9.5. The list of references below are complete citations of topical reports and include the report number, title, revision, date, and any supplements in accordance with the basis for NRC approval of License Amendment No. 196 which eliminated these specific entries from Technical Specification 5.9.5. NRC approval of Amendment No. 196 is consistent with the requirements of the Technical Specification Task Force, Improved Standard Technical Specification Change Traveler, "Revise Topical Report References in ITS 5.6.5 COLR" (TSTF-363-A, Rev. 0). In accordance with this Traveler and Amendment No. 196, this information must be maintained within this TDB section.

The values and limits presented within this TDB section have been derived using the NRC approved methodologies listed below:

- OPPD-NA-8301, "Reload Core Analysis Methodology Overview," Revision 8, dated August 2004. (TAC No. MC4304)
- OPPD-NA-8302, "Reload Core Analysis Methodology, Neutronics Design Methods and Verification," Revision 6, dated August 2004. (TAC No. MC4304)
- OPPD-NA-8303, "Reload Core Analysis Methodology, Transient and Accident Methods and Verification," Revision 7, dated August 2005. (TAC No. MC4304)
- XN-75-32(P)(A) Supplements 1, 2, 3, & 4, "Computational Procedure for Evaluating Fuel Rod Bowing," October 1983.
- XN-NF-79-56(P)(A), Revision 1, Supplement 1, "Gadolinia Fuel Properties of LWR Fuel Safety Evaluation," November 1981.
- XN-NF-82-06(P)(A) and Supplements 2, 4, and 5, "Qualification of Exxon Nuclear Fuel for Extended Burnup," Revision 1, October 1986.
- XN-NF-85-92(P)(A), "Exxon Nuclear Uranium Dioxide/Gadolinia Irradiation Examination and Thermal Conductivity Results," August 1985.
- ANF-88-133(P)(A) and Supplement 1, "Qualification of Advanced Nuclear Fuels PWR Design Methodology for Rod Burnups of 62 GWd/MTU," December 1991.
- EMF-92-116(P)(A), "Generic Mechanical Design Criteria for PWR Fuel Designs," Revision 0, February 1999.
- XN-NF-78-44(P)(A), "A Generic Analysis of the Control Rod Ejection Transient for Pressurized Water Reactors," October 1983.
- XN-NF-82-21(P)(A), "Application of Exxon Nuclear Company PWR Thermal Margin Methodology to Mixed Core Configurations," Revision 1, September 1983.
- EMF-1961(P)(A), "Statistical Setpoint/Transient Methodology for Combustion Engineering Type Reactors," Revision 0, July 2000.
- ANF-89-151(P)(A), "ANF-RELAP Methodology for Pressurized Water Reactors: Analysis of Non-LOCA Chapter 15 Events," Revision 0, May 1992.
- EMF-92-153(P)(A), "HTP: Departure from Nucleate Boiling Correlation for High Thermal Performance Fuel," Revision 1, January 2005.
- XN-NF-82-49(P)(A), Supplement 1, "Exxon Nuclear Company Evaluation Model Revised EXEM PWR Small Break Model," Revision 1, December 1994.
- EMF-2103(P)(A), "Realistic Large Break LOCA Methodology for Pressurized Water Reactors," Revision 0, April 2003.
- EMF-2328(P)(A), "PWR Small Break LOCA Evaluation Model, S-RELAP5 Based," Revision 0, March 2001.
- EMF-96-029(P)(A) Volume 1, EMF-96-029(P)(A) Volume 2, EMF-96-029(P)(A) Attachment, "Reactor Analysis System for PWRs, Volume 1 – Methodology Description, Volume 2 – Benchmarking Results," January 1997.
- EMF-2310(P)(A), "SRP Chapter 15 Non-LOCA Methodology for Pressurized Water Reactors," Revision 1, May 2004.
- BAW-10240(P)(A), "Incorporation of M5™ Properties in Framatome ANP Approved Methods," Revision 0, May 2004.



### 3. TM/LP LIMIT

The TM/LP coefficients are shown below:

**Table 1 -TM/LP Coefficients**

<u>Coefficient</u>	<u>Value</u>
$\alpha$	29.6
$\beta$	20.63
$\gamma$	-12372

The TM/LP setpoint is calculated by the  $P_{VAR}$  equation, shown below and in Figure 1:

$$P_{VAR} = 29.6 PF(B) A1(Y)B + 20.63T_{IN} - 12372$$

$$\begin{aligned} PF(B) &= 1.0 && \text{for } B \geq 100\% \\ &= -0.008(B)+1.8 && \text{for } 50\% < B < 100\% \\ &= 1.4 && \text{for } B \leq 50\% \end{aligned}$$

$$\begin{aligned} A1(Y) &= -0.6666(Y_1) + 1.000 && \text{for } Y_1 \leq 0.00 \\ &= +0.3333(Y_1) + 1.000 && \text{for } Y_1 > 0.00 \end{aligned}$$

Where:

B = High Auctioneered thermal ( $\Delta T$ ) or Nuclear Power, % of rated power

Y = Axial Shape Index, asi

$T_{IN}$  = Core Inlet Temperature, °F

$P_{VAR}$  = Reactor Coolant System Pressure, psia

### 4. MAXIMUM CORE INLET TEMPERATURE

The maximum core inlet temperature ( $T_{IN}$ ) shall not exceed **545°F**. This value includes instrumentation uncertainty of  $\pm 2^\circ\text{F}$  (Ref: FCS Calculation FC06292, 6/9/95).

This limit is not applicable during either a thermal power ramp in excess of 5% of rated thermal power per minute or a thermal power step greater than 10% of rated thermal power.

### 5. POWER DEPENDENT INSERTION LIMIT

The power dependent insertion limit is defined in Figure 2.

6. **LINEAR HEAT RATE**

The allowable peak linear heat rate is shown in Figure 3.

7. **EXCORE MONITORING OF LHR**

The allowable operation for power versus axial shape index for monitoring of LHR with excore detectors is shown in Figure 4.

8. **PEAKING FACTOR LIMITS**

The maximum full power value for the integrated radial peaking factor ( $F_R^T$ ) is 1.732.

9. **DNB MONITORING**

The core operating limits for monitoring of DNB are provided in Figure 5. This figure provides the allowable power versus axial shape index for the cycle.

10.  **$F_R^T$  AND CORE POWER LIMITATIONS**

Core power limitations versus  $F_R^T$  are shown in Figure 6.

11. **REFUELING BORON CONCENTRATION**

The refueling boron concentration is required to ensure a shutdown margin of not less than 5% with all CEAs withdrawn. The refueling boron concentration must be at least **1,900 ppm** through the end of Cycle 24 operation and is valid until the beginning of core reload for Cycle 25.

Listed below in Table 2 are the refueling boron concentration values for Cycle 25 operations:

**Table 2 - Refueling Boron Concentrations**

Cycle Average Burnup (MWD/MTU)	Refueling Boron Concentration (ppm)
BOC	2,141
$\geq 2,000$	2,014
$\geq 4,000$	1,900

**12. AXIAL POWER DISTRIBUTION**

The axial power trip is provided to ensure that excessive axial peaking will not cause fuel damage. The Axial Shape Index is determined from the axially split excore detectors. The setpoint functions, shown in Figure 7 ensure that neither a DNBR of less than the minimum DNBR safety limit nor a fuel centerline temperature greater than the associated safety limit (that which would result in fuel melting) will exist as a consequence of axial power maldistributions. The calculated cycle-specific FCM temperature for Cycle 25 corresponds to 23.416 kw/ft. Allowances have been made for instrumentation inaccuracies and uncertainties associated with the excore symmetric offset – incore axial peaking relationship. Figure 8 combines the LHR LCO tent from Figure 4, the DNB LCO tent from Figure 5, and the APD LSSS tent from Figure 7 into one figure for a visual comparison of the different limits.

**13. SHUTDOWN MARGIN WITH  $T_{\text{cold}} > 210^{\circ}\text{F}$**


Whenever the reactor is in hot shutdown, hot standby or power operation conditions, the shutdown margin shall be  $\geq 3.6\% \Delta k/k$ . With the shutdown margin  $< 3.6\% \Delta k/k$ , initiate and continue boration until the required shutdown margin is achieved.

**14. MOST NEGATIVE MODERATOR TEMPERATURE COEFFICIENT**

The moderator temperature coefficient (MTC) shall be more positive than  $-3.30 \times 10^{-4} \Delta\rho/^{\circ}\text{F}$ , including uncertainties, at rated power.

**15. STEAM GENERATOR DIFFERENTIAL PRESSURE**

The steam generator differential pressure trip of Technical Specification Table 2-11, Item 9 at 135 psid ensures that neither a DNBR of less than the minimum DNBR safety limit nor a fuel centerline temperature greater than the associated safety limit (that which would result in fuel melting) will exist as a consequence of axial power maldistributions resulting from asymmetric steam generator transients. The calculated cycle-specific FCM temperature for Cycle 25 corresponds to 23.416 kw/ft.



$$P_{VAR} = 29.6 PF(B)A1(Y)B + 20.63T_{IN} - 12372$$

$$PF(B) = 1.0$$

$$= -.008B + 1.8$$

$$= 1.4$$

$$B \geq 100\%$$

$$50\% < B < 100\%$$

$$B \leq 50\%$$

$$A1(Y) = -0.6666Y_1 + 1.000$$

$$= +0.3333Y_1 + 1.000$$


$$Y_1 \leq 0.00$$

$$Y_1 > 0.00$$

COLR

THERMAL MARGIN / LOW PRESSURE  
FOR 4 PUMP OPERATION


FIGURE  
1




COLR

POWER DEPENDENT INSERTION LIMIT


FIGURE  
2



COLR	ALLOWABLE PEAK LINEAR HEAT RATE VS. BURNUP	FIGURE 3
------	---	-------------



COLR	EXCORE MONITORING OF LHR	FIGURE 4
------	--------------------------	-------------




COLR

DNB MONITORING

FIGURE  
5






COLR

$F_R^T$  AND CORE POWER LIMITATIONS


FIGURE  
6



COLR

AXIAL POWER DISTRIBUTION LSSS  
FOR 4 PUMP OPERATION


FIGURE  
7



COLR

AXIAL POWER DISTRIBUTION LIMITS FOR 4  
PUMP OPERATION WITH INCORES INOPERABLE

FIGURE  
8



▲ 1800 PPM  
IN SIRWT

× 1900 PPM  
IN SIRWT

◆ 2000 PPM  
IN SIRWT

■ 2150 PPM  
IN SIRWT

+ 2300 PPM  
IN SIRWT

COLR

MINIMUM BAST LEVEL vs. STORED  
BAST CONCENTRATION

FIGURE  
9