


Nondestructive Evaluation: Ultrasonic Equivalency Testing of Weld Inlaid Components

1016543



Nondestructive Evaluation: Ultrasonic Equivalency Testing of Weld Inlaid Components

1016543

Technical Update, April 2008

EPRI Project Manager

C. Latiolais

DISCLAIMER OF WARRANTIES AND LIMITATION OF LIABILITIES

THIS DOCUMENT WAS PREPARED BY THE ORGANIZATION(S) NAMED BELOW AS AN ACCOUNT OF WORK SPONSORED OR COSPONSORED BY THE ELECTRIC POWER RESEARCH INSTITUTE, INC. (EPRI). NEITHER EPRI, ANY MEMBER OF EPRI, ANY COSPONSOR, THE ORGANIZATION(S) BELOW, NOR ANY PERSON ACTING ON BEHALF OF ANY OF THEM:

(A) MAKES ANY WARRANTY OR REPRESENTATION WHATSOEVER, EXPRESS OR IMPLIED, (I) WITH RESPECT TO THE USE OF ANY INFORMATION, APPARATUS, METHOD, PROCESS, OR SIMILAR ITEM DISCLOSED IN THIS DOCUMENT, INCLUDING MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, OR (II) THAT SUCH USE DOES NOT INFRINGE ON OR INTERFERE WITH PRIVATELY OWNED RIGHTS, INCLUDING ANY PARTY'S INTELLECTUAL PROPERTY, OR (III) THAT THIS DOCUMENT IS SUITABLE TO ANY PARTICULAR USER'S CIRCUMSTANCE; OR

(B) ASSUMES RESPONSIBILITY FOR ANY DAMAGES OR OTHER LIABILITY WHATSOEVER (INCLUDING ANY CONSEQUENTIAL DAMAGES, EVEN IF EPRI OR ANY EPRI REPRESENTATIVE HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES) RESULTING FROM YOUR SELECTION OR USE OF THIS DOCUMENT OR ANY INFORMATION, APPARATUS, METHOD, PROCESS, OR SIMILAR ITEM DISCLOSED IN THIS DOCUMENT.

ORGANIZATION(S) THAT PREPARED THIS DOCUMENT

Electric Power Research Institute (EPRI)

AREVA NP, Inc.

WesDyne International, LLC

This is an EPRI Technical Update report. A Technical Update report is intended as an informal report of continuing research, a meeting, or a topical study. It is not a final EPRI technical report.

NOTE

For further information about EPRI, call the EPRI Customer Assistance Center at 800.313.3774 or e-mail askepri@epri.com.

Electric Power Research Institute, EPRI, and TOGETHER...SHAPING THE FUTURE OF ELECTRICITY are registered service marks of the Electric Power Research Institute, Inc.

Copyright © 2008 Electric Power Research Institute, Inc. All rights reserved.

CITATIONS

This document was prepared by

Electric Power Research Institute (EPRI)
Nondestructive Evaluation (NDE) Program
1300 W.T. Harris Blvd.
Charlotte, NC 28262

Principal Investigator
C. Latiolais

AREVA NP, Inc.
155 Mill Ridge Road, MRR-1
Lynchburg, VA 24502

Principal Investigator
C. Graves

WesDyne International, LLC
P.O. Box 409
Madison, PA 15663

Principal Investigator
A. Moreau

This document describes research sponsored by EPRI.

The publication is a corporate document that should be cited in the literature in the following manner:

Nondestructive Evaluation: Ultrasonic Equivalency Testing of Weld Inlaid Components. EPRI, Palo Alto, CA: 2008. 1016543.

PRODUCT DESCRIPTION

This report describes an investigation in which ultrasonic data were acquired by following the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, Appendix VIII, qualified procedures from both a Performance Demonstration Initiative (PDI) 601 series hot leg to reactor vessel mockup and a Pressurized Water Reactor Owners Group inlay test mockup containing similar crack-like flaws. The objective of this investigation was to determine the equivalency of using qualified techniques for the inspection of inlaid nozzle dissimilar metal welds from the inner surface of the nozzle.

Results and Findings

Experiments performed by AREVA NP and WesDyne International demonstrated that qualified techniques for inspecting inlaid nozzle dissimilar metal welds from the inner surface of the nozzle can be used to detect, characterize, and size the length and depth of axial and circumferential flaws. No procedural changes were required by either vendor during these demonstrations, and the qualified techniques worked as expected. The data, which are presented in this report, demonstrate that inlaid components can be examined reliably using the current Appendix VIII qualified inside surface procedures with no further demonstrations required for procedures, personnel, or equipment.

Challenges and Objective

The hot and cold leg primary nozzles in PWRs contain dissimilar metal weld configurations using Alloy 600 materials joining the ferritic reactor pressure vessel to the austenitic coolant piping. Because these welds are exposed to primary coolant water, they are susceptible to primary water stress corrosion cracking (PWSCC). As a result, the Electric Power Research Institute (EPRI) report 1010087, *Materials Reliability Program: Primary System Piping Butt Weld Inspection and Evaluation Guideline* (MRP-139), requires an increased inspection frequency on these components unless actions are taken to minimize the risk for PWSCC. In response to MRP-139, the weld inlay was designed to isolate the PWSCC-susceptible material from the primary environment.

The objective of this investigation was to determine the equivalency of using qualified techniques for the inspection of inlaid nozzle dissimilar metal welds from the inner surface of the nozzle. A demonstration of equivalency would allow the use of these techniques and associated procedures on inlay weld designs without the need for additional qualification activities.

Application, Value, and Use

Currently, 31 plants in the United States have the potential for PWSCC in their hot and cold leg primary nozzles and could benefit from inlay mitigation.

EPRI Perspective

ASME Section XI, Appendix VIII, currently identifies requirements for examination of structural weld inlay (corrosion-resistant clad) austenitic piping welds as “In Course of Preparation.” Therefore, implementation of Appendix VIII qualified examination techniques might require utilities to submit one or more relief requests. EPRI, in conjunction with affected utilities, will develop guidelines for these relief requests as required. These guidelines, along with applicable safety evaluation reports, will be available at www.epriq.com.

Approach

An inlay test mockup was created that was identical to an existing PDI 601 series weld configuration. This mockup is a full-scale representation of a PWR hot leg to reactor pressure vessel DMW, including the safe-end and the safe-end-to-pipe connecting weld. Both the 601 and the inlay mockup were fabricated from actual dropouts taken from a cancelled PWR in order to ensure that materials and welding processes are typical of those found in an operating plant. The inlay material was applied using welding techniques and hardware developed by AREVA NP. In order to identify welding imperfections that might exist in the DMW, the inlay mockup was ultrasonically inspected by AREVA NP using a qualified Appendix VIII procedure before inlay material was applied.

AREVA NP and WesDyne International inspected the inlay mockup and used previously collected data on similar flaws in the 601 mockup for comparison. Data were collected following each vendor’s applicable Appendix VIII qualified automated ultrasonic procedure. Both vendors had prior knowledge of the crack-like flaw locations and sizes for the inlay mockup. The ultrasonic scanning was conducted under the observation and guidance of EPRI PDI personnel to ensure procedural compliance. All scanning was performed from the inner diameter surface, with scanning in both axial and circumferential directions using qualified equipment.

Keywords

Inlay
Dissimilar metal weld
Mitigation
Pressurized water reactor (PWR)
Nozzles
Ultrasonic examination

CONTENTS

1 INTRODUCTION	1-1
Objective	1-1
Background	1-1
2 EQUIVALENCY TESTING APPROACH.....	2-1
Mockup	2-1
Data Collection.....	2-1
3 RESULTS	3-1
4 SUMMARY	4-1
A WESDYNE REPORT	A-1
B AREVA NP REPORT	B-1

LIST OF FIGURES

Figure 2-1 Inlay mockup drawing: location of flaws	2-2
Figure 2-2 Inlay mockup drawing: inspection data.....	2-3
Figure 2-3 Inlay mockup drawing: location of embedded flaws	2-4
Figure 2-4 Inlay mockup drawing: orientation of machined pockets and terraces	2-5
Figure 3-1 Typical axial flaw image (AREVA) from 601 and 1 in. (2.54 cm) inlay mockup	3-1
Figure 3-2 Typical ultrasonic image (WesDyne) from 601 block of circumferentially oriented flaws	3-2
Figure 3-3 Typical ultrasonic image (WesDyne) from inlay mockup of circumferentially oriented flaws (opposite directions)	3-5
Figure 3-4 Circumferential scan data (WesDyne) showing background noise increase with inlay thickness.....	3-5

LIST OF TABLES

Table 3-1 WesDyne detection and sizing results 3-2

Table 3-2 AREVA detection and length sizing results 3-3

Table 3-3 AREVA depth sizing results 3-4

1

INTRODUCTION

Objective

This report documents the results of equivalency testing between Performance Demonstration Initiative (PDI) qualified ultrasonic inspection techniques applied to the Pressurized Water Reactor Owners Group inlay test mockup. This project was designed to evaluate the effectiveness of current automated ultrasonic procedures developed for inner surface inspection on inlaid welds without modification of essential variables. A demonstration of equivalency would allow the use of these techniques and associated procedures on inlay weld designs without the need for additional qualification activities.

Background

Primary water stress corrosion cracking (PWSCC) was first identified as a failure mechanism for Alloy 600 materials in reactor pressure vessels in the United States following the leakage event of a pressurizer heater sleeve at Calvert Cliffs Unit 2 in 1989. Since then, considerable research has been conducted on the environmental influences of this cracking phenomenon. PWSCC occurs in Alloy 600 materials that are directly exposed to the primary coolant water. The susceptibility and onset of cracking for a particular component is influenced by temperature, pressure, material residual stresses, water chemistry, and service life, with incidences in both BWRs and PWRs. The focus of this report is PWSCC and related inlay mitigation in PWRs, specifically the hot and cold leg primary nozzle dissimilar metal welds (DMWs). Currently, 31 plants in the United States have the potential for PWSCC in their hot and cold leg primary nozzles and could benefit from inlay mitigation.

The hot and cold leg primary nozzles in PWRs contain DMW configurations using Alloy 600 materials joining the ferritic reactor pressure vessel to the austenitic coolant piping. Because these welds are exposed to primary coolant water, susceptibility to PWSCC exists. As a result, the Electric Power Research Institute (EPRI) report 1010087, *Materials Reliability Program: Primary System Piping Butt Weld Inspection and Evaluation Guideline* (MRP-139), requires an increased inspection frequency on these components unless actions are taken to minimize the risk for PWSCC. In response to MRP-139, the weld inlay was designed to isolate the PWSCC-susceptible material from the primary environment.

Weld inlay is a process in which weld material is deposited onto the inner surface of the nozzle using remote, automated welding techniques. Although the inlay can provide additional structural support for the weldment, its primary function is to isolate the Alloy 600 material from the primary coolant water. Isolating the susceptible material allows the component's classification to change to Category A, as defined by MRP-139. As a result, the inspection frequency decreases to a 10-year in-service inspection cycle. In contrast, plants using a full structural overlay mitigation strategy still require increased inspection frequency under current guidelines because isolation of the susceptible material was not achieved.

Although an inlay mitigation process can decrease the frequency of inspection as required by MRP-139, it does not eliminate inspection requirements. Presently, ASME Section XI, Appendix VIII, Supplement 10, specifically excludes components with corrosion-resistant cladding from the scope of the qualification for procedures, personnel, and equipment. Therefore, no PDI-qualified technique currently exists that can be used to inspect inlaid DMWs. However, qualified examination procedures do exist that are applicable for hot and cold leg DMWs from the inside surface, but they apply only to unclad austenitic surfaces.

Before this investigation, the effect of inlay material on the ability to ultrasonically inspect a DMW using a qualified procedure was unknown. The primary focus of this project is to evaluate the capabilities of Appendix VIII, Supplement 10, qualified procedures used for examination of DMWs from the inside surface on an inlaid component. The data collected should clearly show the effect of inlay material on the ability to ultrasonically detect and size flaws that might develop later in the service life of an inlaid component. If equivalency is demonstrated, the need for additional qualification activities would be eliminated because currently available inspection procedures could be used.

2

EQUIVALENCY TESTING APPROACH

Mockup

An inlay test mockup was created that was identical to an existing PDI 601 series weld configuration. This mockup is a full-scale representation of a PWR hot leg to reactor pressure vessel DMW, including the safe-end and the safe-end-to-pipe connecting weld. Both the 601 and the inlay mockup were fabricated from actual dropouts taken from a cancelled PWR to ensure that materials and welding processes are typical of those found in an operating plant. The inlay material was applied using welding techniques and hardware developed by AREVA NP. In order to identify welding imperfections that might exist in the DMW, the inlay mockup was ultrasonically inspected by AREVA NP using a qualified Appendix VIII procedure before inlay material was applied.

The inlay test mockup has four 90° quadrants with varying inlay thicknesses that were blended smooth on the inner diameter surface. The first quadrant of the mockup was used for a baseline for noise comparison and had no weld inlay or flaws. The second and third quadrants have 0.20-in. and 0.07-in. (0.508-cm and 0.178-cm) thick inlays, respectively. In addition to the inlay, the three quadrants have the same set of four flaws identified as Flaws 1, 2, 3, and 12, which are identical to flaws found in the 601 practice mockup. In the fourth quadrant, an embedded flaw represents the partial removal and subsequent 1-in. (2.54-cm) deep inlay repair of a deep flaw. The flaws were implanted in the mockup using the same techniques used for the fabrication of the PDI 601 mockup. The flaws were generated using an electrodischarged machining technique, with the topography of the notch designed to simulate that of a crack. Figures 2-1 through 2-4 are drawings of the inlay mockup.

Data Collection

Two vendors were contracted to inspect the inlay mockup. Previously collected data on similar flaws in the 601 mockup were used as a comparative reference. All data were collected following each vendor's applicable Appendix VIII qualified automated ultrasonic procedure. The procedures used by the vendors were AREVA NP's 54-ISI-821-000, "ID Automated Ultrasonic Examination of Austenitic and Dissimilar Metal Piping Welds for Detection and Length Sizing," and 54-ISI-822-000, "ID Automated Ultrasonic Examination of Austenitic and Dissimilar Metal Piping Welds for Depth Sizing," and WesDyne's PDI-ISI-254-SE, "Field Inspection Procedure," Revision 2. Both vendors had prior knowledge of the crack-like flaw locations and sizes for the inlay mockup. The ultrasonic scanning was conducted under the observation and guidance of EPRI PDI personnel to ensure procedural compliance. All scanning was performed from the inner diameter surface, with scanning in both axial and circumferential directions using qualified equipment.







3

RESULTS

Both vendors prepared inspection reports summarizing the flaw detection capabilities and sizing results for the four flaws using data collected from mockup 601 for comparison. Figures 3-1 and 3-2 show typical flaw images obtained from mockup 601. The inspection reports contain objective evidence in the form of data images and quantitative measurements to support the findings and conclusions. These reports are provided in Appendix A, WesDyne Report WDI-DFD-2009-QDP-001, and Appendix B, AREVA NP Report 51-9068587-000.




Figure C-29
601-1 Flaw 3: 80°L from Positive Direction
Reference Flaw




Figure C-30
Inlay Mockup Flaw 3-4: 80°L from Positive Direction
Quadrant 4 – 1" Inlay

Figure 3-1
Typical axial flaw image (AREVA) from 601 and 1 in. (2.54 cm) inlay mockup





Figure 3-2
Typical ultrasonic image (WesDyne) from 601 block of circumferentially oriented flaws

Both vendors reported similar findings with respect to flaw detection, sizing, and relative noise levels within the areas of the inlay. Both vendors were able to detect, characterize, length size, and depth size all the implanted axial and circumferential flaws within the tolerances imposed by EPRI's PDI-qualified inspection procedures. Tables 3-1, 3-2, and 3-3 summarize the measurements obtained by each vendor on each flaw.

Table 3-1
WesDyne detection and sizing results

			PLANT					
			PROCEDURE					
			COMPONENT					
			ANALYST					
			PDI Supplement 2 10 Demonstration					
			PDI -JSI-254-SE Rev. 2					
			Actual Flaw size to UT results of 601 block and Inlay Block					
Indication No.	Actuals		601 Sizing		Inlay Sizing			COMMENTS
	Length	T/W	Length	T/W	Ind. No.	Length	T/W	
1	1.80"	0.339"	1.875"	0.37"	1-Q2	1.75"	0.37"	
2	2.63"	0.350"	2.75"	0.39"	2-Q2	2.75"	0.34"	
3	* 0.60" ** 0.50"	0.374"	0.40"	0.44"	3-Q2	0.64"	0.40"	
12	3.05"	0.815"	3.25"	0.79"	12-Q2	3.00"	0.81"	
embed	2.23"	0.70"						
					1-Q3	1.75"	0.42"	
					2-Q3	2.375"	0.33"	
					3-Q3	0.64"	0.37"	
					12-Q3	2.875"	0.81"	
					1-Q4	1.625"	0.36"	
					2-Q4	2.625"	0.37"	
					3-Q4	0.72"	0.27"	
					12-Q4	3.125"	0.77"	
					embed	2.25"	0.71"	

* 601 Block
 ** Inlay Block

1 in. = 2.54 cm

Table 3-2

AREVA detection and length sizing results

Flaw detection and length sizing results for inlay mockup and mockup 601-1 comparisons

Circumferential Flaws									Measurements from the Nozzle Side					Measurements from the Safe-end Side				
Mockup	Quadrant Start (deg.)	Flaw #	Reference Location (deg.)	Actual Flaw Length (in.)	Actual Flaw Length (deg.)	Actual Center Position (deg.)	Actual Flaw Start Position (deg.)	Actual Flaw End Position (deg.)	Measured Flaw Start Position (deg.)	Measured Flaw End Position (deg.)	Measured Flaw Length (in.)	Measured Flaw Length (deg.)	Length Variance (in.)	Measured Flaw Start Position (deg.)	Measured Flaw End Position (deg.)	Measured Flaw Length (in.)	Measured Flaw Length (deg.)	Length Variance (in.)
601-1	N/A	2	343.40	2.63	10.40	343.40	338.20	348.60	-22.14	-10.20	3.02	11.94	0.39	-22.02	-11.12	2.76	10.90	0.13
		1	0.00	1.80	7.10	0.00	-3.55	3.55	-2.77	4.03	1.72	6.80	-0.08	-3.34	4.18	1.90	7.52	0.10
		12	17.80	3.05	12.10	17.80	11.75	23.85	12.26	24.79	3.17	12.63	0.12	11.82	24.15	3.12	12.33	0.07
Inlay	90	2-2	29.80	2.63	11.00	119.80	114.30	125.30	116.82	128.22	2.74	11.40	0.11	117.18	127.81	2.55	10.63	-0.08
		1-2	46.40	1.80	7.50	136.40	132.65	140.15	135.38	142.42	1.69	7.04	-0.11	136.42	142.67	1.50	6.25	-0.30
		12-2	64.20	3.05	12.70	154.20	147.85	160.55	150.90	163.60	3.02	12.60	-0.03	149.97	163.27	3.19	13.30	0.14
	180	2-3	29.80	2.63	11.00	209.80	204.30	215.30	207.44	218.07	2.55	10.63	-0.08	207.01	218.46	2.75	11.45	0.12
		1-3	46.40	1.80	7.50	226.40	222.65	230.15	225.36	232.82	1.79	7.46	-0.01	225.73	233.01	1.75	7.28	-0.05
		12-3	64.20	3.05	12.70	244.20	237.85	250.55	240.27	253.72	3.23	13.45	0.18	239.99	253.40	3.22	13.41	0.17
	270	2-4	42.60	2.63	11.00	312.60	307.10	318.10	310.00	320.97	2.63	10.97	0.00	309.66	321.10	2.75	11.44	0.12
		1-4	59.20	1.80	7.50	329.20	325.45	332.95	328.49	335.09	1.58	6.60	-0.22	328.48	334.61	1.47	6.13	-0.33
		12-4	77.00	3.05	12.70	347.00	340.65	353.35	342.86	355.37	3.00	12.51	-0.05	343.32	356.04	3.05	12.72	0.00
		embedded	17.00	2.15	9.00	287.90	283.40	292.40	283.83	293.72	2.37	9.89	0.22	286.95	295.20	1.98	8.25	-0.17

Axial Flaws									Negative Beam Direction Measurements					Positive Beam Direction Measurements				
Mockup	Quadrant Start (deg.)	Flaw #	Reference Location (deg.)	Actual Flaw Length (in.)	Beam Angle (deg.)	Actual Center Position (deg.)	Actual Flaw Start Position (deg.)	Actual Flaw End Position (deg.)	Measured Flaw Start Position (in.)	Measured Flaw End Position (in.)	Measured Flaw Length (in.)	Measured Flaw Length (deg.)	Length Variance (in.)	Measured Flaw Start Position (in.)	Measured Flaw End Position (in.)	Measured Flaw Length (in.)	Measured Flaw Length (deg.)	Length Variance (in.)
601-1	N/A	3	325.60	0.60	60L	325.60	325.60	325.60	-0.42	-0.94	0.52	0.00	-0.08	-0.64	-0.99	0.35	0.00	-0.25
Inlay	90	3-2	12.00	0.60	60L	102.00	102.00	102.00	ND	ND				0.01	0.41	0.40	0.00	-0.20
	180	3-3	12.00	0.60	60L	192.00	192.00	192.00	-0.32	0.18	0.50	0.00	-0.10	-0.28	0.22	0.50	0.00	-0.10
	270	3-4	24.80	0.60	60L	294.80	294.80	294.80	ND	ND				0.01	0.56	0.55	0.00	-0.05
601-1		3	325.60	0.60	80L	325.60	325.60	325.60	-0.59	-1.14	0.55	0.00	-0.05	-0.54	-1.15	0.61	0.00	0.01
Inlay	90	3-2	12.00	0.60	80L	102.00	102.00	102.00	-0.42	0.07	0.49	0.00	-0.11	-0.43	0.11	0.54	0.00	-0.06
	180	3-3	12.00	0.60	80L	192.00	192.00	192.00	-0.48	0.09	0.57	0.00	-0.03	-0.43	0.06	0.49	0.00	-0.11
	270	3-4	24.80	0.60	80L	294.80	294.80	294.80	ND	ND				-0.19	0.46	0.65	0.00	0.05

Note: ND means the flaw was not detected.

Table 3-3
AREVA depth sizing results

Flaw Depth Sizing Results for Inlay Mockup and Mockup 601-1 Comparisons											
Circumferential Flaws										UT Measurement	
Mockup	Quadrant Start (deg.)	Flaw #	Reference Location (deg.)	Actual Flaw Length (in.)	Actual Flaw Length (deg.)	Actual Center Position (deg.)	Actual Flaw Start Position (deg.)	Actual Flaw End Position (deg.)	Actual Flaw Depth (in.)	Measured Flaw Depth (in.)	Depth Variance (in.)
601-1	N/A	2	343.40	2.63	10.40	343.40	338.20	348.60	0.350	0.290	-0.060
		1	0.00	1.80	7.10	0.00	-3.55	3.55	0.339	0.390	0.051
		12	17.80	3.05	12.10	17.80	11.75	23.85	0.815	0.823	0.008
Inlay	90	2-2	29.80	2.63	11.00	119.80	114.30	125.30	0.350	0.355	0.005
		1-2	46.40	1.80	7.50	136.40	132.65	140.15	0.339	0.405	0.066
		12-2	64.20	3.05	12.70	154.20	147.85	160.55	0.815	0.850	0.035
	180	2-3	29.80	2.63	11.00	209.80	204.30	215.30	0.350	0.349	-0.001
		1-3	46.40	1.80	7.50	226.40	222.65	230.15	0.339	0.306	-0.033
		12-3	64.20	3.05	12.70	244.20	237.85	250.55	0.815	0.844	0.029
	270	2-4	42.60	2.63	11.00	312.60	307.10	318.10	0.350	0.343	-0.007
		1-4	59.20	1.80	7.50	329.20	325.45	332.95	0.339	0.319	-0.020
		12-4	77.00	3.05	12.70	347.00	340.65	353.35	0.815	0.876	0.061
	Embedded	17.00	2.15	9.00	287.00	283.40	292.40	0.701	0.728	0.027	

Axial Flaws										UT Measurement	
Mockup	Quadrant Start (deg.)	Flaw #	Reference Location (deg.)	Actual Flaw Length (in.)	Beam Angle (deg.)	Actual Center Position (deg.)	Actual Flaw Start Position (deg.)	Actual Flaw End Position (deg.)	Actual Flaw Depth (in.)	Measured Flaw Depth (in.)	Depth Variance (in.)
601-1	N/A	3	325.6	0.6	60L	325.6	325.6	325.6	0.374	0.460	0.086
Inlay	90	3-2	12	0.6	60L	102	102	102	0.374	0.332	-0.042
	180	3-3	12	0.6	60L	192	192	192	0.374	0.322	-0.052
	270	3-4	24.8	0.6	60L	294.8	294.8	294.8	0.374	0.472	0.098

1 in. = 2.54 cm

Figures 3-1 and 3-3 show typical flaw images obtained from the inlay mockup. Although the procedures are not qualified for the detection and sizing of embedded flaws, the embedded flaw in quadrant four was also successfully detected and sized using procedurally acceptable search units and techniques. No procedural changes were required by either vendor during these demonstrations, and the qualified techniques worked as expected.




Figure 3-3
Typical ultrasonic image (WesDyne) from inlay mockup of circumferentially oriented flaws (opposite directions)

The procedures used for this investigation use high beam angles and are not designed to detect an inlay disbond condition. This report demonstrates technique equivalency of crack detection techniques; it does not address the detection of flaws contained in inlay material or at the inlay-to-parent material bond.

Both vendors observed an apparent increase in the noise level in the areas where the inlays were applied. This reference noise level increased as the thickness of the inlay material increased, with the largest reference noise level appearing in the fourth quadrant, where the 1 in. (2.54 cm) inlay material was located. Figure 3-4 is an ultrasonic image that shows the relative noise level of each quadrant.




Figure 3-4
Circumferential scan data (WesDyne) showing background noise increase with inlay thickness

Figure 3-4 clearly illustrates an increase in background noise level associated with the 1 in. (2.54 cm) inlay material when compared to the rest of the block. In the axially oriented flaws, the signal-to-noise ratio was more noticeably affected, but it was not at a level that would impact the results of the examination. This increase in noise generally made flaw depth sizing more difficult, but it had a lesser effect on detection capabilities. Although the precise cause of this noise is not known, it is assumed to be associated with the microstructure of the inlay material. Possible causes could be related to small discontinuities in the material or a preferred orientation of crystallographic grain structure and size that tends to scatter the sound energy as it passes through. Both vendors recommended further investigations to determine the origin of the noise and to determine whether the welding process could be modified to reduce or eliminate the noise.

4

SUMMARY

The objective of this project was to demonstrate the equivalency of existing ASME Section XI, Appendix VIII, Supplement 10 or 14, automated ultrasonic procedures on inlay weld configurations. This was demonstrated through a series of tests by two vendors in which a mockup representing inlays of various thicknesses was inspected using qualified procedures and probes. Both vendors were able to successfully detect, characterize, and length and depth size all the flaws in the inlay mockup without deviating from the procedurally qualified techniques. These experiments demonstrate that components inlaid in a process similar to that used to fabricate the inlay mockup can be examined reliably using the current Appendix VIII qualified inside surface procedures with no further demonstrations required, assuming the inlay material is properly bonded and free of flaws.

Although an increased noise level was noted in the areas where the inlay was applied, it did not affect the procedures' capabilities to detect, characterize, and size the flaws, and it had no effect on the examination. However, it is recommended that additional work be performed to determine whether the welding process can be modified to reduce or eliminate the source of this noise, which would enhance the effectiveness of the examination.

ASME Section XI, Appendix VIII, currently identifies requirements for examination of structural weld inlay (corrosion-resistant clad) austenitic piping welds as "In Course of Preparation." Therefore, implementation of Appendix VIII qualified examination techniques might require utilities to submit one or more relief requests. EPRI, in conjunction with affected utilities, will develop guidelines for these relief requests as required. These guidelines, along with applicable safety evaluation reports, will be available at www.epriq.com.

A

WESDYNE REPORT

WesDyne report number WDI-DFD-2009-QDP-001, "Report Summary for Supplements 2 and 10 Flaw Comparisons between EPRI Block 601 and the Inlay Test Block," Revision 0, December 2007.



WDI-DFD-2009-QDP-001

DEMONSTRATION OF TECHNIQUE:

**Report Summary for Supplements 2 and 10 Flaw Comparisons
between EPRI Block 601 and the Inlay Test Block**

Revision 0

December 2007

**WesDyne International LLC
P.O. BOX 409
I-70 EXIT 25A – Gate D
Madison, PA. 15663
(800) 443-9622**







WDI-DFD-2009-QDP-001

DEMONSTRATION OF TECHNIQUE:

**Report Summary for Supplements 2 and 10 Flaw Comparisons
between EPRI Block 601 and the Inlay Test Block**

December 2007

Prepared by: <u></u>	Date: <u>1-3-08</u>
A. Moreau	
Reviewed by: <u></u>	Date: <u>1-3-08</u>
D. Kurek	
Reviewed by: <u></u>	Date: <u>1-3-08</u>
M. Weatherly, Quality Assurance	
Approved by: <u></u>	Date: <u>1/3/08</u>
D. Adamonis, VP Engineering	

**WESDYNE INTERNATIONAL LLC
P.O. BOX 409
I-70 EXIT 25A – GATE D
MADISON, PA. 15663
(800) 443-9622**

DEMONSTRATION OF TECHNIQUE:

Report Summary for Supplements 2 and 10 Flaw Comparisons between EPRI Block 601 and the Inlay Test Block

Table of Contents

EXECUTIVE SUMMARY

- ATTACHMENT 1: UT Probe Calibrations**
- ATTACHMENT 2: Block 601 UT 70° Detection Results**
- ATTACHMENT 3: Block 601 UT Sizing Results**
- ATTACHMENT 4: Inlay Test Block UT 70° Detection Results**
- ATTACHMENT 5: Inlay Test Block UT Sizing Results**
- ATTACHMENT 6: 601 & Inlay Block Comparison Table**
- ATTACHMENT 7: Inlay Block Noise Comparison Image**
- ATTACHMENT 8: Inlay Block Test Plan**
- ATTACHMENT 9: Inlay Block Drawing 8019331D**

EXECUTIVE SUMMARY

1.0 INTRODUCTION

WesDyne International performed an open procedure demonstration by scanning an inlay test block using qualified procedure PDI-ISI-254-SE, Revision 2. The Inlay Test Block, (reference attachment 9) is a 360 degree welded replica of a primary loop piping DM and safe-end weld divided into four 90 degree segments. Three segments have protective stainless steel inlay applied in layers of varying thickness blended smooth to conform to the ID surface. The fourth segment represents a standard dissimilar metal safe end configuration without inlay. The Inlay Block segments contain a number of crack-like flaws oriented axially and circumferentially. The locations and sizes of the cracks were known to the exam team. Results from the inlay Test Block were compared to baseline data taken previously on PDI practice specimen 601, a standard DM safe end practice specimen containing crack indications. The purpose of the demonstration was to insure that procedures qualified for detection of flaws in primary piping DM welds (Section XI, Appendix VIII, Supplements 2 and 10), were capable of detecting and measuring flaws on primary piping DM welds mitigated by inlay without changing the essential variables of the qualified procedure.

All equipment, setup, scanning and data interpretation was performed between November 26 and Dec. 7, 2007 at the Westinghouse Waltz Mill Service Center. Processed data was also reviewed at EPRI after the initial assessment by WesDyne.

This demonstration was conducted as a controlled exercise under written instructions from a Program Plan developed by WesDyne using information supplied from EPRI and AREVA. Although not present for scanning, the Performance Demonstration Administrator (PDA) was fully informed about the progress of the project and the PDA provided guidance on the preparation of test results. In order to compare similar flaw data from non-inlay and inlay specimens, WesDyne used prior data taken on demonstration block 601 as a basis for comparison with data from the Inlay demonstration block. There are some crack sizes common to both specimens serving as a good basis for comparison.

All scanning was performed with the inlay mock-up immersed in a tank designed specifically for UT demonstrations with SUPREEM scanners. The test system was assembled in the essential configuration depicted in procedure PDI-ISI-254-SE, Revision 2. Examiners qualified to the procedure performed all relevant NDE tasks. The demonstration results were reviewed with Carl Latiolais of EPRI on December 7, at the EPRI NDE Center in Charlotte, NC.

2.0 EQUIPMENT DESCRIPTION

The ultrasonic test system used for this demonstration consisted of the following components:

- WesDyne PARAGON (Software Version Acq. 3.50 Proto. 2, Analysis, 6.3.0)
- SUPREEM ROSA 5 Scanner and associated hardware
- RD TECH Pulser/ Receiver
- Approved Transducers as defined in PDI-ISI-254-SE

The inlay test block was supplied by EPRI as part of this demonstration and is identified as 8019331D and is shown in Attachment 9.

2.0 EXAMINATION PROCESS

The following parts of the WesDyne Field Inspection Procedure, PDI-ISI-254-SE Rev. 2 were used in this demonstration:

- Calibration – The UT system was calibrated in accordance with Sections 6.0 and 8.0 of PDI-ISI-254-SE Rev. 2. Examination sensitivity was established per table 6.4.1 and verified by using the histogram method set forth in Paragraph 9.2.
- Evaluation of Data – The evaluation of data was performed in accordance with Section 9.0 of PDI-ISI-254-SE Rev. 2.
- Scanning was performed in both axial and circumferential directions. All scanning was performed at speeds less than 3 inches per second.

The scan boundaries, sled arrangement and test configuration are defined in the examinations were performed in accordance with the written Open Demonstration Test Plan found in Attachment 8.

3.0 SUMMARY OF RESULTS

- The demonstration was performed using procedure PDI-254-SE Rev. 2 to compare the flaws 1, 2, 3, & 12 of the EPRI practice block 601 to the EPRI replica inlay block which has three sets of virtually identical flaws. The three sets of flaws were positioned in three separate quadrants (2, 3 and 4) and are propagating through the inlay. Quadrant 1 is free from flaws and inlay and quadrant 4 has an additional embedded flaw. Varying thickness' of inlay material was place in each quadrant. Quadrant 2 has a 0.20" thick inlay, Quadrant 3 has a 0.07" thick inlay, and Quadrant 4 has a 1.0" thick inlay.
-

- Although all flaws were detected, through wall and length sized within tolerances of the qualification and procedure PDI-254-SE Rev 2, it should be noted that additional material noise was seen in the inlay areas that made it more difficult to discern sizing features (For a given flaw the signal to noise ratio was less in the EPRI block 601 when comparing the corresponding flaws in the inlayed areas). Flaws that were most affected by this elevated noise were circumferentially oriented flaw 12 in quadrant 4, and axially orientated flaw 3 in all 3 quadrants. Each of the axially orientated flaws was sized using the 60° instead of the 45° which is not the optimum angle for through wall sizing but is allowed by procedure. It should also be noted that even though there was more material noise observed in the processed data, the flaws were seen and measured with the procedure and no changes in the essential variables or procedure instructions were necessary to accomplish the overall objective.
- The results including printouts of all flaws and noise issues are in the following attachments according to the table of contents.

4.0 REFERENCES

- 4.1 Open Demonstration Plan (PDI Inlay Test Mockup) Rev. 0 Dated 11-8-07
- 4.2 WesDyne Inspection Procedure, PDI-ISI-254-SE Rev. 2: *Remote Inservice Examination of Reactor Vessel Nozzle To Safe End, Nozzle to Pipe and Safe End to Pipe Welds.*

ATTACHMENT 1:

UT Probe Calibrations

SENSITIVITY CALIBRATION DATA SHEET # SE-DET

Utility:	Wesdyne	Plant:		Unit:		Outage:	
Procedure No:	PSI-ISI-254-SE			Procedure Rev. No.:	2		
Applicable Weld Numbers:							
Applicable PARAGON UT Session(s):	Inlay SE-DET-Ax / Circ						

PARAGON Operator Signature:	Dal Nelson	Date:	11-30-07
UT Examiner Signature:	Dal Nelson	Date:	11-30-07

EQUIPMENT INFORMATION

PARAGON SAP #:		104591		RPR SAP #:		104592			
PARAGON Acq. Software Release No:			3.5.0 Proto 2		PARAGON Anal. Software Release No:			6.3.0	
Calibration/Inspection Cable Types			Cable Length (ft.)				No of Intermediate Connectors		
			Calibration		Inspection				
			Cable #1	Cable #2	Cable #3	Cable #4			
UT Probes to Underwater Connector			150'		150'	150'			
Underwater Connector to RPR			48"		48"	48"			
RPR to Remote CPU			40"		40"	40"			
UT Profile Probe Extension			N/A	N/A	6"				
		Color	Blk		White	Black			

UT PROBE INFORMATION

[illegible]

SENSITIVITY CALIBRATION DATA SHEET # SE-DET

UT SENSITIVITY/TIMEBASE CALIBRATION										
Calibration Block:		Navship		Calibration Block S/N:		103155		Block Temp:		70° F
Thermometer S/N:		105509		Couplant:		Demin		Essential Variable Settings per Appendix A, Figures A1-3 through A1-14:		
Wire #	Wire Color	RPR Channel (P/R #)	Probe S/N	Probe Angle (deg)	Buffer Bias	Hole I.D.	Hole Amp %FSH	Gain (dB)	Exam. Gain (dB)	Measured Depth (in)
1	Blk	1	01PW71	70	35	A	80	24	30	.247
2	Blk					B	53	---	---	.417
1	Blk	2	01PW72	70	33	A	80	25	31	.247
2	Blk					B	54	---	---	.427
1	Blk	3	01PHLH	0	182	ID	100	6	6	0
2	Blk							---	---	
1	Blk	4	01PW73	70	70	A	80	25	31	.247
2	Blk					B	50	---	---	.249
1	Blk	5	01PW74	70	70	A	80	24.5	30.5	.242
2	Blk					B	50	---	---	.452
								---	---	
								---	---	
			CLAD EXAM							
1	Blk	1	01NVC9	0	41	A	50	19.5	31.5	.222
2	Blk		PDI-Cal			C	29	---	---	.804

SENSITIVITY CALIBRATION DATA SHEET # SE-DET

CALIBRATION VERIFICATION									
Reference Block:		B1		Reference Block S/N:		103939		Block Temp: 70° F	
Thermometer S/N:		105509		Couplant:		Ultragel			
Essential Variable Settings per Appendix A, Figures A1-3 through A1-14, Sensitivity/Timebase Calibration and Para. 6.5.2:									
UT Sessions:		InlaySE-DET-Ax-Calver / InlaySE-DET-Circ-Calver							
Calibration Verification – Baseline									
Wire #s	Wire Color	RPR Channel (P/R #)	Probe S/N	Reflector ID	Amp. (%FSH)	Gain (dB)	Noise (dB or dB + %FSH)	Depth Position (in)	
1-2	Blk	1	01PW71	1" Radius	80	6.5	58	.664	
1-2	Blk	2	01PW72	1" Radius	80	7.0	56.5	.673	
1-2	Blk	4	01PW73	1" Radius	80	6.5	57	.779	
1-2	Blk	5	01PW74	1" Radius	80	6.5	53	.779	
Calibration Verification – Transfer									
Wire #s	Wire Color	RPR Channel (P/R #)	Probe S/N	Reflector ID	Amp. (%FSH)	Gain (dB)	Noise (dB or dB + %FSH)	Depth Position (in)	EPP Sled Position
1-2	W	1	01PW71	1" Radius	81	7.0	56	.664	D1
3-4	W	2	01PW72	1" Radius	78	7.0	57	.664	D2
5-6	W	4	01PW73	1" Radius	79	6.0	58	.782	D3
7-8	W	5	01PW74	1" Radius	82	6.5	51	.774	D4
Acceptance of Calibration Verification (Y or N):									

SENSITIVITY CALIBRATION DATA SHEET # SE-Size-Circ

Utility:	Wesdyne	Plant:		Unit:		Outage:	
Procedure No:	PSI-ISI-254-SE			Procedure Rev. No.:	2		
Applicable Weld Numbers:							
Applicable PARAGON UT Session(s):	Inlay SE-Size-Circ						

PARAGON Operator Signature:	Dal Nelson	Date:	11-30-07
UT Examiner Signature:	Dal Nelson	Date:	11-30-07

EQUIPMENT INFORMATION

PARAGON SAP #:		104591		RPR SAP #:		104592			
PARAGON Acq. Software Release No:			3.5.0 Proto 2		PARAGON Anal. Software Release No:			6.3.0	
Calibration/Inspection Cable Types			Cable Length (ft.)				No of Intermediate Connectors		
			Calibration		Inspection				
			Cable #1	Cable #2	Cable #3	Cable #4			
UT Probes to Underwater Connector			150'		150'	150'			
Underwater Connector to RPR			48"		48"	48"			
RPR to Remote CPU			40"		40"	40"			
UT Profile Probe Extension			N/A	N/A					
		Color	Blk		White	Black			

UT PROBE INFORMATION

[illegible]

SENSITIVITY CALIBRATION DATA SHEET # SE-Size-Circ[illegible]

SENSITIVITY CALIBRATION DATA SHEET # SE-Size-Circ

CALIBRATION VERIFICATION									
Reference Block:		B1		Reference Block S/N:		103939		Block Temp: 70° F	
Thermometer S/N:		105509		Couplant:		Ultragel			
Essential Variable Settings per Appendix A, Figures A1-3 through A1-14, Sensitivity/Timebase Calibration and Para. 6.5.2:									
UT Sessions:		InlaySE-Size-Circ-Calver							
Calibration Verification – Baseline									
Wire #s	Wire Color	RPR Channel (P/R #)	Probe S/N	Reflector ID	Amp. (%FSH)	Gain (dB)	Noise (dB or dB + %FSH)	Depth Position (in)	
1-2	Blk	1	01PWPV	1" Radius	80	4.0	62	0.709	
1-2	Blk	2	01PWPT	1" Radius	80	6.0	64	0.709	
1-2	Blk	3	01R157	1" Radius	80	9.0	70	0.515	
1-2	Blk	4	01R158	1" Radius	80	10.0	70	0.515	
1-2	Blk	5	01PW9D	2" Radius	82	4.5	40	1.62	
1-2	Blk	6	01PW9F	2" Radius	80	5.5	39	1.62	
Calibration Verification – Transfer									
Wire #s	Wire Color	RPR Channel (P/R #)	Probe S/N	Reflector ID	Amp. (%FSH)	Gain (dB)	Noise (dB or dB + %FSH)	Depth Position (in)	EPP Sled Position
1-2	Blk	1	01PWPV	1" Radius	81	4.5	64	0.709	S1
1-2	W	2	01PWPT	1" Radius	78	6.0	63	0.711	S2
3-4	Blk	3	01R157	1" Radius	80	8.5	68	0.519	S3
3-4	W	4	01R158	1" Radius	81	10.5	71	0.515	S4
5-6	Blk	5	01PW9D	2" Radius	84	5.0	42	1.64	S5
5-6	W	6	01PW9F	2" Radius	81	5.0	40	1.62	S6
Acceptance of Calibration Verification (Y or N):									

SENSITIVITY CALIBRATION DATA SHEET # InlaySE-Size-Ax

	Wesdyne	Plant:		Unit:		Outage:	
Procedure No:	PDI-ISI-254-SE			Procedure Rev. No.:	2		
Applicable Weld Numbers:							
Applicable PARAGON UT Session(s):		InlaySE-Size-Ax					

PARAGON Operator Signature:	Dal Nelson	Date:	12-1-07
UT Examiner Signature:	Dal Nelson	Date:	12-1-07

EQUIPMENT INFORMATION						
PARAGON SAP #:	104591		RPR SAP #:	104592		
PARAGON Acq. Software Release No:	3.5.0 Proto 2		PARAGON Anal. Software Release No:	6.3.0		
Calibration/Inspection Cable Types	Cable Length (ft.)					No of Intermediate Connectors
	Calibration		Inspection/ cal Cable			
	Cable #1	Cable #2	Cable #3	Cable #4	Cable #5	
UT Probes to Underwater Connector	150'	N/A	150'	150'	150'	0
Underwater Connector to RPR	48"	N/A	48"	48"	48"	0
RPR to Remote CPU	40"	N/A	40"	40"	40"	0
UT Profile Probe Extension	N/A	N/A	N/A	N/A	6"	0
Color	BLK	N/A	RED	WHITE	BLUE	

UT PROBE INFORMATION											
Make	Serial Number	Mode	Measured Sound Beam Exit Point (in.)	Measured Angle (deg)	Center Freq (MHz)	Bandwidth (%)	No of Elements	Element Shape	Element Size (mm)	Focal Sound Path (mm)	Contour (mm)
KB	01PWPR	L	0.0	45	1.89	58	2	Rect.	8.6 X 15.2	30mm	N/A
KB	01PWPW	L	0.0	45	1.89	58	2	Rect.	8.6 X 15.2	30mm	N/A
KB	01R154	L	0.0	60	1.95	62	2	Rect.	7.6 X 14.2	20mm	N/A
KB	01R155	L	0.0	60	1.95	62	2	Rect.	7.6 X 14.2	20mm	N/A
KB	01PYD0	L	0.0	45	1.46	66	2	Rect.	16 X 28.5	80mm	736mm
KB	01PYD1	L	0.0	45	1.46	66	2	Rect.	16 X 28.5	80mm	736mm
KB	01PW9H	L	0.0	37	1.04	58	2	Rect.	16 X 29.2	80mm	737.6mm
KB	10PW9J	L	0.0	37	1.04	58	2	Rect.	16 X 29.2	80mm	737.6mm
KB	01PHLH	L	0.0	0	4.88	50	2	Rnd	.25"	.625"	Profile

SENSITIVITY CALIBRATION DATA SHEET # InlaySE-Size-Ax

UT SENSITIVITY/TIMEBASE CALIBRATION										
Calibration Block:		NAVSHIP		Calibration Block S/N:		103933		Block Temp:		70° F
Thermometer S/N:		105509		Couplant:		DEMIN		Essential Variable Settings per Appendix A, Figures A1-3 through A1-14:		YES
Wire #	Wire Color	RPR Channel (P/R #)	Probe S/N	Probe Angle (deg)	Buffer Bias	Hole I.D.	Hole Amp %FSH	Gain (dB)	Exam. Gain (dB)	Measured Depth (in)
1	BLK	1	01PWPR	45	55	D	80	22	32	0.98
2	BLK					B	80 +4			0.49
1	BLK	2	01PWPW	45	56	D	80	22	32	0.98
2	BLK					B	80 +2.5			0.49
1	BLK	3	01R154	60	57	A	80	26	36	1.0
2	BLK					B	36			0.51
1	BLK	4	01R155	60	54	A	80	24.5	34.5	1.0
2	BLK					B	33			0.51
1	BLK	5	01PYD0	45	60	B	80	27	27	2.29
2	BLK					F	93			1.49
1	BLK	6	01PYD1	45	60	B	80	27.5	27.5	2.40
2	BLK					F	98			1.50
1	BLK	7	01PW9H	37	63	B	80	25	33	2.48
2	BLK					F	99			1.50
1	BLK	8	01PW9J	37	61	B	80	24.5	32.5	2.48
2	BLK					F	99			1.49
1	BLK	9	01PHLH	0	179	ID	100	6	6	0
2	BLK									

SENSITIVITY CALIBRATION DATA SHEET # InlaySE-Size-Ax

CALIBRATION VERIFICATION									
Reference Block:		ROMPAS		Reference Block S/N:		103939		Block Temp: 70°F	
Thermometer S/N:		105509		Couplant:		Ultragel			
Essential Variable Settings per Appendix A, Figures A1-3 through A1-14, Sensitivity/Timebase Calibration and Para. 6.5.2:									N/A
UT Sessions:		InlaySE-Size-Ax-Calver							
Calibration Verification – Baseline									
Wire #s	Wire Color	RPR Channel (P/R #)	Probe S/N	Reflector ID	Amp. (%FSH)	Gain (dB)	Noise (dB or dB + %FSH)	Depth Position (in)	
1+2	BLK	1	01PWPR	1"Radius	80	4.5	64	0.706	
1+2	BLK	2	01PWPW	1"Radius	80	5.0	63	0.719	
1+2	BLK	3	01R154	1"Radius	80	7.0	70	0.508	
1+2	BLK	4	01R155	1"Radius	80	6.5	68	0.517	
1+2	BLK	5	01PYD0	2"Radius	80	9.0	56	1.41	
1+2	BLK	6	01PYD1	2"Radius	78	8.0	62	1.41	
1+2	BLK	7	01PW9H	2"Radius	78	4.5	49	1.64	
1+2	BLK	8	01PW9J	2"Radius	82	3.5	39	1.64	
Calibration Verification – Transfer									
Wire #s	Wire Color	RPR Channel (P/R #)	Probe S/N	Reflector ID	Amp. (%FSH)	Gain (dB)	Noise (dB or dB + %FSH)	Depth Position (in)	EPP Sled Position
1-2	W	1	01PWPR	1"Radius	81	5.0	62	0.712	A1
3-4	W	2	01PWPW	1"Radius	79	5.0	64	0.720	A2
1-2	Blk	3	01R154	1"Radius	80	6.5	70	0.510	A3
3-4	Blk	4	01R155	1"Radius	81	7.0	66	0.520	A4
5-6	W	5	01PYD0	2"Radius	80	8.5	58	1.42	A5
7-8	W	6	01PYD1	2"Radius	80	8.0	61	1.42	A6
5-6	Blk	7	01PW9H	2"Radius	79	5.0	50	1.66	A7
7-8	Blk	8	01PW9J	2"Radius	81	4.0	40	1.64	A8
Acceptance of Calibration Verification (Y or N):					Y				

SENSITIVITY CALIBRATION DATA SHEET # InlaySE-Size-Ax

SYSTEM CHARACTERIZATION							
Block Type:	SECONDARY STD.		Block S/N:	N/A	Block Temp:	87°F	
Couplant:	DEMIN WATER		Essential Variable Settings per Appendix A, Figures A1-3 through A1-14, Sensitivity/Timebase Calibration and Para. 6.5.2:				YES
UT Session:	AxSysChar						
System Characterization – Initial 05/20/07 1120							
Wire #s	Wire Color	RPR Channel (P/R #)	Probe S/N	Reflector ID	Amp.(% FSH)	Gain (dB)	Depth Position (In)
1-2	White	1	014PMD	SLOT	79	25.5	1.124
5-6	Red	2	014PMF	SLOT	78	28.5	1.124
3-4	White	3	01DJ1D	SLOT	82	5.5	0.834
3-4	Red	4	01DJJK	SLOT	78	12.5	0.853
5-6	White	5	012KWF	SLOT	82	18.5	1.04
7-8	Red	6	012KWC	SLOT	80	17.0	1.04
5-6	Blue	7	00WXDH	SLOT	80	16.0	0.91
1-2	Blue	8	00WXDF	SLOT	78	14.5	0.93
1-2	Red	9	00W97X	SLOT	82	24.5	1.16
3-4	Blue	10	00W97W	SLOT	81	14.0	1.16
System Characterization – Interim*							
Wire #s	Wire Color	RPR Channel (P/R #)	Probe S/N	Reflector ID	Amp.(% FSH)	Gain (dB)	Depth Position (In)
System Characterization – Final 05/21/07 1831							
Wire #s	Wire Color	RPR Channel (P/R #)	Probe S/N	Reflector ID	Amp.(% FSH)	Gain (dB)	Depth Position (In)
1-2	White	1	014PMD	SLOT	79	25.5	1.124
5-6	Red	2	014PMF	SLOT	78	28.5	1.124
3-4	White	3	01DJ1D	SLOT	82	5.5	0.834
3-4	Red	4	01DJJK	SLOT	78	12.5	0.853
5-6	White	5	012KWF	SLOT	82	18.5	1.04
7-8	Red	6	012KWC	SLOT	80	17.0	1.04
5-6	Blue	7	00WXDH	SLOT	80	16.0	0.91
1-2	Blue	8	00WXDF	SLOT	78	14.5	0.93
1-2	Red	9	00W97X	SLOT	82	24.5	1.16

**SENSITIVITY CALIBRATION DATA SHEET # InlaySE-Size-
Ax**

3-4	Blue	10	00W97W	SLOT	81	14.0	1.16
-----	------	----	--------	------	----	------	------

- - adding additional 'Interim' checks to this form is permissible.

ATTACHMENT 2:

Block 601 UT 70° Detection Results



INDICATION ASSESSMENT

PLANT

PDI Supplement 2 10 Demonstration

PROCEDURE

PDI -ISI-254-SE Rev. 2

COMPONENT



601 Detection



ANALYST

 12-5-07


FILE NAME	INDICATION NO.	BEAM ANGLE	BEAM/ DIRECTION In, out, cw, ccw	MIN SWP#	MAX SWP #	TOTAL# SWPS	XB MIN	XB MAX	CENTER LINE= XB MIN + XB MAX / 2	AVERAGE YB (average of two consecutive sweeps) for in out scan = distance from CI of vessel for cw ccw scan = theta	LENGTH PER PROCEDURE(L) (inches) (number of sweeps X increment value)	TOTAL THROUGH WALL BOTTOM TIP ZB (corrected from profilometry view)
AxDet-601-2	1	70	IN/OUT	2	9	8	357.90°	4.84°	1.37°	18.80"	2.00"	detection only
AxDet-601-2	2	70	IN/OUT	346	357	12	338.90°	349.80°	344.35°	17.55"	3.00"	detection only
CIRCDet601	3	70	CW/CCW	53	61	9	18.41"	19.05°	18.73"	322.00°	0.72"	detection only
AxDet-601-2	12	70	IN/OUT	18	30	13	13.76°	25.65°	19.71°	18.50"	3.25"	detection only

NOTES






Chan 1 - Tops - Dual 20mm FS : CIRCD601-2A



Z= 0.209, A= 4%, Y=321.236

xb 18.81 yb 307.38° zb -0.07 Amp 6.3 Sweep 58 Ascan 1027 MPL 27


Chan 2 - Tops - Dual 20mm FS : CIRCD601-2A





Z= 0.158, A= 15%, Y=322.095

xb 18.81 yb 334.39° zb 0.43 Amp 7.1 Sweep 58 Ascan 1122 MPL 76

Chan 2 - C-Scan - Dual 20mm FS - Gate 1 : CIR...



xb 19.77 yb 308.91° zb 0.44 Amp 10.6 Sweep 70 Ascan 1036 MPL 7



ATTACHMENT 3:

Block 601 UT Sizing Results



INDICATION ASSESSMENT

PLANT

PDI Supplement 2 10 Demonstration


PROCEDURE

PDI -ISI-254-SE Rev. 2

COMPONENT




601 Sizing




ANALYST

 12-5-07


FILE NAME	INDICATION NO.	BEAM ANGLE	BEAM/ DIRECTION in, out, cw, ccw	MIN SWP#	MAX SWP #	TOTAL# SWPS	XB MIN	XB MAX	CENTER LINE= XB MIN + XB MAX / 2	AVERAGE YB (average of two consecutive sweeps) for in out scan = distance from cl of vessel for cw ccw scan = theta	LENGTH PER PROCEDURE(L) (inches) (number of sweeps X increment value)	TOTAL THROUGH WALL BOTTOM TIP ZB (corrected from profilometry view)
axsize601-pro	1	45	IN/OUT	715	3	15	356.98°	4.08°	0.53°	18.70"	1.875"	0.37"
axsize601-pro	2	45	IN/OUT	676	697	22	337.65°	348.06°	342.86°	17.35"	2.75"	0.39"
circsize6012	3	45	CW/CCW	96	100	5	18.60"	18.92"	18.76"	322.70°	0.40"	0.44"
axsize601-pro	12	45	IN/OUT	18	43	26	11.52°	23.91°	17.71°	18.20"	3.25"	0.79"

NOTES







Chan 1 - Tops - Dual 30mm FS : circsize6012






Chan 2 - Tops - Dual 30mm FS : circsize6012



Chan 1 - A-Scan - Dual 30mm FS : circsize6012





ATTACHMENT 4:

Inlay Block UT 70° Detection Results







PDI Supplement 2 10 Demonstration

PDI -ISI-254-SE Rev. 2

Inlay Test Mockup

[Signature] 12-5-67

[illegible]



Chan 1 - Tops - 70L IN-D1-01PW71 :

Z= 0.341, A= 100%, Y=26.513

DETECTION 70°
EPRI INLAY BLOCK
IND# 2-Q2
LENGTH= 2.75"

xb 120.65° yb 26.54 zb 0.32 Amp 100.0 Sweep 119 Ascan 63 MPL 69


Chan 2 - Tops - 70L OUT-D2-01PW72 :

Z= 0.199, A= 50%, Y=26.378

DETECTION 70°
EPRI INLAY BLOCK
IND# 2-Q2
LENGTH= 2.75"


xb 120.85° yb 26.54 zb 0.33 Amp 40.0 Sweep 113 Ascan 87 MPL 68

Chan 1 - C-Scan - 70L IN-D1-01PW71 - Gate 1 :




xb 120.65° yb 26.56 zb 0.33 Amp 95.3 Sweep 119 Ascan 63 MPL 70

Chan 2 - C-Scan - 70L OUT-D2-01PW72 - Gate 1 :




xb 120.85° yb 26.54 zb 0.33 Amp 40.0 Sweep 113 Ascan 87 MPL 68

Chan 1 - Tops - 70L CCW-D3-01PW73 : Inlay-Det C...




xb 27.28 yb 97.22° zb -0.17 Amp 23.5 Sweep 32 Ascan 295 MPL 16

Chan 2 - Tops - 70L CW-D4-01PW74 : Inlay-D...




xb 27.28 yb 90.24° zb 0.20 Amp 3.5 Sweep 32 Ascan 307 MPL

Chan 2 - C-Scan - 70L CW-D4-01PW74 - Gate 1 : Inlay-Det Circ2




xb 25.04 yb 114.61° zb 0.26 Amp 11.0 Sweep 4 Ascan 387 MPL 61

Chan 1 - C-Scan - 70L CCW-D3-01PW73 - Gate 1 : Inlay-Det Circ2




xb 25.20 yb 118.21° zb 0.20 Amp 10.6 Sweep 6 Ascan 362 MPL 55

Chan 1 - Tops - 70L IN-D1-01PW71 :




xb 156.35° yb 25.92 zb 0.40 Amp 8.2 Sweep 153 Ascan 52 MPL 77

Chan 2 - Tops - 70L OUT-D2-01PW72 :




xb 156.55° yb 26.00 zb 0.47 Amp 5.1 Sweep 147 Ascan 85 MPL 83

Chan 1 - C-Scan - 70L IN-D1-01PW71 - Gate 1 :




xb 138.50° yb 24.27 zb 0.18 Amp 9.0 Sweep 136 Ascan 38 MPL 54

Chan 2 - C-Scan - 70L OUT-D2-01PW72 - Gate 1 :




xb 306.70° yb 24.35 zb 0.23 Amp 11.4 Sweep 290 Ascan 54 MPL 57

Chan 1 - Tops - 70L IN-D1-01PW71 :




xb 228.80° yb 25.26 zb 0.08 Amp 1.6 Sweep 222 Ascan 55 MPL 43

Chan 2 - Tops - 70L OUT-D2-01PW72 :




xb 229.00° yb 29.96 zb -0.12 Amp 14.5 Sweep 216 Ascan 116 MPL 20

Chan 1 - C-Scan - 70L IN-D1-01PW71 - Gate 1 :







xb 356.75° yb 27.07 zb 0.22 Amp 22.7 Sweep 1 Ascan 74 MPL 58


Chan 2 - C-Scan - 70L OUT-D2-01PW72 - Gate 1 :



xb 325.60° yb 24.04 zb 0.34 Amp 10.2 Sweep 308 Ascan 54 MPL 69




Chan 1 - Tops - 70L CCW-D3-01PW73 : Inlay-Det C...



xb 27.36 yb 213.81° zb 0.53 Amp 3.9 Sweep 33 Ascan 658 MPL 85

Chan 2 - Tops - 70L CW-D4-01PW74 : Inlay-D...




xb 27.36 yb 209.16° zb -0.16 Amp 37.3 Sweep 33 Ascan 687 MPL

Chan 2 - C-Scan - 70L CW-D4-01PW74 - Gate 1 : Inlay-Det Circ2



xb 24.96 yb 155.77° zb 0.21 Amp 11.8 Sweep 3 Ascan 517 MPL 56

Chan 1 - C-Scan - 70L CCW-D3-01PW73 - Gate 1 : Inlay-Det Circ2



xb 27.36 yb 194.05° zb 0.19 Amp 12.5 Sweep 33 Ascan 605 MPL 54

Chan 1 - Tops - 70L IN-D1-01PW71 :

Z= 0.180, A= 11%, Y=27.270

DETECTION 70°
EPRI INLAY BLOCK
IND # 12-Q3
LENGTH= 3.00"

xb 244.55° yb 26.95 zb 0.64 Amp 2.4 Sweep 237 Ascan 57 MPL 102


Chan 2 - Tops - 70L OUT-D2-01PW72 :

Z= 0.247, A= 100%, Y=27.373

DETECTION 70°
EPRI INLAY BLOCK
IND # 12-Q3
LENGTH= 3.00"


xb 244.75° yb 26.26 zb 0.63 Amp 3.1 Sweep 231 Ascan 94 MPL 99

Chan 1 - C-Scan - 70L IN-D1-01PW71 - Gate 1 :




xb 267.65° yb 24.50 zb 0.24 Amp 11.4 Sweep 259 Ascan 39 MPL 60

Chan 2 - C-Scan - 70L OUT-D2-01PW72 - Gate 1 :




xb 311.95° yb 24.51 zb 0.17 Amp 7.5 Sweep 295 Ascan 54 MPL 51

Chan 1 - Tops - 70L IN-D1-01PW71 :




xb 327.50° yb 31.98 zb 0.97 Amp 3.5 Sweep 316 Ascan 112 MPL 137

Chan 2 - Tops - 70L OUT-D2-01PW72 :




xb 327.70° yb 29.34 zb -0.14 Amp 35.7 Sweep 310 Ascan 107 MPL 18

Chan 1 - C-Scan - 70L IN-D1-01PW71 - Gate 1 :




xb 3.050° yb 25.65 zb 0.25 Amp 12.2 Sweep 7 Ascan 54 MPL 61

Chan 2 - C-Scan - 70L OUT-D2-01PW72 - Gate 1 :




xb 326.65° yb 24.40 zb 0.21 Amp 7.5 Sweep 309 Ascan 54 MPL 55

Chan 1 - Tops - 70L IN-D1-01PW71 :




xb 310.70° yb 27.74 zb -0.09 Amp 2.0 Sweep 300 Ascan 94 MPL 26

Chan 2 - Tops - 70L OUT-D2-01PW72 :




xb 310.90° yb 26.56 zb -0.09 Amp 6.3 Sweep 294 Ascan 72 MPL 24

Chan 1 - C-Scan - 70L IN-D1-01PW71 - Gate 1 :




xb 147.95° yb 24.77 zb 0.39 Amp 10.6 Sweep 145 Ascan 37 MPL 76

Chan 2 - C-Scan - 70L OUT-D2-01PW72 - Gate 1 :




xb 334.00° yb 24.24 zb 0.29 Amp 9.0 Sweep 316 Ascan 55 MPL 64

Chan 1 - Tops - 70L CCW-D3-01PW73 : Inlay-Det C...



xb 27.20 yb 291.26° zb -0.12 Amp 6.3 Sweep 31 Ascan 918 MPL 22

Chan 2 - Tops - 70L CW-D4-01PW74 : Inlay-D...




xb 27.20 yb 306.22° zb 0.08 Amp 5.5 Sweep 31 Ascan 994 MPL

Chan 2 - C-Scan - 70L CW-D4-01PW74 - Gate 1 : Inlay-Det Circ2




xb 24.96 yb 191.81° zb 0.23 Amp 11.0 Sweep 3 Ascan 633 MPL 58

Chan 1 - C-Scan - 70L CCW-D3-01PW73 - Gate 1 : Inlay-Det Circ2




xb 27.20 yb 293.43° zb 0.16 Amp 43.1 Sweep 31 Ascan 924 MPL 51

Chan 1 - Tops - 70L IN-D1-01PW71 :




xb 339.05° yb 26.37 zb 0.40 Amp 10.6 Sweep 327 Ascan 58 MPL 77

Chan 2 - Tops - 70L OUT-D2-01PW72 :




xb 339.25° yb 30.32 zb -0.14 Amp 35.7 Sweep 321 Ascan 120 MPL 18

Chan 1 - C-Scan - 70L IN-D1-01PW71 - Gate 1 :



xb 339.05° yb 27.59 zb 0.16 Amp 37.3 Sweep 327 Ascan 83 MPL 52

Chan 2 - C-Scan - 70L OUT-D2-01PW72 - Gate 1 :



xb 311.95° yb 25.71 zb 0.17 Amp 9.4 Sweep 295 Ascan 70 MPL 51