

PMSTPCOL PEmails

From: Tai, Tom
Sent: Friday, May 15, 2009 10:26 AM
To: Agles, James
Cc: STPCOL
Subject: Draft RAI for Chapter 9.3.11
Attachments: RAI 2780 9.3.11.doc

James,

Please review attached draft RAI 2780 for Chapter 9.3.11 of the COL. If you need a conference call to clarify the requested information, please contact me. If a conference call is not needed, please send me an email and I will continue the formal process of issuing the RAI to STPNO.

Regards

Tom Tai
DNRL/NRO
(301) 415-8484
Tom.Tai@NRC.GOV

Hearing Identifier: SouthTexas34Public_EX
Email Number: 1232

Mail Envelope Properties (C56E360E9D804F4B95BC673F886381E71F409ABF79)

Subject: Draft RAI for Chapter 9.3.11
Sent Date: 5/15/2009 10:26:02 AM
Received Date: 5/15/2009 10:26:04 AM
From: Tai, Tom

Created By: Tom.Tai@nrc.gov

Recipients:

"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"Agles, James" <jaagles@STPEGS.COM>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE RAI 2780 9.3.11.doc	390 28666	5/15/2009 10:26:04 AM

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 2780 Revision 2

South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013
SRP Section: 01 - Introduction and Interfaces
Application Section: 9.3.11

QUESTIONS for Component Integrity, Performance, and Testing Branch 2 (ESBWR/ABWR Projects)
(CIB2)

01-***

In ABWR DCD, Provisions are made to permit the installation of a system for adding a zinc solution to the feedwater. In the South Texas COL FSAR section 9.3, the applicant incorporated by reference section 9.3 of the ABWR DCD. But it is not clear whether or not the Zinc Injection System will be utilized. Therefore the staff requests a clarification from the applicant to confirm whether or not the Zinc Injection System will be utilized.