

PMSTPCOL PEmails

From: Tai, Tom
Sent: Tuesday, May 19, 2009 1:20 PM
To: Agles, James
Cc: STPCOL
Subject: Draft RAI 2671 for Chapter 9.5.3
Attachments: RAI 2671 09.05.03-xx.doc

James,

Please review the attached RAI (09.01.02-xx). If you need a conference call to clarify the requested information, please contact me. If a conference call is not needed, please send me an email and I will continue the formal process of issuing the RAI to STPNOC.

Regards

Tom Tai
DNRL/NRO
(301) 415-8484
Tom.Tai@NRC.GOV

Hearing Identifier: SouthTexas34Public_EX
Email Number: 1237

Mail Envelope Properties (C56E360E9D804F4B95BC673F886381E71F40A1425C)

Subject: Draft RAI 2671 for Chapter 9.5.3
Sent Date: 5/19/2009 1:20:19 PM
Received Date: 5/19/2009 1:20:21 PM
From: Tai, Tom

Created By: Tom.Tai@nrc.gov

Recipients:
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"Agles, James" <jaagles@STPEGS.COM>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	367	5/19/2009 1:20:21 PM
RAI 2671 09.05.03-xx.doc		30202

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 2671 Revision 2

South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013
SRP Section: 09.05.03 - Lighting Systems
Application Section: SRP 9.5.3

QUESTIONS for Electrical Engineering Branch (EEB)

09.05.03-***

In FSAR Subsection 9.5.3.1.1, "General Design Bases," the Subsections numbering was modified with respect to the DCD. For instance, Subsections (4)(-5) and (5)(-3)(-2) correspond to DCD Subsections (4)(I) and (5)(a)(ii), respectively. Similarly, in the same Subsection, site-specific supplements were given Subsection numbers (-4), (-1), and (0). Clarify these discrepancies.