



May 29, 2009
NRC:09:064

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Submittal of Revision 1 of the U.S. EPR Final Safety Analysis Report for Design Certification

Ref. 1: Letter, Sandra M. Sloan (AREVA NP Inc.) to Document Control Desk (NRC), "Application for Standard Design Certification of the U.S. EPR (Project No. 733), NRC:07:070, December 11, 2007.

AREVA NP Inc. (AREVA NP) hereby submits Revision 1 of the U.S. EPR Final Safety Analysis Report (FSAR). Revision 0 of the U.S. EPR FSAR was submitted to the NRC as part of the application for Standard Design Certification of the U.S. EPR in Reference 1. Revision 1 of the U.S. EPR FSAR includes changes associated with responses to NRC Requests for Additional Information (RAIs) submitted through late April, although the timing for inclusion of RAI-associated changes varies somewhat by chapter and RAI response submittal date.

The following items are enclosed on separate DVDs:

1. U.S. EPR Final Safety Analysis Report including Sensitive Unclassified Non-Safeguards Information (SUNSI), to be withheld under 10 CFR 2.390.
2. U.S. EPR Final Safety Analysis Report in which the SUNSI material is redacted, termed the "Public Version."

A list of changes to the U.S. EPR FSAR is also enclosed separately. The list of changes identifies the location of changes by FSAR section and provides a brief description of the nature of each change. Changes in the FSAR text are identified by change bars. Minor editorial changes such as those related to punctuation and capitalization are generally not marked.

In addition to the changes associated with RAI responses, Revision 1 of the U.S. EPR FSAR includes editorial changes such as typographical changes and changes for internal consistency. These changes are minor and are not expected to impact the technical assessments performed to date by the NRC reviewers.

AREVA NP looks forward to continued constructive interactions with the NRC to support efficient conduct of the design certification review.

AREVA NP INC.
An AREVA and Siemens company


3315 Old Forest Road, P.O. Box 10935, Lynchburg, VA 24506-0935
Tel.: (434) 832-3000 Fax: (434) 832-3840

FORM 22709VA-1 (4/1/2008)

DO77
NRO

If you have any questions related to this submittal, please contact me at 434-832-2369
or by e-mail at sandra.sloan@areva.com

Sincerely,



Sandra M. Sloan, Manager
New Plants Regulatory Affairs
AREVA NP Inc.

Enclosures

cc: G. Tesfaye
Docket No. 52-020

Item	Chapter	Subsection	Type of Change
1	1	1.1	Correction - minor / Eliminate last sentence regarding corrective action in As-built Deviation definition.
2	1	1.1	Correction - minor / Add the word "train" to Tier 1 definition of "Division (for mechanical systems or components)"
3	1	1.2	Editorial / Clarification of valve position indications on figures - following sentence added: " Valve position indications shown on these figures do not represent a specific operational state."
4	1	1.2	Editorial / Clarification of continuation labels on figures - paragraph added based on NRC questions during draft RAI phone call and subsequent conference call on 06/09/2008
5	1	1.2	RAI / Changes associated with RAI Batch #105, Response to Question 11.03-1
6	1	1.3	Editorial / Update Acronym List - Tier 1
7	1	1.3	Editorial / Update of acronym list
8	1	1.3	Editorial / Update Acronym list - Add Accident Monitoring Instrumentation (AMI) and Post-Accident Monitoring (PAM)
9	1	1.3	Editorial / Update of acronym list (Change ESF from "Emergency" to "Engineered" safety features to match Tier 2)
10	1	1.3 Figure 1.03-01	Editorial / Figure update (symbol legend)
11	1	1.3 Figure 1.03-01	RAI / Changes associated with RAI Batch #12 - revise symbol legend to include gate valves - RAI Response 06.02.04-07 (Part 6)
12	1	1.3	RAI / Changes associated with RAI Batch #135, Supp 1, Response to Question 09.04.05-1.13
13	2	2.1	RAI / Changes associated with RAI Batch #132, Supp 1, Response to Question 14.03.02-11
14	2	2.1.1 Fig. 2.1.1-1	Editorial / Define correct acronyms to match Table 1.3-1 (MFWSVS and MSVS) and in Figure 2.1.1-1
15	2	2.1.1	RAI / Changes associated with RAI Batch #20 - include separation of FB from other NI structures in commitment wording and update ITAAC table - RAI Response 09.05.01-31
16	2	2.1	RAI / Changes associated with RAI Batch #43, Supp 2, Response to Question 14.03.08-1
17	2	2.1	RAI / Changes associated with RAI Batch #109, Supp 1, Response to Questions 03.05.01.01-1 and 03.05.01.02-1
18	2	2.1.1	Correction - minor / Add missing ITAAC that was inadvertently omitted in Rev. 0 for Section 2.1.1, Item #4.1
19	2	2.1	RAI / Changes associated with RAI Batch #80, Response to Questions 03.06.01-2, 03.06.01-9 and 03.06.01-10
20	2	2.1	RAI / Changes associated with RAI Batch #81, Supp 1 Response to Question 06.01.01-11
21	2	2.1	RAI / Changes associated with RAI Batch #140, Supp 1, Response to Question 14.03-4
22	2	2.1	RAI / Changes associated with RAI Batch #115, Supp 1 Response to Questions 14.03.02-1 thru 8
23	2	2.1	RAI / Changes associated with RAI Batch #118, Supp 1 Response to Question 03.04.01-7
24	2	2.1	RAI / Changes associated with RAI Batch #20, Supp 2 Response to Question 09.05.01-8
25	2	2.1.1 Figure 2.1.1-1	Editorial / Figure clarification
26	2	2.1.1 Figures 2.1.1-7 thru 2.2.1-10	Correction - moderate / Update figures based on change in T2 Section 2.4 in Supplement #2 letter on 2/20/08 to change definition of finished yard grade to 1 foot below ground floor top of concrete.
27	2	2.1.5	Editorial / Clarify and ensure consistency with use of acronyms for ESWB and associated structures for cooling tower and pumps
28	2	2.2.1	RAI / Changes associated with RAI Batch #156, Supp 1, Response to Questions 14.03.03-27 and 14.03.03-28

Item	Chapter	Subsection	Type of Change
29	2	2.2.1	Editorial / Change definition for PACS acronym - Priority and Actuator Control System
30	2	2.2.1	Editorial / Under PACS column, add 'Yes' to blank entries
31	2	2.2.1 Figure 2.2.1-1 (Sheet 1 of 6)	Editorial / Figure correction of continuation labels - should specify continuation on sh2 rather than sh3
32	2	2.2.1 Figure 2.2.1-1 (Sheet 2 of 6)	Editorial / Figure clarification
33	2	2.2	RAI / Changes associated with RAI Batch #151, Supp 1, Response to Question 09.05.01-60
34	2	2.2	RAI / Changes associated with RAI Batch #124, Supp 1, Response to Question 14.03.04-1
35	2	2.2	RAI / Changes associated with RAI Batch #149, Response to Questions 03.09.05-1, 03.09.05-2, 03.09.05-3 and 03.09.05-4
36	2	2.2	RAI / Changes associated with RAI Batch #128, Response to Questions 14.03.03-12, 14.03.03-13, 14.03.03-18, 14.03.04-3, 14.03.04-7, 14.03.06-28, 14.03-07-3
37	2	2.2	RAI / Changes associated with RAI Batch #148, Response to Question 14.03.03-23
38	2	2.2	RAI / Changes associated with RAI Batch #116, Response to Question 14.03.06-11
39	2	2.2	RAI / Changes associated with RAI Batch #123, Response to Questions 14.03.03-4, 14.03.03-7, 14.03.03-8, 14.03.03-9
40	2	2.2	RAI / Changes associated with RAI Batch #123, Supp 1, Response to Question 14.03.03-1
41	2	2.2	RAI / Changes associated with RAI Batch #156, Response to Question 14.03.03-26
42	2	2.2.2	RAI / Changes associated with RAI Batch #156, Supp 1, Response to Questions 14.03.03-27 and 14.03.03-28
43	2	2.2	RAI / Changes associated with RAI Batch #140, Response to Questions 14.03-8, 14.03-9
44	2	2.2	RAI / Changes associated with RAI Batch #104, Supp 1, Response to Questions 14.03-1b, 14.03.11-1, 1c
45	2	2.2.3	RAI / Changes associated with RAI Batch #156, Supp 1, Response to Questions 14.03.03-27 and 14.03.03-28
46	2	2.2	RAI / Changes associated with RAI Batch #128, Supp 2, Response to Question 14.03.03-11
47	2	2.2	RAI / Changes associated with RAI Batch #128, Supp 1, Response to Questions 14.03.03-14, 14.03.03-15, 14.03.03-16, 14.03.03-17
48	2	2.2.4	RAI / Changes associated with RAI Batch #156, Supp 1, Response to Questions 14.03.03-27 and 14.03.03-28
49	2	2.2	RAI / Changes associated with RAI Batch #83, Supp 1 Response to Question 10.04.09-1
50	2	2.2	RAI / Changes associated with RAI Batch #83, Supp 4 Response to Question 10.04.09-5
51	2	2.2.2	Editorial / Change definition for PACS acronym - Priority and Actuator Control System
52	2	2.2.3	Editorial / Change definition for PACS acronym - Priority and Actuator Control System
53	2	2.2.4	Editorial / Change definition for PACS acronym - Priority and Actuator Control System
54	2	2.2.5	RAI / Changes associated with RAI Batch #156, Supp 1, Response to Questions 14.03.03-27 and 14.03.03-28
55	2	2.2.5	Editorial / Change definition for PACS acronym - Priority and Actuator Control System
56	2	2.2.6	RAI / Changes associated with RAI Batch #156, Supp 1, Response to Questions 14.03.03-27 and 14.03.03-28

Item	Chapter	Subsection	Type of Change
57	2	2.2.6	Editorial / Change definition for PACS acronym - Priority and Actuator Control System
58	2	2.2.6	Correction - minor / Wording for ITAAC - change from "analysis" to "test"
59	2	2.2.7	RAI / Changes associated with RAI Batch #156, Supp 1, Response to Questions 14.03.03-27 and 14.03.03-28
60	2	2.2.7	Editorial / Change definition for PACS acronym - Priority and Actuator Control System
61	2	2.2.8	Correction - minor / Clarify commitment wording for Fuel Handling System for equipment designated as Seismic Category II to state that they can maintain their structural integrity (delete "under loads") during a design basis seismic event
62	2	2.2.8	RAI / Changes associated with RAI Batch #201, Response to Question 03.02.01-10
63	2	2.3	RAI / Changes associated with RAI Batch #69, Supp 1, Response to Question 06.02.05-5
64	2	2.3	RAI / Changes associated with RAI Batch #69, Response to Question 06.02.05-06
65	2	2.3	RAI / Changes associated with RAI Batch #128, Response to Questions 14.03.04-2, 14.03.04-3, 14.03.04-4, 14.03.07-3
66	2	2.3	RAI / Changes associated with RAI Batch #148, Response to Question 14.03.03-23
67	2	2.3	RAI / Changes associated with RAI Batch #149, Response to Question 03.09.05-1
68	2	2.3.3	RAI / Changes associated with RAI Batch #156, Supp 1, Response to Questions 14.03.03-27 and 14.03.03-28
69	2	2.3	RAI / Changes associated with RAI Batch #156, Response to Question 14.03.03-26
70	2	2.3.3	Editorial / Change definition for PACS acronym - Priority and Actuator Control System
71	2	2.3.3 Figure 2.3.3-1	RAI / Changes associated with RAI Batch #12 - revise SAHRS figure - RAI Response 06.02.04-07 (Parts 7 and 8)
72	2	2.3	RAI / Changes associated with RAI Batch #104, Supp 1, Response to Question 14.03.11-1, 1c
73	2	2.4	RAI / Changes associated with RAI Batch #128 Response to Questions 14.03.03-18, 14.03.06-27, 14.03.06-29
74	2	2.4	RAI / Changes associated with RAI Batch #123, Supp 2, Response to Questions 14.03.05-9, 14.03.05-10, 14.03.05-11, 14.03.05-12, 14.03.05-14, 14.03.05-15, 14.03.05-16, 14.03.05-17, 14.03.05-24
75	2	2.4	Correction - moderate / Address inconsistency between Tier 1, Section 2.4.1 and Tier 2 Section 7.1 on the topic of Remote Shutdown System (RSS) protective system manual controls - delete reference to existence of RSS controls to allow manual actuation of the manually actuated functions identified in Table 2.4.1-5 - see also WebCAP 2008-4007
76	2	2.4	RAI / Changes associated with RAI Batch #60 Response to Question 07.03-3
77	2	2.4	RAI / Changes associated with RAI Batch #60 Response to Question 07.03-5
78	2	2.4	RAI / Changes associated with RAI Batch #116, Response to Question 14.03.06-5
79	2	2.4	RAI / Changes associated with RAI Batch #128, Supp 1, Response to Question 14.03.6-18
80	2	2.4	RAI / Changes associated with RAI Batch #78 Response to Question 14.03.05-6
81	2	2.4	RAI / Changes associated with RAI Batch #123 Response to Questions 14.03.05-19, 14.03.05-20, 14.03.05-21, 14.03.05-22, 14.03.05-23
82	2	2.4	RAI / Changes associated with RAI Batch #59 Response to Question 07.01-2
83	2	2.4.2	RAI / Changes associated with RAI Batch #20 - include commitment wording that "electrical isolation is provided between the RSS and the MCR for the SICS" and update ITAAC table - RAI Response 09.05.01-26

Item	Chapter	Subsection	Type of Change
84	2	2.4.6	RAI / Changes associated with RAI Batch #20 - include commitment wording that "the as-built plant fire alarm system is consistent with the post-fire safe shutdown analyses" and update ITAAC table - RAI Response 09.05.01-27
85	2	2.4.10	RAI / Changes associated with RAI Batch #20 - include commitment wording that "electrical isolation is provided between the RSS and the MCR for the PICS" and update ITAAC table - RAI Response 09.05.01-26
86	2	2.4	Editorial
87	2	2.4	RAI / Changes associated with RAI Batch #115, Response to Question 14.03.05-7
88	2	2.4	RAI / Changes associated with RAI Batch #104, Supp 1, Response to Question 14.03.-1b
89	2	2.4	RAI / Changes associated with RAI Batch #43, Supp 1, Response to Question 14.03.08-1 (1a and 1e)
90	2	2.4	RAI / Changes associated with RAI Batch #43, Supp 1, Response to Question 14.03.08-1 (1a)
91	2	2.5	RAI / Changes associated with RAI Batch #128, Supp 1, Response to Question 10.03.06-18
92	2	2.5	RAI / Changes associated with RAI Batch #118, Supp 1, Response to Question 03.04.01-7
93	2	2.5	RAI / Changes associated with RAI Batch #116, Response to Questions 14.03.06-3, 14.03.06-5, 14.03.06-6, 14.03.06-7, 14.03.06-8, 14.03.06-9, 14.03.06-10, 14.03.06-11
94	2	2.5	RAI / Changes associated with RAI Batch #138, Response to Questions 14.03.06-16, 14.03.06-20, 14.03.06-21, 14.03.06-22, 14.03.06-24, 14.03.06-26, 14.03.06-27
95	2	2.5	RAI / Changes associated with RAI Batch #148, Response to Question 14.03.03-23
96	2	2.5	RAI / Changes associated with RAI Batch #70, Supp 1, Response to Question 08.03.01-17
97	2	2.5	RAI / Changes associated with RAI Batch #145, Response to Question 09.05.08-8
98	2	2.5	RAI / Changes associated with RAI Batch #87, Supp 2, Response to Question 09.05.07-5
99	2	2.5.4	RAI / Changes associated with RAI Batch #156, Supp 1, Response to Questions 14.03.03-27 and 14.03.03-28
100	2	2.5	RAI / Changes associated with RAI Batch #156, Response to Question 14.03.03-26
101	2	2.5	RAI / Changes associated with RAI Batch #110, Supp 1, Response to Question 16-237
102	2	2.5.1	Editorial
103	2	2.5.2	Editorial
104	2	2.5.2	Editorial / Remove pointer to other ITAAC within ITAAC Table 2.5.2-3
105	2	2.5.3	Editorial
106	2	2.5.4	Editorial
107	2	2.5.5	Editorial
108	2	2.5.6	Editorial
109	2	2.5.7	Editorial
110	2	2.5.8	Editorial
111	2	2.5.8 Table 2.5.8-1	Editorial / Change Column Title in ITAAC table to Commitment Wording
112	2	2.5.9	RAI / Changes to FSAR as specified in RAI Batch 19 - Response #9.5.3-11, 9.5.3-13, 9.5.3-14 & 9.5.3-15
113	2	2.5.9 - 2.5.10	Editorial
114	2	2.5.11	Editorial
115	2	2.5	RAI / Changes associated with RAI Batch #131, Supp 2, Response to Question 09.05.06-7

Item	Chapter	Subsection	Type of Change
116	3	2.5	RAI / Changes associated with RAI Batch #152, Supp 1, Response to Question 09.05.04-15
117	3	2.5	RAI / Changes associated with RAI Batch #159, Supp 1, Response to Question 09.05.05-6
118	2	2.6	RAI / Changes associated with RAI Batch #135, Supp 1, Response to Questions 09.04.05-1.1, 09.04.05-1.4, 09.04.05-1.5, 09.04.05-1.13
119	2	2.6	RAI / Changes associated with RAI Batch #148, Response to Question 14.03.03-23
120	2	2.6	RAI / Changes associated with RAI Batch #128, Response to Questions 14.03.04-3, 14.03.07-2, 14.03.07-3, 14.03.07-4, 14.03.07-5, 14.03.07-6, 14.03.07-9, 14.03.07-15, 14.03.07-16
121	2	2.6	RAI / Changes associated with RAI Batch #11, Supp 2, Response to Question 08.03.01-2
122	2	2.6	RAI / Changes associated with RAI Batch #128, Supp 1, Response to Questions 14.03.07-8, 14.03.07-10, 14.03.07-11, 14.03.07-12, 14.03.07-13, 14.03.07-14, 14.03.07-17
123	2	2.6	RAI / Changes associated with RAI Batch #156, Response to Question 14.03.03-26
124	2	2.6	RAI / Changes associated with RAI Batch #104, Supp 1 Response to Question 14.03.-1b
125	2	2.6.1, 2.6.6, 2.6.7, 2.6.8, 2.6.9	Correction - minor / Update IEEE Class 1E source for selected components in Tables 2.6.1-2, 2.6.6-2, 2.6.7-2, 2.6.8-3, and 2.6.9-2; add commitment wording (PACS modules and alternate feed) for KLA (Section 2.6.8)
126	2	2.7	RAI / Changes associated with RAI Batch #128, Response to Questions 14.03.03-12, 14.03.03-18, 14.03.04-3, 14.03.07-3, 14.03.07-18, 14.03.07-22, 14.03.07-23, 14.03.07-24
127	2	2.7	RAI / Changes associated with RAI Batch #128, Supp 1, Response to Questions 14.03.07-20, 14.03.07-21, 14.03.07-25
128	2	2.7	RAI / Changes associated with RAI Batch #148, Response to Questions 14.03.03-19, 14.03.03-21, 14.03.03-22, 14.03.03-23 and 14.03.03-24
129	2	2.7.1	RAI / Changes associated with RAI Batch #156, Supp 1, Response to Questions 14.03.03-27 and 14.03.03-28
130	2	2.7	RAI / Changes associated with RAI Batch #156, Response to Question 14.03.03-26
131	2	2.7	RAI / Changes associated with RAI Batch #174, Supp 2, Response to Questions 09.02.02-18, 09.02.02-21, 09.02.02-30, 09.02.02-34
132	2	2.7	RAI / Changes associated with RAI Batch #149, Response to Question 03.09.05-1
133	2	2.7	RAI / Changes associated with RAI Batch #174, Response to Questions 09.02.02-10(b), 09.02.02-10(c) and 09.02.02-33
134	2	2.7	RAI / Changes associated with RAI Batch #104, Supp 1, Response to Question 14.03-1b
135	2	2.7.1	Editorial / Change definition for PACS acronym - Priority and Actuator Control System
136	2	2.7.2	RAI / Changes associated with RAI Batch #156, Supp 1, Response to Questions 14.03.03-27 and 14.03.03-28
137	2	2.7.2	Editorial / Change definition for PACS acronym - Priority and Actuator Control System
138	2	2.7.5	Editorial / Change definition for PACS acronym - Priority and Actuator Control System
139	2	2.7.5	RAI / Changes associated with RAI Batch #20 - Add commitment wording (Item 4.4) to state that "the as-built fire water distribution system is consistent with the post-fire safe shutdown analysis"; also revise/clarify commitment wording for 7.7 for standby and hose systems functionality following an SSE, and update ITAAC table - RAI Responses 09.05.01-25 and 09.05.01-27
140	2	2.7.5	Editorial / Remove pointer to other ITAAC within ITAAC Table 2.7.5-3

Item	Chapter	Subsection	Type of Change
141	2	2.7.6	RAI / Changes associated with RAI Batch #20 - include commitment wording that "the as-built gaseous fire extinguishing system is consistent with the post-fire safe shutdown analyses" and update ITAAC table - RAI Response 09.05.01-27
142	2	2.7.11	RAI / Changes associated with RAI Batch #156, Supp 1, Response to Questions 14.03.03-27 and 14.03.03-28
143	2	2.7.11	Editorial / Change definition for PACS acronym - Priority and Actuator Control System
144	2	2.7.11	RAI / Changes associated with RAI Batch #119, Supp 2, Response to Questions 09.02.01-1, 09.02.01-4 (Part i), 09.02.01-8, 09.02.01-17, 09.02.01-21, 09.02.01-22, & 09.02.01-23
145	2	2.8	RAI / Changes associated with RAI Batch #100, Response to Questions 10.02.03-10, 10.02.03-11
146	2	2.8	RAI / Changes associated with RAI Batch #149, Response to Question 03.09.05-1
147	2	2.8	RAI / Changes associated with RAI Batch #128, Response to Questions 14.03.03-18, 14.03.04-3, 14.03-07-3
148	2	2.8	RAI / Changes associated with RAI Batch #148, Response to Questions 14.03.03-23, 14.03.07-26, 14.03.07-27, 14.03.07-28, 14.03.07-29, 14.03.07-30, 14.03.07-32
149	2	2.8.2	RAI / Changes associated with RAI Batch #156, Supp 1, Response to Questions 14.03.03-27 and 14.03.03-28
150	2	2.8	RAI / Changes associated with RAI Batch #106, Response to Question 10.3-1 (Part III)
151	2	2.8	RAI / Changes associated with RAI Batch #156, Response to Question 14.03.03-26
152	2	2.8	RAI / Changes associated with RAI Batch #78 Response to Question 14.03.05-6
153	2	2.8.2	Editorial / Change definition for PACS acronym - Priority and Actuator Control System
154	2	2.8.2	Editorial / Delete duplicate ITAAC entries (SG steam outlet flow restrictor throat area of 1.39 sq ft.) - covered in 2.2.1 (#3.5).
155	2	2.8.6	Editorial / Change figure references in 3.5 and 3.8 to match correct ITAAC table entries - should be Figure 2.8.6-1 rather than Figure 2.2.4-1.
156	2	2.8.6	RAI / Changes associated with RAI Batch #156, Supp 1, Response to Questions 14.03.03-27 and 14.03.03-28
157	2	2.8.6	Editorial / Change definition for PACS acronym - Priority and Actuator Control System
158	2	2.8.7	RAI / Changes associated with RAI Batch #156, Supp 1, Response to Questions 14.03.03-27 and 14.03.03-28
159	2	2.8.7	Editorial / Change definition for PACS acronym - Priority and Actuator Control System
160	2	2.8.7 Figure 2.8.7-1	Editorial Correction - In Figure 2.8.7-1, change the design area flags from alphanumeric to numeric to match the design area table given in the figure per WebCAP 2008-6141-CR.
161	2	2.9	RAI / Changes associated with RAI Batch #43, Supp 1, Response to Question 14.03.08-1 (1a and 1e)
162	2	2.9	RAI / Changes associated with RAI Batch #128, Response to Question 14.03.04-3
163	2	2.9	RAI / Changes associated with RAI Batch #104, Supp 1, Response to Question 14.03-1b
164	2	2.9	RAI / Changes associated with RAI Batch #43, Supp 1, Response to Question 14.03.08-1 (1a)
165	2	2.10.1	Editorial / Clarify wording in cranes ITAAC table [Table 2.10.1-2] for acceptance criteria for consistency with other ITAAC (delete wording "A report exists and concludes")
166	2	2.6.7 Figure 2.6.7-1	Editorial / Figure clarification

Item	Chapter	Subsection	Type of Change
167	2	2.6.7 Figure 2.6.7-3	Editorial / Figure clarification
168	2	2.6.8 Figure 2.6.8-1	Editorial / Figure clarification
169	2	2.7.11	Correction - minor / Delete unnecessary non-safety Tier 1 commitment wording and ITAAC for ESWs (Section 2.7.11); add add'l equipment to ESWs Table 2.7.11-2; delete duplicate ITAAC entry in Table 2.7.11-3
170	2	2.8.2	Editorial / Delete duplicate ITAAC entries for Main Steam System (SG steam outlet flow restrictor throat area size) and its associated ITAAC entry because it's already covered by ITAAC for the RCS in Section 2.2.1 (#3.5).
171	2	2.8.2 Figure 2.8.2-1 (Sheet 1 of 2)	Editorial / Figure clarification
172	2	2.8.6	Editorial - correct figure number for Items 3.5 - 3.8 to match correct figure number in ITAAC Table 2.8.6-3.
173	2	2.8.6 Figure 2.8.6-1	Editorial / Figure clarification
174	2	2.8.7 Figure 2.8.7-1	Editorial / Figure clarification
175	2	2.10	RAI / Changes associated with RAI Batch #173, Response to Question 09.01.05-19
176	3	3.1	Editorial
177	3	3.1	RAI / Changes associated with RAI Batch #42, Suppl 1, Response to Question 14.03.12-6
178	3	3.2	RAI / Changes to FSAR as specified in RAI Batch 21 - Response #17.04-14 & 17.04-15
179	3	3.3	Editorial
180	3	3.3	RAI / Changes associated with RAI Batch #104, Supp 1, Response to Question 14.03-1b
181	3	3.3	RAI / Changes associated with RAI Batch #123, Supp 1, Response to Questions 14.03-4, 14.3-5, 14.03-6
182	3	3.4	RAI / Changes associated with RAI Batch #115, Supp 2, Response to Question 14.03.09-5, 14.03.09-6, 14.03.09-7, 14.03.09-8, 14.03.09-9, 14.03.09-10, 14.03.09-11, 14.03.09-12, 14.03.09-13
183	3	3.5	Editorial
184	3	3.5	RAI / Changes associated with RAI Batch #149, Response to Question 03.09.05-1
185	3	3.5	RAI / Changes associated with RAI Batch #148, Response to Question 14.03.03-23
186	3	3.5	RAI / Changes associated with RAI Batch #116, Response to Question 14.03.06-2
187	3	3.5	RAI / Changes associated with RAI Batch #128, Response to Questions 14.03.04-3, 14.03.07-3
188	3	3.5	RAI / Changes associated with RAI Batch #156, Supp 1, Response to Questions 14.03.03-27 and 14.03.03-28
189	3	3.5	Editorial / Delete duplicate ITAAC entries (containment leakage rate) - covered in 3.3 (#1.0).
190	3	3.5 Figure 3.5-1	RAI / Changes associated with RAI Batch #12 - RAI Responses 06.02.04-07 (Parts 1, 3, 4, 5)
191	2	3.5	RAI / Changes associated with RAI Batch #156, Response to Question 14.03.03-26
192	3	3.6	RAI / Changes associated with RAI Batch #128, Supp 1, Response to Question 14.03.6-18
193	3	3.7	RAI / Changes associated with RAI Batch #61, Supp 3, Response to Question 07.05-3
194	2	3.11	RAI / Changes associated with RAI Batch #104, Supp 1, Response to Question 14.03-1b

Item	Chapter	Subsection	Type of Change
195	2	4 - TOC and 4.5	RAI / Changes associated with RAI Batch #131, Response to Question 09.01.04-12
196	4	4	Correction - minor / Correct cross-reference for regulations governing ITAAC for the site-specific portion of the facility design - change 10 CFR 52.79(c) to 10 CFR 52.80(a)
197	4	4.6	Editorial / Delete inappropriate level of detail – delete reference to specific revisions of ANSI codes, etc. since this level of detail belongs in Tier 2 only
198	4	4.6 & 4.7	RAI / Changes associated with RAI Batch #119, Supp 2, Response to Question 09.02.01-23
199	4	4.10	Editorial / Correct cross-reference
200	4	4.9 - 4.12	Correction - moderate / Delete Interface Requirement in Section 4.9 and renumber following sections [The Lightning Protection and Ground System interface requirement formerly in 4.9 has been deleted because the Section 2.5.8 ITAAC provides enough detail that an interface requirement is not necessary].
201	5	5 Table 5.0-1	RAI / Changes to FSAR as specified in RAI Batch 10 - Response #2.03.01-2 - clarify maximum wind speed parameter to state "Maximum Speed (Other Than Tornado)"; For precipitation - delete parenthetical "(for roof design)" for Rainfall rate and Snow & Ice Load
202	5	5 Table 5.0-1	RAI / Changes to FSAR as specified in RAI Batch 13 - Response #2.04-01 - For precipitation - delete parenthetical "(for roof design)" for Rainfall rate and Snow & Ice Load
203	5	5 Figure 5.0-1, Table 5.0-1	RAI / Changes to FSAR as specified in RAI Batch 35 - Response# 02.05.02-4 - Add seismology design response spectra figure (Figure 5.0-1) and reference in Tier 1, Table 5.0-1
204	5	5	RAI / Changes associated with RAI Batch #35, Supp 1, Response to Question 02.05.04-2
205	5	5	RAI / Changes associated with RAI Batch #86, Supp 1, Response to Question 09.01.02-21
206	5	5	RAI / Changes associated with RAI Batch #93, Supp 1, Response to Question 02.03.01-12

Item	Chapter	Subsection	Type of Change
1	Generic	Generic	Editorial / Generic FSAR Cleanup Issues
2	1	1.1	Editorial / Add trademark designation for U.S. EPR and note that the symbol is not used elsewhere in the document but it applies throughout.
3	1	1.1 Table 1.1-1	Editorial / Update Table of Acronyms
4	1	1.1 Table 1.1-1	Editorial / Update Acronym list for Tier 2
5	1	1.1	Editorial / Update Acronym list for Tier 2
6	1	1.1 Table 1.1-1	Editorial - Update Table of Acronyms from Section 4.2
7	1	1.1 Table 1.1-1	Editorial / Additional update to Acronym table (Add COLR, CT, HAZ, and RCA)
8	1	1.1 Table 1.1-1	Editorial / Update Table of Acronyms to clarify and add acronyms for Essential Service Water Building and associated structures, plus add Flow Induced Vibration (FIV)
9	1	1.1 Table 1.1-1	Editorial / Update Table of Acronyms
10	1	1.1 Table 1.1-1	Editorial / Update Table of Acronyms (Add BAST, CDM, delete SBOVS, add SGBVS, and correct SDD)
11	1	1.1 Table 1.1-1	Editorial / Update Acronym list - Correct Post-Accident Monitoring (PAM) for consistency
12	1	1.2	Editorial - Change Figure References for Turbine Building to delete Figure 1.2-49 since it has been deleted.
13	1	1.2	Correction - minor / Revise/clarify wording and revise cross-reference for further description of NAB and RWPB
14	1	1.2	RAI / Changes associated with RAI Batch #64, Response to Question 05.03.01-2
15	1	1.2	RAI / Changes associated with RAI Batch #91, Suppl 3, Response to Questions 91-S3, 100-S2, 106-S1
16	1	1.2	RAI / Changes associated with RAI Batch #100, Suppl 2, Response to Questions 91-S3, 100-S2, 106-S1.
17	1	1.2	RAI / Changes associated with RAI Batch #106, Suppl 1, Response to Questions 91-S3, 100-S2, 106-S1.
18	1	1.2	Editorial / Correct/revise cross-references
19	1	1.2 Figures 1.2-18 thru 1.2-20	Editorial / Figure titles correction - Place (-) Sign Before elevation numerical value
20	1	1.3 Table 1.3-1	Editorial / Correct/revise cross-references
21	1	1.3 Table 1.3-1	Correction - minor / Delete new fuel storage racks center-to-center spacing since it is listed separately in Chapter 16 - Section 4.3.1
22	1	1.6 Table 1.6-1	Editorial / Update dates, ANP revision levels
23	1	1.6 Table 1.6-1	Editorial / Update table of reports referenced (misc notes, titles, and dates)
24	1	1.6 Table 1.6-1	Editorial / Update Title for ANP-10283P and ANP-10283NP to add words "Technical Report" as denoted on report title page
25	1	1.6 Table 1.6-1	RAI / Changes associated with RAI Batch #107, Response to Question 03.06.02-5
26	1	1.6 Table 1.6-1	RAI / Changes associated with RAI Batch #64, Supplement 2, Response to Question 05.03.02-5
27	1	1.6 Table 1.6-1	Correction - minor / Add new report to list [ANP-10293, "U.S. EPR Design Features to Address GSI-191 Technical Report" that was issued in February 2008 and included in Supplement #1 letter sent to the NRC on 2/07/08]
28	1	1.6 Table 1.6-1	Correction - minor / Add new report to list [ANP-10294, "U.S. EPR Reactor Coolant Pump Motor Flywheel Structural Analysis Technical Report" that was issued in November 2008 in support of the response to RAI 18, Question 05.04.01.01-1]

Item	Chapter	Subsection	Type of Change
29	1	1.6 Table 1.6-1	Update Reference to ANP-10294, "U.S. EPR Reactor Coolant Pump Motor Flywheel Structural Analysis Technical Report" to Rev. 1 based on AREVA Ltr NRC:-9:028 dated 3/31/09 which transmitted Rev. 1 of the report to the NRC
30	1	1.6 Table 1.6-1	Correction - minor /Add EMF-2341(P), "Generic Strategy for Periodic Surveillance Testing of TELEPERM XS Systems in U.S. Nuclear Generating Stations" to list of reports referenced in Table 1.6-1 (used in Section 7.1) and add footnotes
31	1	1.7	RAI / Changes associated with RAI Batch #135, Suppl 1, Response to Question 09.04.05-1.13
32	1	1.7	Editorial / Clarification of valve position indications on figures - following sentence added: " Valve position indications shown on these figures do not represent a specific operational state."
33	1	1.7	Editorial / Clarification of continuation labels on figures - paragraph added based on NRC questions during draft RAI phone call and subsequent conference call on 06/09/2008
34	1	1.7	RAI / Changes associated with RAI Batch #125, Response to Questions 09.03-04-1, 09.03.04-12
35	1	1.7 Figure 1.7-1	Editorial / Figure cleanup (Change sludge water line type, and delete angle lift check valve)
36	1	1.8	Editorial / Change reference to the "Ultimate Heat sink (UHS) Structures" to "Essential Service Water Buildings"
37	1	1.8 Table 1.8-1	RAI / Changes associated with RAI Batch #119, Suppl 2, Response to Question 09.02.01-23
38	1	1.8 Table 1.8-2	Corrections - minor /COL Item Corrections (mostly cross-references); revise wording for COL Item 9.2-1; add COL Item 10.2-5.
39	1	1.8	RAI / Changes associated with RAI Batch #89, Response to Question 06.04-4
40	1	1.8	RAI / Changes associated with RAI Batch #107, Response to Question 03.06.02-5
41	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #99, Response to Question 03.13-4
42	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #88, Suppl 1, Response to Question 05.03.02-6
43	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #11, Suppl 1, Response to Question 08.03.01-6
44	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #37, Response to Question 02.03.04-5
45	1	1.8 Table 1.8-2	Editorial / Correct Table referenced in COL Item 2.3-1 - should be "Table 2.1-1" rather than "Table 2-1".
46	1	1.8 Table 1.8-2	RAI / Changes to FSAR associated with RAI Batch #13 - in accordance with RAI Responses 02.04.04-01, 02.04.06-1, and 02.04.09-01
47	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #109, Suppl 1, Response to Question 03.05.01.01-1
48	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #118, Suppl 1, Response to Question 03.04.01-7
49	1	1.8 Table 1.8-2	Correction - minor / restructure to clarify existing COL items in COL Item 3.5-1 - split 3 items originally included in 3.5-1 into 2 new COL items (3.5-8 and 3.5-9) and revise original Item 3.5-1 to match exactly with the text of Section 3.5.1.1.3 and 3.5.1.2.3.
50	1	1.8 Table 1.8-2	RAI / COL Item revision to wording [#3.9-9] based on RAI response to Piping Topical Report - change "NRC approved benchmark program" to "U.S. EPR benchmark program"
51	1	1.8 Table 1.8-2	Correction - moderate / Delete COLA Item in Section 3.10 related to seismic qualification of equipment (based on NRC application review schedule letter dated 3/26/08 and subsequent NRC telecon) and re-number other COL items in 3.10
52	1	1.8 Table 1.8-2	RAI / Changes to FSAR associated with RAI Batch #41 - in accordance with RAI Response 05.02.01.01-1
53	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #61, Suppl 3, Response to Question 07.05-3

Item	Chapter	Subsection	Type of Change
54	1	1.8 Table 1.8-2	RAI / Changes to FSAR associated with RAI Batch #216 - in accordance with RAI Response 08.04-9
55	1	1.8 Table 1.8-2	RAI / Changes to FSAR associated with RAI Batch #119, Supplement 3, Response to Question 09.02.01-24
56	1	1.8 Table 1.8-2	RAI / Changes to FSAR associated with RAI Batch #20 - Add new Fire Protection System COL items - in accordance with RAI Responses #09.05.01-02, 09.05.01-03, 09.05.01-09, & 09.05.01-13
57	1	1.8 Table 1.8-2	RAI / Changes to FSAR associated with RAI Batch #18 - in accordance with RAI Response 03.05.01.03-01
58	1	1.8 Table 1.8-2	RAI / Changes to FSAR associated with RAI Batch #36 - in accordance with RAI Response 09.05.02-6 - Add COL Item for offsite communication system
59	1	1.8 Table 1.8-2	Correction - moderate / Add COL items for Liquid and Gaseous Radwaste Systems to compare typical site Cost-Benefit Analysis against specific COL applicant's site [associated with deletion of NEI Generic Cost Benefit Analysis - NEI 07-11 - which is no longer being reviewed by NRC]
60	1	1.8 Table 1.8-2	Editorial / Add indication of whether Item 13.6-2 is for COL Applicant or COL Holder
61	1	1.8 Table 1.8-2	Editorial
62	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #152, Response to Question 09.05.04-16
63	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #83, Response to Question 10.04.05-1
64	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #91, Suppl 3, Response to Questions 91-S3, 100-S2, 106-S1
65	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #100, Suppl 2, Response to Questions 91-S3, 100-S2, 106-S1
66	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #106, Suppl 1, Response to Questions 91-S3, 100-S2, 106-S1
67	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #42, Response to Question 14.03.12-1
68	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #192, Response to Question 12.05-1
69	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #214, Response to Question 12.05-2
70	1	1.8 Table 1.8-2	Editorial change to wording of COL items 14.2-5 and 14.2-7 for circulating water supply system and cooling tower [to state provide site-specific test "abstract" information]; Add COL item 14.2-8 that was inadvertently omitted for the raw water supply system.
71	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #143, Suppl 1, Response to Question 14.02-64
72	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #85, Suppl 1, Response to Question 14.02-36
73	1	1.8 Table 1.8-2	Correction - Minor / Delete duplicate COL item added in RAI Batch #85, Suppl 1 Q 14.02-36 [COL Item 14.2-12]. This is a duplicate of existing COL item 14.2-8.
74	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #98, Response to Questions 14.02.44, 14.02-45
75	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #189, Response to Question 14.2-95
76	1	1.8 Table 1.8-2	Clarify COL item associated with Tech Specs (Item 16.0-1) to indicate that the COL Applicant will "provide the necessary information in response to the Reviewer's Notes and replace preliminary information provided in brackets of the TS and TS Bases with plant-specific values." - per discussion with NRC and to facilitate inclusion of the Setpoint Control Program in COL Tech Specs.
77	1	1.8 Table 1.8-2	RAI / Changes associated with RAI Batch #97, Response to Question 19-225

Item	Chapter	Subsection	Type of Change
78	1	1.9	RAI / Changes associated with RAI Batch #143, Suppl 1, Response to Question 14.02-64
79	1	1.9 Table 1.9-2	RAI / Add conformance and commitment to RG 1.37, Rev. 1 for section 17.5 - per Response to RAI Batch #38, Question #17.5-1
80	1	1.9 Table 1.9-2	RAI / Changes associated with RAI Batch #168, Response to Question 03.06.03-19
81	1	1.9 Table 1.9-2	RAI / Delete reference to 5% damping for piping - agreed to use 4% damping per RG 1.61. NOTE: Part of comment resolution from ANP-10264 [U.S. EPR Piping Analysis and Piping Support Design Topical Report]
82	1	1.9 Table 1.9-2	RAI / Changes associated with RAI Batch #143, Response to Question 14.02-65
83	1	1.9 Table 1.9-2	RAI / Changes to FSAR associated with RAI Batch #16 in accordance with RAI Response #14.02-9
84	1	1.9 Table 1.9-2	RAI / Changes to FSAR associated with RAI Batch #214 in accordance with RAI Response #12.05-2
85	1	1.9 Table 1.9-3	Editorial / Update references to FSAR sections where TMI requirements are addressed in Table 1.9-3
86	2	TOC, 2.1, 2.3, 2.4, 2.5,	Editorial
87	2	2.1, 2.3, 2.4, 2.5,	Editorial
88	2	2.1, 2.3, 2.5,	Editorial
89	2	2.1 Table 2.1-1	RAI / Changes to FSAR as specified in RAI Batch 10 - Response #2.03.01-2 - clarify maximum wind speed parameter to state "Maximum Speed (Other Than Tornado)"
90	2	2.1 Table 2.1-1	Editorial / Change label for Tornado to include rate of pressure drop
91	2	2.1	RAI / Changes associated with RAI Batch #130, Suppl 1, Response to Question 03.07.02-22
92	2	2.1	RAI / Changes associated with RAI Batch #35, Suppl 1, Response to Question 02.05.04-2
93	2	2.1	RAI / Changes associated with RAI Batch #37, Response to Question 02.03.04-5
94	2	2.1	RAI / Changes associated with RAI Batch #93, Suppl 1, Response to Question 02.03.01-12
95	2	2.1 Table 2.1-2	Editorial / Entry for metastable isotopes changed to lowercase "m"
96	2	2.1 Table 2.1-2	Addition of Tritium to Table 2.1-2 - Bounding Values for Component Radionuclide Inventory - corresponding change required for consistency with response to RAI 86, Suppl 1, Q 09.01.02-21
97	2	2.3 Table 2.3-3	RAI / Changes to FSAR as specified in RAI Batch 10 - Response #2.03.04-4 - add Table 2.3-3: Input Parameters for Control Room X/Q Values
98	2	2.3	RAI / Changes associated with RAI Batch #37, Response to Question 02.03.04-5
99	2	2.4	RAI / Changes associated with RAI Batch #93, Suppl 1, Response to Question 02.03.01-12
100		2.4	RAI / Changes to FSAR associated with RAI Batch #13 - in accordance with RAI Responses 02.04.04-01, 02.04.06-1, and 02.04.09-01
101	2	2.5	Editorial
102	2	2.5	RAI / Changes associated with RAI Batch #35, Suppl 1, Response to Question 02.05.04-2
103	2	2.5 2.5.4.2 2.5.4.3	Correction - minor / Revision of Sliding and Overturning Results for the Nuclear Island: Change maximum bearing pressure under safe shutdown earthquake loads combined with other loads from 25,000 lb/ft ² to 31,400 lb/ft ² . Also include a range of friction coefficients and update soil damping in 2.5.4.2 & 2.5.4.3.
104	2	2.5	Editorial correction to title and dates of 2 references in Sec. 2.5.
105	3	3 TOC	Editorial / Consistency in titles and other editorial changes
106	3	3.1	Editorial correction to title of Reference 1- ANSI/ASME NQA-1-1994

Item	Chapter	Subsection	Type of Change
107	3	3.2	Editorial / Clarify sentences defining classification of SSCs and secondary design function definition
108	3	3.2 Table 3.2.2-1	Editorial / Add "(Note 5)" to Table 3.2.2-1 column titled "10 CFR 50 Appendix B Program" spelling corrections in Note 5
109	3	3.2 Table 3.2.2-1	RAI / Changes associated with RAI Batch #71 Response to Question 03.02.01-2
110	3	3.2 Table 3.2.2-1	RAI / Changes associated with RAI Batch #50, Suppl 1, Response to Question 04.05.02-4
111	3	3.2 Table 3.2.2-1	RAI / Changes associated with RAI Batch #111, Suppl 5, Response to Question 06.02.02-17
112	3	3.2 Table 3.2.2-1	RAI / Changes associated with RAI Batch #72, Suppl 1, Response to Question 03.02.02-5
113	3	3.2 Table 3.2.2-1	RAI / Changes associated with RAI Batch #131, Suppl 3, Response to Questions 09.01.04-1a, 09.01.04-1c
114	3	3.2 Table 3.2.2-1	RAI / Changes associated with RAI Batch #72, Suppl 1, Response to Question 03.02.02-4
115	3	3.2 Table 3.2.2-1	RAI / Changes associated with RAI Batch #119, Suppl 1, Response to Questions 09.02.01-1 & 09.02.01-3
116	3	3.2 Table 3.2.2-1	RAI / Changes associated with RAI Batch #169, Suppl 1, Response to Question 09.05.01-66
117	3	3.2 Table 3.2.2-1	RAI / Changes associated with RAI Batch #168, Response to Question 03.06.03-19
118	3	3.2 Table 3.2.2-1	RAI / Changes associated with RAI Batch #87, Suppl 4, Response to Question 09.05.07-2
119	3	3.2 Table 3.2.2-1	RAI / Changes associated with RAI Batch #131, Suppl 2, Response to Question 09.05.06-2
120	3	3.2 Table 3.2.2-1	RAI / Changes associated with RAI Batch #145, Suppl 1, Response to Question 09.05.08-2
121	3	3.2 Table 3.2.2-1	RAI / Changes associated with RAI Batch #159, Suppl 1, Response to Question 09.05.05-1
122	3	3.2 Table 3.2.2-1	RAI / Changes associated with RAI Batch #135, Suppl 1, Response to Questions 09.04.05-1.1 and 09.04.05-1.13
123	3	3.2 Table 3.2.2-1	RAI / Changes associated with RAI Batch #173, Suppl 1, Response to Question 09.01.05-1
124	3	3.2 Table 3.2.2-1	Editorial / Correct punctuation for ASME Code in Notes 1,2,3,4 and 8 in Table 3.2.2-1
125	3	3.2 Table 3.2.2-1	RAI / Changes associated with RAI Batch #119, Suppl 1, Response to Question 09.02.01-3
126	3	3.3	RAI / Changes associated with RAI Batch #108, Response to Question 03.03.01-2
127	3	3.3	RAI / Changes associated with RAI Batch #126, Response to Questions 03.03.02-1, 03.03.02-2
128	3	3.4	RAI / Changes associated with RAI Batch #118, Response to Question 03.04.01-4
129	3	3.4	RAI / Changes associated with RAI Batch #118, Suppl 1, Response to Question 03.04.01-7
130	3	3.4	RAI / Changes associated with RAI Batch #131, Suppl 1, Response to Question 09.02.01-25
131	3	3.4	RAI / Changes associated with RAI Batch #109, Response to Questions 03.04.01-1, 03.04.01-2, 03.04.01-3
132	3	3.4	RAI / Changes associated with RAI Batch #84, Response to Question 09.01.02-8
133	3	3.5	RAI / Changes associated with RAI Batch #109, Response to Questions 03.05.01-1, 03.05.02-1
134	3	3.5	RAI / Changes associated with RAI Batch #109, Suppl 1, Response to Question 03.05.01.01-1
135	3	3.5	RAI / Changes associated with RAI Batch #109, Suppl 2, Response to Question 03.05.01.03-2

Item	Chapter	Subsection	Type of Change
136	3	3.5	RAI / Changes associated with RAI Batch #162, Suppl 1, Response to Questions 03.05.03-1 and 03.05.03-3
137	3	3.5	RAI / Changes associated with RAI Batch #162, Response to Question 03.05.03-7
138	3	3.6	RAI / Changes associated with RAI Batch #107, Suppl 1, Response to Questions 03.06.02-9, 03.06.02-11
139	3	3.6	RAI / Changes associated with RAI Batch #80, Response to Questions 03.06.01-3 and 03.06.01-4
140	3	3.6	RAI / Changes associated with RAI Batch #107, Response to Questions 03.06.02-2, 03.06.02-4, 03.06.02-5
141	3	3.6 Table 3.6.1-1	Correction - minor / Clarify wording for Footnotes 1 and 6 in Table 3.6.1-1—High-Energy and Moderate-Energy Fluid Systems Considered for Protection of Essential Systems
142	3	3.6.3.3.3	Editorial / Additional sentence added to provide cross-reference for additional detail on flow-accelerated corrosion in the main steam supply system in Section 10.3.6.3
143	3	3.6	Editorial
144	3	3.6	RAI / Changes associated with RAI Batch #48, Suppl 1, Response to Question 03.06.03-12
145	3	3.6	Editorial / correct cross-reference (3.6.3.1.1 should be 3.6.3.6.1.1)
146	3	3.6	RAI / Changes associated with RAI Batch #168, Response to Question 03.06.03-19
147	3	3.6	RAI / Changes associated with RAI Batch #48, Response to Question 03.06.03-9
148	3	3.7	Editorial
149	3	3.7	RAI / Delete reference to 5% damping for piping - agreed to use 4% damping per RG 1.61. NOTE: Part of comment resolution from ANP-10264 [U.S. EPR Piping Analysis and Piping Support Design Topical Report]
150	3	3.7 Figure 3.7.1-2	Editorial / Figure 3.7.1-2 - Spelling correction in title
151	3	3.7.2.2	Editorial / Change table titles referenced in text to match the actual table titles for Tables 3.7.2-1 thru Table 3.7.2-3
152	3	3.7 Table 3.7.2-1 Figure 3.7.2-3, Figure 3.7.2-4, Figure 3.7.2-62	Editorial / Table 3.7.2-1, and figure clarification
153	3	3.7	Editorial / Change Titles for Figures 3.7.1-17 through 3.7.1-25 – needed to understand different lines on same graph (changed titles instead of adding legend)
154	3	3.7	RAI / Changes associated with RAI Batch #161, Response to Question 03.12-11
155	3	3.7	RAI / Changes associated with RAI Batch #130, Suppl 1, Response to Questions 03.07.01-10, 03.07.01-12, 03.07.01-15, 03.07.01-16, 03.07.02-2, 03.07.02-34, 03.07.02
156	3	3.7	RAI / Changes associated with RAI Batch #130, Suppl 2, Response to Questions 03.07.01-5, 03.07.01-6, 03.07.01-7, 03.07.02-19, 03.07.02-23, 03.07.02-25, 03.07.02-27
157	3	3.7	RAI / Changes associated with RAI Batch #52, Suppl 1, Response to Question 03.09-02-2
158	3	3.7	RAI / Changes associated with RAI Batch #115, Suppl 1, Response to Question 14.03.02-5
159	3	3.7	RAI / Changes associated with RAI Batch #35, Suppl 1, Response to Question 02.05.02-3
160	3	3.7	RAI / Changes associated with RAI Batch #73, Response to Questions 03.07.04-2, 03.07.04-3, 03.07.04-4 and 03.07.04-5

Item	Chapter	Subsection	Type of Change
161	3	3.7, Table 3.7.2-8, 3.8	Editorial / Miscellaneous editorial changes (including changing 'Emergency' Service Water Building to 'Essential' Service Water Building (Table 3.7.2-8))
162	3	3.7 Figures: 3.7.2-104, 3.7.2-105, 3.7.2-107, 3.7.2-108	Correction - minor / Labeling for coordinate system for the in-structure response spectrum for the ESWB corrected in Figures 3.7.2-104, 105, 107, & 108 per WebCAP 2008-4032
163	3	3.7	RAI / Changes associated with RAI Batch #108, Suppl 1, Response to Questions 03.07.03-1, 03.07.03-3, 03.07.03-4, 03.07.03-5, 03.07.03-9, 03.07.03-11, 03.07.03-12, 03.07.03-14, 03.07.03-16, 03.07.03-18, 03.07.03-19
164	3	3.7	RAI / Changes associated with RAI Batch #108, Response to Question 03.07.03-2
165	3	3.7	RAI / Changes associated with RAI Batch #187, Response to Questions 03.07.03-20, 03.07.03-21
166	3	3.7	RAI / Changes associated with RAI Batch #107, Response to Question 03.06.02-5
167	3	3.8.1.1	Editorial / Add ""Figure" before reference to Figure 3.8-13 in text of 3.8.1.1 (cross-references consistency)
168	3	3.8	RAI / Changes associated with RAI Batch #126, Response to Questions 03.03.02-1
169	3	3.8	Correction - minor / Change description of ANSYS SOLID45 to indicate that it is an "eight-node" rather than a "four-node" brick element.
170	3	3.8	Editorial / Change table cross-references for Tables 3.8-2, 3.8-3, and 3.8-4 for consistency
171	3	3.8	RAI / Changes associated with RAI Batch #155, Response to Questions 03.08.01-15, 03.08.01-15 (Part 1), 03.08.01-18, 03.08.01-19, 03.08.01-26 (Part 2)
172	3	3.8	RAI / Changes associated with RAI Batch #155, Suppl 1, Response to Questions 03.08.01-4, 03.08.01-5, 03.08.03-2, 03.08.03-9, 03.08.05-3, 03.08.05-4
173	3	3.8	RAI / Changes associated with RAI Batch #81, Suppl 1, Response to Question 06.01.01-6
174	3	3.8	Editorial / Correct cross-reference from "Sections 3.6" to "Section 3.6"
175	3	3.8	RAI / Changes associated with RAI Batch #86, Response to Question 09.01.02-20
176	3	3.8	RAI / Changes associated with RAI Batch #93, Suppl 1, Response to Question 02.03.01-12
177	3	3.8.4.4.2	Editorial / Title and content editorial corrections for 3.8.4.4.2 - delete "Other Seismic Category I Structures" in reference to NI Common Basemat Structure
178	3	3.8	RAI / Changes associated with RAI Batch #35, Suppl 1, Response to Question 02.05.04-2
179	3	3.8	RAI / Changes associated with RAI Batch #107, Response to Question 03.06.02-5
180	3	3.8	RAI / Changes associated with RAI Batch #130, Suppl 2, Response to Question 03.07.02-27
181	3	3.8 Figures 3.8-101 & 3.8-102	Correction - moderate / Update figures based on change in T2 Section 2.4 in Supplement #2 letter on 2/20/08 to change definition of finished yard grade to 1 foot below ground floor top of concrete.
182	3	3.8 Figure 3.8-106	Correction - moderate / Replace figure with correct one for "Elastic Displacement for Soil Case 1u". Original submittal had repeated the figure for Fig. 3.8-103 twice - once for Fig. 3.8-103 (correct figure) and again for Fig. 3.8-106.
183	3	3.9	Editorial / Delete unnecessary sentence concerning computer programs
184	3	3.9	Editorial / Change "Appendix C" to "Appendix 3C".

Item	Chapter	Subsection	Type of Change
185	3	3.9	RAI / COL Item revision to wording [#3.9-9] based on RAI response to Piping Topical Report - change "NRC approved benchmark program" to "U.S. EPR benchmark program"
186	3	3.9	RAI / Changes associated with RAI Batch #161, Response to Question 03.12-11
187	3	3.9	RAI / Changes associated with RAI Batch #107, Response to Question 03.06.02-5
188	3	3.9 Table 3.9.1-1	RAI / Changes associated with RAI 179, Supplement 2, Response to Question 03.09.01-1 - Update Table 3.9.1-1
189	3	3.9	RAI / Changes associated with RAI Batch #160, Response to Questions 03.09.02-10 and 03.09.02-14
190	3	3.9	Editorial / Delete reference to "during detailed design"
191	3	3.9	Correction - minor / Section number cross-reference, and clarification of information provided on seismic qualification testing given in 3.10.
192	3	3.9	Editorial / Insertion of sentence in 3.9.2 ["These sources are considered in the hot functional testing of the RPV internals and in subsequent analytical evaluations."], and other miscellaneous editorial changes
193	3	3.9	RAI / Changes associated with RAI Batch #143, Suppl 1, Response to Question 14.02-64
194	3	3.9	Editorial / Cross-out text, editorial update
195	3	3.9	RAI / Changes associated with RAI Batch #178, Response to Questions 03.09.03-17, 03.09.03-20
196	3	3.9	Editorial / Replace text to match Figure title; replace text to match Reference
197	3	3.9.4	Editorial / Revised wording/clarification to keep consistent units of psia for design and operating pressure in 3.9.4 discussion
198	3	3.9	RAI / Changes associated with RAI Batch #95, Response to Question 03.09-04
199	3	3.9	Editorial / Revised wording/clarification to add additional pointer for RPV interfaces to RCS discussion in Section 5.3
200	3	3.9	RAI / Changes associated with RAI Batch #149, Response to Questions 03.09.05-8, 03.09.05-9, 03.09.05-10 and 03.09.05-11
201	3	3.9	RAI / Changes associated with RAI Batch #50, Suppl 1, Response to Question 04.05.02-4
202	3	3.9	RAI / Changes associated with RAI Batch #50, Suppl 1, Response to Question 04.05.02-6
203	3	3.9 Figure 3.9.5-1	Editorial / Added an identifier for Inlet and Outlet of primary coolant flow in RPV in Figure 3.9.5-1
204	3	3.9.6.1	Editorial / Maximum flow testing and acceptance criteria - change wording to match Revised source document and correct "acceptable" to "acceptance" criteria
205	3	3.9	RAI / Changes associated with RAI Batch #49, Response to Question 03.09.06-13
206	3	3.9	RAI / Changes associated with RAI Batch #49, Suppl 1, Response to Question 03.09.06-5
207	3	3.10	Correction - moderate / Delete existing text and replace with updated information on seismic qualification based on NRC application review schedule letter dated 3/26/08 and subsequent NRC telecon.
208	3	3.10	RAI / Changes associated with RAI Batch #161, Response to Question 03.10-2, 30.10-7, 03.10-5, 30.10-21
209	3	3.10	RAI / Changes associated with RAI Batch #107, Response to Question 03.06.02-5
210	3	3.10	RAI / Changes associated with RAI Batch #135, Suppl 1, Response to Question 09.04.05-1.13
211	3	3.11	Editorial / Change "humidity [steam]" to "humidity from steam"
212	3	3.11	RAI / Changes associated with RAI Batch #96, Response to Question 03.11-2
213	3	3.11	RAI / Changes associated with RAI Batch #96, Supplement 1, Response to Question 03.11-1
214	3	3.11	RAI / Changes associated with RAI Batch #43, Suppl 1, Response to Question 14.03.08-1 (1a)

Item	Chapter	Subsection	Type of Change
215	3	3.11 Table 3.11-1	Correction to EQ list in Table 3.11-1 for Containment Ventilation System (KLA) Sensors. The KLA pressure sensors should be safety-related (S), and Seismic Category I, rather than Supplemental Grade Non-Safety (NS-AQ), Seismic Category II - resulting from WebCAP 2008-6358
216	3	3.11	RAI / Changes associated with RAI Batch #135, Suppl 1, Response to Question 09.04.05-1.1
217	3	3.12	RAI / Changes associated with RAI Batch #161, Response to Question 03.12-11
218	3	3.12	RAI / Changes associated with RAI Batch #107, Response to Questions 03.06.02-5 and 03.09.03-8
219	3	3.13	RAI / Changes associated with RAI Batch #99, Response to Question 03.13-4
220	3	3.1, 3.4, 3.5, 3.7, 3.9, 3.10, 3.11, 3.12, 3.13, 3A.4, 3D Attach. E	Editorial / Editorial and Reference additions/corrections
221	3	3A 3C	RAI / Changes associated with RAI Batch #107, Response to Question 03.06.02-5
222	3	3A	RAI / Changes associated with RAI Batch #52, Response to Question 03.09-02-4
223	3	3A	RAI / Changes associated with RAI Batch #52, Suppl 1, Response to Question 03.09-02-2
224	3	3A	RAI / Changes associated with RAI Batch #130, Suppl 1, Response to Question 03.07-01-15
225	3	3B	RAI / Changes associated with RAI Batch #130, Suppl 2, Response to Question 03.07.02-27
226	3	3B Figure 3B-75 Figure 3B-76	Correction - moderate / Update figures based on change in T2 Section 2.4 in Supplement #2 letter on 2/20/08 to change definition of finished yard grade to 1 foot below ground floor top of concrete.
227	3	3D	RAI / Changes associated with RAI Batch #96, Supplement 1, Response to Question 03.11-1
228	3	3D	Editorial / Revised wording/clarification - Changed RPS to PS in Note 1 to Table 3D-2
229	3	3D	RAI / Changes associated with RAI Batch #96, Response to Question 03.11-2
230	3	3D Figure 3D.D-1	Editorial / Change to make Figure 3D.D-1 title consistent with title in the text of this section
231	3	3D	Correction - moderate / Delete existing text and replace with updated information on seismic qualification based on NRC application review schedule letter dated 3/26/08 and subsequent NRC telecon.
232	3	3D	RAI / Changes associated with RAI Batch #161, Response to Question 03.12-11
233	3	3E	RAI / Changes associated with RAI Batch #155, Suppl 1, Response to Question 03.08.01-21
234	3	3E	RAI / Changes associated with RAI Batch #130, Suppl 2, Response to Question 03.07.02-27
235	3	3E.1	Editorial
236	3	3E.1	Editorial / Correct cross-reference to "Section 3.8.5.3" rather than "Section 3.8.5.3.2".
237	3	3E.1 Figure 3E.1-70	Correction - moderate / Replace Figure 3E.1-70 with correct figure - per WebCAP 2008-3658
238	3	3E.2, 3E.3	Editorial
239	3	3E.1- 3E.3	Correction - minor / Non-editorial comments - relating to figure changes
240	4	4.1	Editorial
241	4	4.1	Editorial
242	4	4.2	Editorial / revision to references for dates of approved topical and technical reports
243	4	4.3	Editorial
244	4	4.3	Editorial / Cleanup references - no references to letters for topical reports

Item	Chapter	Subsection	Type of Change
245	4	4.3, Table 4.3-1, 4.4	Editorial / Changes to references for Tech Specs
246	4	4.3	RAI / Changes associated with RAI Batch #134, Response to Question 04.03-15
247	4	4.4	RAI / Changes associated with RAI Batch #134, Response to Question 04.04-25
248	4	4.4	Editorial / Update cross-references to LYNXT code to Section 4.4.4.5.2 rather than 4.4.4.5.1
249	4	4.4	RAI / Changes associated with RAI Batch #134, Response to Questions 04.04-27 and 04.04-34
250	4	4.4.4.2.3	Editorial / Correct misspelling of 'empirical' in title of Section 4.4.4.2.3
251	4	4.4	RAI / Changes associated with RAI Batch #134, Response to Question 04.04-21
252	4	4.5	Editorial / Correction to table number reference - should be Table 5.2-2 rather than 5.2-1
253	4	4.5	Editorial / Term "grade" being added after "cold-worked" to indicate that no austenitic SS material that is designated as cold-worked is used in the RCPB. However, manufacturing processes such as bending may introduce incidental cold-working into the material - which is acceptable.
254	4	4.5	RAI / Changes to FSAR associated with RAI Batch #15, Supplement 1 - in accordance with RAI Responses 04.05.01-1, and 04.05.01-3
255	4	4.5	RAI / Changes associated with RAI Batch #50, Response to Questions 04.05.02-1, 04.05.02-3 and 04.05.02-5
256	4	4.6	RAI / Changes associated with RAI Batch #134, Response to Question 04.06-3
257	4	4.6	RAI / Changes associated with RAI Batch #134, Suppl 1, Response to Question 04.06-3
258	4	4.6	RAI / Changes associated with RAI Batch #57, Suppl 1, Response to Question 07.07-15
259	4	4.6	Correction - minor / Clarification/correction of line sizes for reactor vent lines and incore instrumentation lines - so it now states that lines are "less than or equal to nominal pipe size (NPS) 1..."
260	4	4.6.2	Editorial / Correct Reference citation in 2nd paragraph for IEEE 384-1992 from Reference 4 to Reference 3 and delete Reference 3 citation in paragraph above after "ASME Section III". No Ref. 4 exists in this section.
261	4	4.6	RAI / Changes associated with RAI Batch #33, Response to Questions 04.06-1, 04.06-2
262	5	5.1 Figure 5.1-4 (Sheet 3 of 7)	Editorial / Figure cleanup (Replace PZR Safety relief component symbols)
263	5	5.2	RAI / Changes associated with RAI Batch #51, Response to Questions 05.02.01-2, 05.02.01.02-3, and 05.02.01.02-4
264	5	5.2	Correction - minor / Change of wording - channels to subsystems
265	5	5.2	Editorial / Change cross-reference to Chapter 16 'Technical Specifications' rather than 'SR' 3.4.10 and 3.4.11
266	5	5.2	RAI / Changes associated with RAI Batch #164, Suppl 1, Response to Question 12.03-12.04-8
267	5	5.2	RAI / Changes associated with RAI Batch #127, Suppl 1, Response to Question 14.02-54
268	5	5.2.3.3.2, 5.3.3.5, 5.4.2.4.1	Correction - minor / (1) Replace welding material storage requirements to more general requirements of ASME Section III, Paragraphs NB-2400 and NB-4400, (2) Delete references to RG 1.38 as these are concerns not addressed within the context of a DC application - also consistent with US EPR assessment in Table 1.9-2 for compliance with RG 1.38 (N/A-COL).

Item	Chapter	Subsection	Type of Change
269	5	5.2.3.4.1	Editorial / Term "grade" being added after "cold-worked" to indicate that no austenitic SS material that is designated as cold-worked is used in the RCPB. However, manufacturing processes such as bending may introduce incidental cold-working into the material - which is acceptable.
270	5	5.2	RAI / Changes associated with RAI Batch #88, Response to Questions 05.02.03-4, 05.02.03-5, 05.02.03-6, 05.02.03-8
271	5	5.2	RAI / Changes associated with RAI Batch #65, Response to Question 05.02.04-3
272	5	5.2	RAI / Changes associated with RAI Batch #186, Response to Question 05.02.04-4
273	5	5.2	RAI / Changes associated with RAI Batch #154, Response to Questions 05.02.05-1, 05.02.05-2
274	5	5.2	RAI / Changes associated with RAI Batch #88, Suppl 1, Response to Question 05.02.03-3
275	5	5.2, 5.3, 5.4	Editorial
276	5	5.2, 5.3, 5.4	Editorial / Correct cross-references and other editorial changes
277	5	5.2, 5.3, 5.4	Editorial
278	5	5.3	Editorial / Reference numbers corrected in text for ASME XI and ANP-10283P
279	5	5.3	RAI / Changes associated with RAI Batch #64, Response to Questions 05.03.01-1, 05.03.01-2, 05.03.01-5, 05.03.02-1, 05.03.02-2
280	5	5.3	RAI / Changes associated with RAI Batch #88, Suppl 1, Response to Question 05.03.02-6
281	5	5.3	RAI / Changes associated with RAI Batch #180, Response to Question 05.03.03-2
282	5	5.3	RAI / Changes associated with RAI Batch #50, Suppl 1, Response to Question 04.05.02-6
283	5	5.4	RAI / Changes associated with RAI Batch #18, Suppl 1, Response to Question 05.04.01.01-1
284	5	5.4	RAI / Changes associated with RAI Batch #83, Response to Question 10.04.07-3
285	5	5.4	RAI / Changes associated with RAI Batch #63, Suppl 1, Response to Questions 05.04.02.01-3, 05.04.02.02-4 thru 6, 05.04.02.02-9, 05.04.02.02-10 and 05.04.02.02-14
286	5	5.4	RAI / Changes associated with RAI Batch #127, Suppl 1, Response to Question 14.02-54
287	5	5.4	Editorial / Update references and other editorial changes
288	5	5.4	Correction - minor / Added reference to SECY 93-087 compliance for mid-loop operation
289	5	5.4	RAI / Changes associated with RAI Batch #31 - RAI Responses 05.04.07-3
290	5	5.4	RAI / Changes associated with RAI Batch #129, Response to Question 05.04.07-8
291	5	5.4	RAI / Changes associated with RAI Batch #83, Suppl 4, Response to Question 10.04.09-5
292	5	5.4	Editorial
293	5	5.4	RAI / Changes associated with RAI Batch #117, Response to Question 05.04.11-5
294	5	5.4.15	Update Reference to ANP-10294, "U.S. EPR Reactor Coolant Pump Motor Flywheel Structural Analysis Technical Report" to Rev. 1 (Ref 19) based on AREVA Ltr NRC:- 9:028 dated 3/31/09 which transmitted Rev. 1 of the report to the NRC
295	5	5.4 Table 5.4-9	Editorial / Clarify low temperature operation setpoints (Table 5.4-9)
296	5	5.4 Table 5.4-9	Correction-minor / Change LTOP setpoint from 524 psig to 525 psig for Pressurizer Safety Relief valves
297	6	6.1.3	RAI / Changes associated with RAI Batch #127, Suppl 1, Response to Question 14.02-54
298	6	6.1, 6.2	Editorial

Item	Chapter	Subsection	Type of Change
299	6	6.1, 6.2, 6.3, 6.4, 6.5	Editorial
300	6	6.1, 6.3, 6.2, 6.5	Editorial
301	6	6.1.1.1	Editorial / Term "grade" being added after "cold-worked" to indicate that no austenitic SS material that is designated as cold-worked is used in the RCPB. However, manufacturing processes such as bending may introduce incidental cold-working into the material - which is acceptable.
302	6	6.1.1.1, Table 6.1-1	RAI / Changes associated with RAI Batch #81, Suppl 1, Response to Question 06.01.01-6
303	6	6.1.1.3, 6.1.1.4	RAI / Changes associated with RAI Batch #81 Response to Question 06.01.01-8 and RAI Batch #81, Suppl 1, Response to Question 06.01.01-9
304	6	6.1.2.4	RAI / Changes associated with RAI Batch #203 Response to Questions 06.01.02-7, 06.01.02-8, and 06.01.02-9
305	6	6.1 Table 6.1-1	RAI / Changes associated with RAI Batch #81, Suppl 1, Response to Question 06.01.01-2
306	6	6.1	Editorial / Delete unnecessary extraneous information (galvanized material not assumed as a part of the debris load transported to IRWST sump screens) not required by SRP or RG 1.206
307	6	6.2	Editorial / Add additional cross-reference information to help reviewer find information (containment analyses during shutdown conditions) requested by RG 1.206, C.1.6.2.1
308	6	6.2	Editorial / update reference to tech specs
309	6	6.2.1.5.2	Correction - minor / For consistency with rest of FSAR (Tech Specs and chapter 15 and elsewhere in Chapter 6), revise IRWST upper range of water temperature from 120°F to 122°F
310	6	6.2	Editorial
311	6	6.2.1.1, 6.2.1.5, Table 6.2.1-4, Table 6.2.1-5, Table 6.2.1-8	RAI / Changes to FSAR associated with RAI Batch #1 - passive heat sink and IRWST heat sink description; added column to Table 6.2.1-5 for C-Steel, and update to peak pressure values in Table 6.2.1-8
312	6	6.2 Table 6.2.1-5	Correction - minor / Revise IRWST geometric information in Table 6.2.1-5 (Containment Heat Sink Inventory) for the surface area of the heavy floor. Original model included 2 heat sinks for the heavy floor and should have been only one. - Per WebCAP CR 2008-5206
313	6	6.2	Editorial
314	6	6.2.4	Correction - minor / Clarification of 2-hr batteries designation, and clarification of reference to Section 8.3.1.1.1
315	6	6.2.3.2 Table 6.2.3-2 Table 6.2.3-1	RAI / Changes associated with RAI Batch #122, Suppl 1, Response to Question 16-254
316	6	6.2.6.1, Table 6.2.4-1, 6.2.4.2	RAI / Changes associated with RAI Batch #12 - RAI Responses 06.02.06-01, 06.02.06-02, 06.02.04-03, 06.02.04-04, 06.02.04-05
317	6	6.2.3.2 Table 6.2.3-1, Table 6.2.3-2, 6.2.6.1	RAI / Changes associated with RAI Batch #101, Response to Questions 16-117, 16-123
318	6	Table 6.2.5-1	RAI / Changes associated with RAI Batch #RAI 1, Suppl 2 Response to Questions 6.2.1-07a and 6.2.1-07b
319	6	6.2.8	RAI / Changes associated with RAI Batch #RAI 82, Response to Question 06.02.06-3
320	6	6.2.6.2	RAI / Changes associated with RAI Batch #RAI 116, Response to Question 14.03.06-2
321	6	6.3.2.2	RAI / Changes associated with RAI Batch # 139, Suppl 1, Response to Question 06.02.02-18

Item	Chapter	Subsection	Type of Change
322	6	6.3 Table 6.3-1, Table 6.3-5	Editorial / Delete overly detailed component design information in Tables 6.3-1 and 6.3-5
323	6	Table 6.3-1	RAI / Changes associated with RAI Batch #128, Suppl 2, Response to Question 14.03.03-11
324	6	Table 6.3-4	RAI / Changes associated with RAI Batch #101, Response to Question 16-95
325	6	6.3 Figure 6.3-2	Editorial / Figure cleanup (Rotate pressure relief to correct configuration)
326	6	6.4	Editorial / Clarification of reference to Tech Specs
327	6	6.4.2.2	RAI / Changes associated with RAI Batch #135, Suppl 1, Response to Question 09.04.05-1.1
328	6	6.4.1 through 6.4.7	RAI / Changes associated with RAI Batch #RAI 89, Suppl 1, Response to Question 06.04-4
329	6	6.4.5, 6.4.7	RAI / Changes associated with RAI Batch #RAI 89, Suppl 1, Response to Question 06.04-2
330	6	6.5.1.2, 6.5.1.3	RAI / Changes associated with RAI Batch #RAI 122, Suppl 1, Response to Question 16-254
331	6	6.5.1.2, 6.5.4	RAI / Changes associated with RAI Batch #135, Response to Question 09.04.05-1.13
332	6	6.6	Correction - minor / Clarification in terminology. The US EPR does not have a system called the "containment atmospheric cleanup system" - replace with "ESF filter system".
333	7	7.1, 7.2, 7.3, 7.4	Editorial
334	7	7.2, 7.3, 7.7, 7.8	Editorial
335	7	7.1.1.3.1	RAI / Changes associated with RAI Batch #56, Suppl 1, Response to Question 07.09-7
336	7	7.1	Editorial / Spell out acronym wording in 1st occurrence in section for consistency (AOOs)
337	7	7.1	Editorial
338	7	7.1	Editorial / Spell out acronym wording in 1st occurrence in section for consistency (RCCAs)
339	7	7.1.1.5.1	RAI / Changes associated with RAI Batch #59, Response to Question 07.01-4
340	7	7.1.1.6.4	RAI / Changes associated with RAI Batch #56, Suppl 3, Response to Question 07.09-22
341	7	7.1.2.6.13, 7.1.2.6.19, 7.1.2.6.34	RAI / Changes associated with RAI Batch #75, Response to Questions 07.02-23, 07.02-24 and 07.02-28
342	7	7.1.1.6.4, Table 7.1-2	RAI / Changes associated with RAI Batch #61, Suppl 2, Response to Question 07-05-6
343	7	7.1	Editorial / Miscellaneous Editorial corrections (including references) - added additional reference for EMF-2341(P) - Ref. 39
344	7	7.1 Figure 7.1-7	Correction - minor / Fix 3 typos mislabeled in figure
345	7	7.1, 7.2	Editorial
346	7	7.2 Figure 7.2-5, Figures 7.2-25 thru 7.2-36	Editorial / Miscellaneous editorial corrections (including references) - plus change in titles of figures
347	7	7.2	Editorial / Update cross-references
348	7	7.2	Editorial / Clarify label for QN in equation
349	7	7.2.1.3.8	RAI / Changes associated with RAI Batch #RAI 103, Response to Question 16-142
350	7	7.3	Editorial / Miscellaneous editorial corrections - plus correction to titles of Figures 7.3-22, and 7.3-24
351	7	7.4	Editorial

Item	Chapter	Subsection	Type of Change
352	7	7.4.1.1	RAI / Changes associated with RAI Batch # 61, Suppl 2, Response to Question 07.04-1
353	7	7.4.1.1	RAI / Changes associated with RAI Batch #RAI 61, Response to Questions 07.04-3 and 07.04-7
354	7	7.4.1.1	RAI / Changes associated with RAI Batch #RAI 61, Suppl 1, Response to Questions 07.04-3, 07.04-5 and 07.04-7
355	7	7.5	Editorial
356	7	7.5.2.2.1, Table 7.5-1	RAI / Changes associated with RAI Batch #61, Suppl 3, Response to Question 07.05-3
357	7	7.5.2.1.1	Editorial / Change wording to add "Indication of " emergency feedwater flow is provided in the MCR.
358	7	7.5 Table 7.5-1	Editorial / Capitalization and abbreviations used in Table 7.5-1
359	7	7.5, 7.6, 7.7	Editorial
360	7	7.6	Editorial / Provide reference in text to associated figures.
361	7	7.6.1, Figure 7.6-3	RAI / Changes associated with RAI Batch #RAI 58, Suppl 1, Response to Questions 07.06-1, 07.06-2
362	7	7.6	Editorial
363	7	7.7	Editorial
364	7	7.7	Editorial
365	7	7.7.2.10	RAI / Changes associated with RAI Batch #RAI 57 Response to Question 07.07-14
366	7	7.8.1.1.3	RAI / Changes associated with RAI Batch #RAI 57 Response to Question 07.08-2
367	7	7.8	Editorial
368	8	8.1, 8.2, 8.3, 8.4	Editorial
369	8	8.1	Editorial
370	8	8.1	Editorial / Delete the "emergency" from EUPS name - per Acronym list, it should be Class 1E uninterruptible power supply
371	8	8.1	Correction - minor / Clarification of wording wrt compliance with RGs and industry standards for design of electrical systems
372		8.1, 8.3	RAI / Changes to FSAR associated with RAI Batch #11- in accordance with RAI Responses #08.03.01-12 and 08.03.01-16
373	8	8.1, 8.2, 8.3	Editorial / Some editorial comments and clarification
374		8.2.2.4	RAI / Changes to FSAR associated with RAI Batch #9- in accordance with RAI Response #08.01-3
375	8	8.2, 8.3	Editorial / Error in table placement; re-location and renumbering required
376	8	8.2	Editorial
377	8	8.3, 8.4	Editorial / Deletions referencing technical specifications
378	8	8.3.1.1	Editorial / Replace 'Diesel Building' with 'Emergency Power Generating Building'
379	8	8.3	RAI / Changes associated with RAI Batch #11, Suppl 2, Response to Questions 08.03.01-1 and 08.03.02-5
380	8	8.3.1.1	RAI / Changes associated with RAI Batch #110, Suppl 1, Response to Question 16-237
381	8	8.3.1	RAI / Changes associated with RAI Batch #11, Suppl 1, Response to Questions 08.03.01-5 and 08.03.01-6
382	8	8.3.1.1	RAI / Changes associated with RAI Batch #128, Suppl 1, Response to Question 14.03.06-18
383	8	8.3	RAI / Changes associated with RAI Batch #183, Suppl 1, Response to Questions 8.3.1-20, 8.3.1-22
384	8	8.3.1.3.8	Editorial / Reference to Table 8.3-4 changed to Figure 8.3-4 - [[Typical Station Grounding Grid]]
385	8	8.3.2.3	RAI / Changes associated with RAI Batch #116, Response to Question 14.03.06-6
386	8	8.3.2.3.2	Correction - minor /delete reference to "close and latch ratings" - based on RAI-related review

Item	Chapter	Subsection	Type of Change
387	8	8.3 Tables 8.3-4 thru 8.3-7	Correction - minor / Change to EDG nominal loads in Tables 8.3-4 thru 8.3-7 based on vendor info - (1) increase rating of KLC fans KLC41/42AN001 from 7 hp to 9 hp and change to sequenced load from manually connected load (and revise load subtotals), and (2) decrease ESW UHS fans rating from 300 hp to 250 hp - per WebCAP CR-2008-2658
388	8	8.3	Correction - minor / Correction of Alternate Feed Load kW number
389	8	8.3 Table 8.3-11	Correction - minor / In Table 8.3-11, correct nominal value for 12 UPS Batteries - change 3616 AH at 12-hour rate to 1808 AH
390	8	8.3 Figures 8.3-2 (Sht 3 of 3), 8.3-3 (Sht 1 of 4, Sht 3 of 4), & 8.3-5	Correction - minor / Fix typographical errors in figures — per WebCAP CR 2008-6833
391	8	8.3	Editorial
392	8	8.3	RAI / Changes associated with RAI Batch #RAI 70, Supp. 1, Response to Question 08.03.01-17
393	8	8.3 Figure 8.3-3	Correction - minor / Fix normal power supply non-class 1E 480V load center in drawing
394	8	8.4.1.1	RAI / Changes associated with RAI Batch #RAI 116, Response to Question 14.03.06-7
395	8	8.4.2.6	RAI / Changes associated with RAI Batch #RAI 70, Suppl 1, Response to Question 08.04-7
396	8	8.4.1.4	Editorial / Add reference to NUMARC87-00 as a source for the testing interval frequency for the SBODGs of every 3 months
397	8	8.4.3	Editorial / Update references in 8.4 for consistency with other reference sections
398	8	8.4.2.6	RAI / Changes associated with RAI Batch #216, Response to Question 08.04-9
399	8	8.4	Editorial
400	9	9.1	RAI / Changes associated with RAI Batch # 84, Suppl 2, Response to Questions 09.01.02-2 and 09.01.02-11
401	9	9.1	RAI / Changes associated with RAI Batch #RAI 84, Suppl 1, Response to Question 09.01.02-7
402	9	9.1	RAI / Changes associated with RAI Batch #RAI 84, Suppl 1, Response to Question 09.01.02-16
403	9	9.1	RAI / Changes associated with RAI Batch #86, Response to Question 09.01.02-20
404	9	9.1	RAI / Changes associated with RAI Batch #84, Response to Questions 09.01.02-4, 09.01.02-8, 09.01.02-10
405	9	9.1	RAI / Changes associated with RAI Batch #87, Suppl 1, Response to Question 09.01.03-4
406	9	9.1	RAI / Changes associated with RAI Batch #86, Response to Question 09.01.03-3
407	9	9.1	RAI / Changes associated with RAI Batch #87, Response to Question 09.01.03-6
408	9	9.1	RAI / Changes associated with RAI Batch #87, Response to Question 09.01.03-5
409	9	9.1	RAI / Changes associated with RAI Batch #87, Response to Question 09.01.03-8
410	9	9.1	RAI / Changes associated with RAI Batch #87, Suppl 2, Response to Question 09.01.03-7
411	9	9.1	RAI / Changes associated with RAI Batch #131, Response to Question 09.01.04-2
412	9	9.1	RAI / Changes associated with RAI Batch #131, Suppl 3, Response to Questions 09.01.04-1b, 09.01.04-4, 09.01.04-8
413	9	9.1	RAI / Changes associated with RAI Batch #173, Response to Questions 09.01.05-2, 09.01.05-3

Item	Chapter	Subsection	Type of Change
414	9	9.1.2	Correction - minor / Clarify minimum boric acid concentration in spent fuel pool - per WebCAP 2008-3516
415	9	9.1.3	Editorial
416	9	9.1.3	Editorial
417	9	9.1.3	Correction - moderate / Technical Issue concerning the normal mode of refueling - shuffle vs. full-core offload - per WebCAP#2008-1846.
418	9	9.1.4	Editorial / Correct cross-reference to cask drop accidents based on change in Chapter 15 - this is now discussed in Section 15.0.3 (per March 2007 update to SRP 15.0.3); replace cross-reference to 15.7 with 15.0.3.10.
419	9	9.1.5	Correction - minor / Add clarification wording to design bases of 9.1.5 as follows: "The control of heavy loads in the Fuel Building meets the guidance presented in RG 1.13, position C.5."
420	9	9.1.5	Editorial
421	9	9.1.5	Editorial / Correct cross-reference to cask drop accidents based on change in Chapter 15 - this is now discussed in Section 15.0.3 (per March 2007 update to SRP 15.0.3); replace cross-reference to 15.7 with 15.0.3.10.
422	9	9.2	RAI / Changes associated with RAI Batch #131, Suppl 1, Response to Question 09.02.01-25
423	9	9.2.1	RAI / Changes associated with RAI Batch #119, Suppl 3, Response to Question 09.02.01-24
424	9	9.2.1.4.1	Correction - minor / Clarification to indicate that during standby, the divisions not in operation are aligned for normal operation (i.e., <u>manual</u> valves in the main line are open)...."
425	9	9.2	RAI / Changes associated with RAI Batch #119, Suppl 1, Response to Questions 09.02.01-1, 09.02.01-2, 09.02.01-4 (parts g and k), 09.02.01-9 and 09.02.01-11
426	9	9.2	RAI / Changes associated with RAI Batch #119, Response to Question 09.02.01-13
427	9	9.2	RAI / Changes associated with RAI Batch #174, Response to Questions 09.02.02-10(a), 09.02.02-10(c), 09.02.02-10(d) and 09.02.02-17
428	9	9.2	RAI / Changes associated with RAI Batch #174, Suppl 2, Response to Questions 09.02.02-11, 09.02.02-16, 09.02.02-18, 09.02.02-19, 09.02.02-25, 09.02.02-30, 09.02.02-34
429	9	9.2	RAI / Changes associated with RAI Batch #87, Suppl 3, Response to Question 09.02.04-1
430	9	9.2	RAI / Changes associated with RAI Batch #119, Suppl 1, Response to Question 09.02.01-7
431	9	9.2.1 Figure 9.2.1-1 (Sheet 1 of 4)	Editorial / Figure cleanup (Change component symbol, remove flanges, remove redundant building walls)
432	9	9.2.1	Editorial
433	9	9.2.2	Editorial
434	9	9.2.5	Correction - minor / Add clarification wording to design bases of 9.2.5 to include reference to GDC46 as follows: "The UHS is designed to permit operational functional testing of safety-related components to ensure system operability (GDC 46)."
435	9	9.2.5	Editorial
436	9	9.2.7	Editorial
437	9	9.2	RAI / Changes associated with RAI Batch #163, Suppl 1, Response to Questions 09.02.02-1, 09.02.02-3, 09.02.02-4 (Parts 1, 3, 4, and 5), 09.02.02-5 (Parts 1, 2 and 4), 09.02.02-6
438	9	9.2	RAI / Changes associated with RAI Batch #169, Response to Question 09.02.05-2
439	9	9.3	RAI / Changes associated with RAI Batch #84, Response to Question 09.03.01-1
440	9	9.3.1 Figure 9.3.1-2	Correction - minor / Updated Figure 9.3.1-2 (Compressed Air System) to reflect most recent design changes - per WebCAP 2008-1471
441	9	9.3.2	Editorial / revise cross-reference to Tech Specs

Item	Chapter	Subsection	Type of Change
442	9	9.3	RAI / Changes associated with RAI Batch #113, Suppl 1, Response to Question 09.03.02-8
443	9	9.3	RAI / Changes associated with RAI Batch #113, Response to Questions 09.03.02-2, 09.03.02-3, 09.03.02-5, 09.03.02-7
444	9	9.3	RAI / Changes associated with RAI Batch #127, Suppl 1, Response to Question 14.02-54
445	9	9.3.2 Table 9.3.2-2	Correction- minor / Add pH monitors to the samples taken from the SG Blowdown system [per EPRI recommendations].
446	9	9.3	RAI / Changes associated with RAI Batch #131, Suppl1, Response to Question 09.02.01-25
447	9	9.3	RAI / Changes associated with RAI Batch #163, Response to Question 09.03.03-1
448	9	9.3.4	Editorial / Revise cross-reference to Tech Specs
449	9	9.3	RAI / Changes associated with RAI Batch #125, Response to Questions 09.03.04-1, 09.03.04-2, 09.03.04-3, 09.03.04-4, 09.03.04-7, 09.04.03-12, 09.03.04-13, 09.03.04-14, 09.03.04-18
450	9	9.3.4	Editorial / Provide clarification and cross-reference for how the CVCS mitigates a reactor coolant inventory increase event (refer to Section 15.5.2) and how the CVCS mitigates a boron dilution event (refer to Section 15.4.6)
451	9	9.3	RAI / Changes associated with RAI Batch #163, Suppl 1, Response to Question 09.02.02-5 (Parts 1 and 3)
452	9	9.3.4 Figure 9.3.4-1 (Sheet 6 of 9)	Editorial / Figure cleanup (Wrong HX type)
453	9	9.3.4 Figure 9.3.4-2 (Sheet 2 of 5)	Editorial / Figure cleanup (Correct line symbol) Should be sludge
454	9	9.3.4 Figure 9.3.4-2 (Sheet 4 of 5)	Editorial / Figure cleanup (Correct line symbol). Should be sludge
455	9	9.3.4 Figure 9.3.4-2 (Sheet 5 of 5)	Editorial / Figure cleanup (Correct line symbol). Should be sludge
456	9	9.4.1	RAI / Changes associated with RAI Batch #89, Suppl 1, Response to Question 06.04-3
457	9	9.4.1	RAI / Changes associated with RAI Batch #89, Response to Question 06.04-4
458	9	9.4	RAI / Changes associated with RAI Batch #135, Suppl 1, Response to Questions 09.04.05-1.1, 09.04.05-1.2, 09.04.05-1.3, 09.04.05-1.4, 09.04.05-1.5, 09.04.05-1.7 and 09.04.05-1.13
459	9	9.4.1	Correction - minor / Add clarification wording to design bases of 9.4.1 (CRACS) as follows: "Consideration of the environmental and dynamic effects of internal and external missiles and postulated piping failures on the CRACS is addressed in Section 3.5.1.1, Section 3.5.2, and Section 3.6.1."
460	9	9.4.1.2.3	RAI / Changes associated with RAI Batch #89, Suppl 1, Response to Question 06.04-3
461	9	9.4.2	Correction - minor / Add clarification wording to design bases of 9.4.2 (FBVS) as follows: "RG 1.52 is not applicable because the FBVS is not required to operate during post-accident engineered safety features (ESF) atmospheric cleanup."
462	9	9.4.2 Figure 9.4.2-1	Editorial / Figure cleanup (Correct heater symbol)
463	9	9.4.3 Figure 9.4.3-1	Editorial / Figure cleanup (Correct heater symbol and impact separators)
464	9	9.4.3 Figure 9.4.3-5	Editorial / Figure cleanup (Correct HEPA filters - rotate 180 degrees)
465	9	9.4.5	RAI / Changes associated with RAI Batch #135, Response to Question 09-04.05-1

Item	Chapter	Subsection	Type of Change
466	9	9.4.5	Correction - minor / Add clarification wording to design bases of 9.4.5 (SBVS) as follows: "Refer to Section 3.5.1.1, Section 3.5.1.4, Section 3.5.2, and Section 3.6.1 for information on compliance with GDC 4 as it relates to protection from missiles and postulated piping failures."
467	9	9.4.5	Editorial
468	9	9.4.5	Editorial / Standardization of how references are cited
469	9	9.4.6	Editorial
470	9	9.4.6 Figure 9.4.6-1	Editorial / Figure cleanup (Correct heater symbol)
471	9	9.4.6 Figure 9.4.6-3	Editorial / Figure cleanup (Correct heater symbol)
472	9	9.4.7	Editorial
473	9	9.4.7 Figure 9.4.7-2	Editorial / Figure cleanup (Rotate HEPA Filters 180 degrees and change flow element from "F" to "FE")
474	9	9.4.7 Figure 9.4.7-3	Editorial / Figure cleanup (Rotate HEPA Filters 180 degrees and change flow element from "F" to "FE")
475	9	9.4.7 Figure 9.4.7-4	Editorial / Figure cleanup (Correct damper symbol and impact separators)
476	9	9.4.8	Editorial
477	9	9.4.8 Figure 9.4.8-1	Editorial / Figure cleanup (Correct heater symbol and impact separators)
478	9	9.4.9	Editorial
479	9	9.4.10	Editorial
480	9	9.4.12	Editorial
481	9	9.4.12 Figure 9.4.12-1	Editorial / Figure cleanup (Correct symbol for HX and impact separators)
482	9	9.4.13	Editorial
483	9	9.4.14 Figure 9.4.14-1	Editorial / Figure cleanup (Correct symbol for heater and impact separators; add KLD to KKS legend)
484	9	9.5	RAI / Changes associated with RAI Batch #25, Response to Questions 09.05.01-39, 09.05.01-41, 09.05.01-43 thru 48, 09.05.01-50, 09.05.01-52
485	9	9.5	RAI / Changes associated with RAI Batch #25, Suppl 1, Response to Questions 09.05.01-37 and 09.05.01-53
486	9	9.5	Correction - minor / Add paragraph to address compliance with NFPA 804; wording is consistent with guidance in RG 1.189
487	9	9.5	RAI / Changes associated with RAI Batch #151, Response to Questions 09.05.01-54, 09.05.01-57, 09.05.01-59, 09.05.01-61, 09.05.01-62, 09.05.01-64, 09.05.01-65
488	9	9.5	RAI / Changes associated with RAI Batch #169, Response to Question 09.02.01-67
489	9	9.5	RAI / Changes associated with RAI Batch #196, Response to Question 09.05.01-68
490	9	9.5	RAI / Changes associated with RAI Batch #114, Response to Question 09.05.03-20
491	9	9.5	RAI / Changes associated with RAI Batch #152, Response to Questions 09.05.04-9, 09.05.04-10, 09.05.04-16
492	9	9.5	RAI / Changes associated with RAI Batch #152, Suppl 1, Response to Questions 09.05.04-7, 09.05.04-11, 09.05.04-13
493	9	9.5	RAI / Changes associated with RAI Batch #159, Suppl 1, Response to Question 09.05.05-1
494	9	9.5	RAI / Changes associated with RAI Batch #159, Response to Questions 09.05.05-3, 09.05.05-5
495	9	9.5	RAI / Changes associated with RAI Batch #131, Suppl 2, Response to Questions 09.05.06-1, 09.05.06-2, 09.05.06-5, 09.05.06-8
496	9	9.5	RAI / Changes associated with RAI Batch #131, Response to Question 09.05.06-3

Item	Chapter	Subsection	Type of Change
497	9	9.5	RAI / Changes associated with RAI Batch #87, Suppl 4, Response to Question 09.05.07-2
498	9	9.5	RAI / Changes associated with RAI Batch #87, Suppl 2, Response to Question 09.05.07-5
499	9	9.5	RAI / Changes associated with RAI Batch #87, Response to Questions 09.05.07-6 and 09.05.07-10
500	9	9.5	RAI / Changes associated with RAI Batch #74, Suppl 2, Response to Question 16-28
501	9	9.5	RAI / Changes associated with RAI Batch #145, Response to Questions 09.05.08-4, 09.05.08-5 and 09.05.08-8
502	9	9.5	RAI / Changes associated with RAI Batch #145, Suppl 1, Response to Questions 09.05.08-1, 09.05.08-2, 09.05.08-6, 09.05.08-9 and 09.05.08-10
503	9	9.5.1	RAI / Changes to FSAR associated with RAI Batch #20 - in accordance with RAI Responses #09.05.01-1, 09.05.01-2, 09.05.01-3, 09.05.01-9, 09.05.01-10, 09.05.01-11, 09.05.01-13, 09.05.01-14, 09.05.01-15, 09.05.01-16, 09.05.01-17, 09.05.01-19, 09.05.01-20, 09.05.01-21, 09.05.01-22, 09.05.01-33, 09.05.01-34, and 09.05.01-35
504	9	9.5.1	Correction - minor / Correct Date of NFPA Codes in References
505	9	9.5.1 Figure 9.5.1-1 (Sheet 2 of 13)	Editorial / Figure cleanup (Show diesel fuel lines and double lines)
506	9	9.5.1 Figure 9.5.1-1 (Sheet 8 of 13)	Editorial / Figure cleanup (Rotate safety relief valve 90 degrees)
507	9	9.5.2	RAI / Changes to FSAR associated with RAI Batch #36 - in accordance with RAI Responses 09.05.02-5, 09.05.02-6, and 09.05.02-11
508	9	9.5.2	RAI / Correction of Regulatory citation - NRC courtesy notification during RAI clarification call on 7/24 (NOTE: SRP also has typing error)
509	9	9.5.3	RAI / Changes to FSAR associated with RAI Batch #19 - in accordance with RAI Responses 9.5.3-5, 9.5.3-9, 9.5.3-11, 9.5.3-16, & 9.5.3-17
510	9	9.5	RAI / Changes associated with RAI Batch #74, Suppl 1 Response to Question 16-29
511	9	9.5.4	Editorial
512	9	9.5.5	Editorial
513	9	9.5.5 Figure 9.5.5-1 (Sheet 1 of 2)	Editorial / Figure cleanup (Correct symbol for HX)
514	9	9.5.6	Editorial
515	9	9.5.7	Editorial
516	9	9.5.7 Figure 9.5.7-1	Editorial / Figure cleanup (Correct symbol for HX and remove redundant pressure transmitters)
517	9	9.5.8	Editorial
518	9	9A	Editorial / SUNSI - Delete OUO note on bottom of selected public pages
519	9	9A	Editorial
520	9	9A.4	Editorial / Delete IEEE 383 reference (not in App. 9A)
521	9	9A	RAI / Changes to FSAR associated with RAI Batch #20 - in accordance with RAI Response 09.05.01-20
522	9	9A	RAI / Changes associated with RAI Batch #20, Suppl 1 Response to Question 09.05.01-4
523	9	9A	RAI / Changes associated with RAI Batch #151, Response to Questions 09.05.01-55, 09.05.01-56, 09.05.01-64
524	10	10.1	RAI / Changes associated with RAI Batch #91, Suppl 3, Response to Questions 91-S3, 100-S2, 106-S1
525	10	10.1	RAI / Changes associated with RAI Batch #100, Suppl 2, Response to Questions 91-S3, 100-S2, 106-S1
526	10	10.1	RAI / Changes associated with RAI Batch #106, Suppl 1, Response to Questions 91-S3, 100-S2, 106-S1
527	10	10.1.3	Editorial

Item	Chapter	Subsection	Type of Change
528	10	10.2.2	Editorial / Correct typo -delete number '18'
529	10	10.2	RAI / Changes associated with RAI Batch #91, Suppl 3, Response to Questions 91-S3, 100-S2, 106-S1
530	10	10.2	RAI / Changes associated with RAI Batch #100, Suppl 2, Response to Questions 91-S3, 100-S2, 106-S1
531	10	10.2	RAI / Changes associated with RAI Batch #106, Suppl 1, Response to Questions 91-S3, 100-S2, 106-S1
532	10	10.2	RAI / Changes associated with RAI Batch #91, Suppl 1 Response to Question 10.02-2
533	10	10.2	RAI / Changes associated with RAI Batch #91, Suppl 3, Response to Question 10.02-4
534	10	10.2.3	RAI / Changes to FSAR associated with RAI Batch #18 - in accordance with RAI Response 03.05.01.03-01
535	10	10.2	RAI / Changes associated with RAI Batch #100, Suppl 1 Response to Questions 10.02.03-1 thru 3, 10.02.03-5 thru 7
536	10	10.2	RAI / Changes associated with RAI Batch #100, Response to Questions 10.02.03-14
537	10	10.3	RAI / Changes associated with RAI Batch #101, Response to Question 16-86
538	10	10.3	RAI / Changes associated with RAI Batch #106, Response to Questions 10.3-1 (Part I, Part II and Part IV)
539	10	10.3	RAI / Changes associated with RAI Batch #127, Suppl 1, Response to Question 14.02-54
540	10	10.3	RAI / Changes associated with RAI Batch #44, Suppl 1 Response to Question 10.03.06-1
541	10	10.3	RAI / Changes associated with RAI Batch #44, Suppl 1 Response to Question 10.03.06-5
542	10	10.3	RAI / Changes associated with RAI Batch #165, Response to Questions 10.03.06-7, 10.03.06-8, 10.03.06-9, 10.03.06-10
543	10	10.3	RAI / Changes associated with RAI Batch #44, Suppl 1 Response to Question 10.03.06-3
544	10	10.3	RAI / Changes associated with RAI Batch #44, Suppl 1 Response to Question 10.03.06-4
545	10	10.3	RAI / Changes associated with RAI Batch #91, Suppl 3 Response to Questions 91-S2, 100-S2, 106-S1
546	10	10.3	RAI / Changes associated with RAI Batch #100, Suppl 2 Response to Questions 91-S2, 100-S2, 106-S1
547	10	10.3	RAI / Changes associated with RAI Batch #106, Suppl 1 Response to Questions 91-S2, 100-S2, 106-S1
548	10	10.3.1 Figure 10.3-1 (Sheet 1 of 2)	Editorial / Figure cleanup (Change flow element from "F" to "FE", and fix penetrations)
549	10	10.4	RAI / Changes associated with RAI Batch #127, Suppl 1, Response to Question 14.02-54
550	10	10.4	RAI / Changes associated with RAI Batch #112, Suppl 1, Response to Question 10.04.3-1
551	10	10.4	RAI / Changes associated with RAI Batch #83, Response to Questions 10.04-05-1; 10.0407-3, 10.04.01-1, 10.04.02-1, 10.04.07-1, 10.04.09-6, 10.04.09-11, 10.04.09-8, 10.04.09-2, 10.04.09-3, 10.04.09-7
552	10	10.4	RAI / Changes associated with RAI Batch #91, Suppl 3 Response to Questions 91-S2, 100-S2, 106-S1
553	10	10.4	RAI / Changes associated with RAI Batch #100, Suppl 2 Response to Questions 91-S2, 100-S2, 106-S1
554	10	10.4	RAI / Changes associated with RAI Batch #106, Suppl 1 Response to Questions 91-S2, 100-S2, 106-S1

Item	Chapter	Subsection	Type of Change
555	10	10.4	RAI / Changes associated with RAI Batch #83, Suppl 1 Response to Question 10.04.09-1
556	10	10.4	RAI / Changes associated with RAI Batch #83, Suppl 4 Response to Question 10.04.09-5
557	10	10.4.5 Figure 10.4.5-1	Editorial / Change figure title (title listed in text is correct)
558	10	10.4.7 Figure 10.4.7-1 (Sheet 2 of 2)	Editorial / Figure cleanup (Correct symbol for angle check valves, fix penetrations)
559	10	10.4.8 Figure 10.4.8-1 (Sht 2 of 3), Figure 10.4.8-1 (Sht 3 of 3), Figure 10.4.8-2 (Shts 1 - 4)	Revise S/G Blowdown System (LCQ) figures - editorial and for consistency with other FSAR figures, delete maintenance and testing lines and valves, consolidation of duplicate design areas, and editorial change to title of Fig. 10.4.8-2 per WebCAP 2008-6141-CR.
560	10	10.4.8 Figure 10.4.8-2 (Sht 2 of 4)	Editorial / Figure cleanup (Correct line symbol)
561	10	10.4.8 Figure 10.4.8-2 (Sht 3 of 4)	Editorial / Figure cleanup (Correct line symbol)
562	10	10.4.8 Figure 10.4.8-2 (Sht 3 of 4)	Correction - minor / Figure change - See WebCAP 2008-3924-CR - piping routing
563	10	10.4.9.4	Editorial / Clarification of reference to technical specifications (Ch16)
564	11	11.1.2.2	Correction - minor / Clarify text to reflect a response to a Chapter 12 RAI (RAI Batch 150, Question 12.02-1). The RAI response should have also updated this wording in Chapter 11 concerning the shielding evaluation source term for normal operations.
565	11	11	Editorial / Editorial changes from "page turn"
566	11	11	Editorial
567	11	11.2	RAI / Changes associated with RAI Batch #105, Suppl 1, Response to Question 11.02-3
568	11	11.2	Correction - moderate / Delete reference to NEI Generic Cost Benefit Analysis - NEI 07-11 is no longer being reviewed by NRC - also add COL item to compare typical site against specific COL applicant's site
569	11	11.2 Figure 11.2-1	Editorial / Figure cleanup (Correct Design Area Table)
570	11	11.2 Figure 11.2-2	Editorial / Figure cleanup (Correct Design Area Table, and centrifuge symbol)
571	11	11.2 Figure 11.2-3	Editorial / Figure cleanup (Correct Design Area Table)
572	11	11.3	RAI / Changes associated with RAI Batch #105, Response to Question 11.03-2
573	11	11.3	Correction - moderate / Delete reference to NEI Generic Cost Benefit Analysis - NEI 07-11 is no longer being reviewed by NRC - also add COL item to compare typical site against specific COL applicant's site
574	11	11.3 Table 11.3-7	RAI / Changes to FSAR associated with RAI Batch #10 - updated annual average X/Q value for consistency with Table 2.1-1 and 11.3-4 - in accordance with RAI Response to 02.03.05-4
575	11	11.3 Figure 11.3-1	Editorial / Figure cleanup (Correct Design Area Table from SI to I; correct compressor orientation)
576	11	11.5.4.6	Editorial / Clarification of reference to technical specifications (Ch16)
577	11	11.4	RAI / Changes associated with RAI Batch #105, Response to Questions 11.04-1, 11.04-2
578	12	12	Editorial

Item	Chapter	Subsection	Type of Change
579	12	12.5	RAI / Changes associated with RAI Batch #192, Response to Question 12.05-1
580	12	12.1, 12.3	RAI / Changes associated with RAI Batch #164, Suppl 1, Response to Question 12.03-12.04-8
581	12	12.3	RAI / Changes associated with RAI Batch #105, Response to Question 11.04-4
582	12	12.3	RAI / Changes associated with RAI Batch #150, Response to Questions 12.02-1(2), 12.03-12.04-7, 12.03-12.04-5(2)
583	12	12	Editorial
584	12	12.2	RAI / Changes associated with RAI Batch #150, Response to Question 12.02-2(b)
585	12	12.3	RAI / Changes associated with RAI Batch #136, Suppl 1, Response to Question 12.03-12.04-2
586	12	12.3	RAI / Changes associated with RAI Batch #43, Suppl 2, Response to Question 14.03.08-1
587	12	12.3 Figure 12.3-72	Editorial / Figure cleanup (Correct lines through grates, impact separators, include Design Area Table)
588	12	12.3 Figure 12.3-73	Editorial / Figure cleanup (Change label to 'KLC Accident Exhaust', include Design Area Table).
589	12	12.3 Figure 12.3-74	Editorial / Figure cleanup (Correct lines through grates, impact separators, include Design Area Table)
590	12	12.5	RAI / Changes associated with RAI Batch #214, Response to Question 12.05-2
591	13	13.5.2.1.1	Editorial
592	13	13.6	RAI / Changes associated with RAI Batch #42, Response to Question 14.03.12-1
593	13	13.6	Correction - minor / Fix FSAR markup for 13.6 - Items 1 and 4 from RAI 42, Supplement 1. The sentences were incomplete as originally written in the RAI response.
594	14	14.2	RAI / Changes to FSAR associated with RAI Batch #16 in accordance with RAI Responses to 14.02-2 thru 14.02-4, and 14.02-6 thru 14.02-17
595	14	14.2	RAI / Changes associated with RAI Batch #143, Suppl 1, Response to Question 14.02-64
596	14	14.2.10.2	RAI / Changes associated with RAI Batch #68, Suppl 1, Response to Question 14.02-23
597	14	14.2.11	RAI / Changes associated with RAI Batch #189, Response to Question 14.2-95
598	14	14.2.12	RAI / Changes associated with RAI Batch #87, Suppl 2, Response to Question 09.01.03-10
599	14	14.2	RAI / Changes associated with RAI Batch #68, Response to Questions 14.02-19, 14.02-20, 14.02-21, 14.02-22, 14.02-24, 14.02-25, 14.02-26, 14.02-27, 14.02-29 and 14.02-30
600	14	14.2	RAI / Changes associated with RAI Batch #98, Response to Questions 14.02-39, 14.02-41, 14.02-42, 14.02-44, 14.02-45, 14.02-46, 14.02-47, 14.02-48, 14.02-49, 14.02-51
601	14	14.2	RAI / Changes associated with RAI Batch #158, Response to Questions 14.02-80, 14.02-83, 14.02-84, 14.02-86, 14.02-87, 14.02-88, 14.02-89, 14.02-90, 14.02-91
602	14	14.2.12.3.14	RAI / Changes associated with RAI Batch #117, Response to Question 05.04.11-7
603	14	14.2.12.5.8	RAI / Changes associated with RAI Batch #176, Response to Question 14.02-94
604	14	14.2.12.8.10	RAI / Changes associated with RAI Batch #89, Response to Question 06.04-4
605	14	14.2.12.13	RAI / Changes associated with RAI Batch #11, Suppl 1, Response to Question 08.03.01-7
606	14	14.2	RAI / Changes associated with RAI Batch 144, Response to Questions 14.02-73, 14.02-74 and 14.02-75
607	14	14.2	RAI / Changes associated with RAI Batch 77, Response to Questions 14.02-33 and 14.02-31

Item	Chapter	Subsection	Type of Change
608	14	14.2	RAI / Changes associated with RAI Batch 77, Suppl 1, Response to Question 14.2-32
609	14	14.2	RAI / Changes associated with RAI Batch #143, Response to Questions 14.02-61, 14.02-62, 14.02-63, 14.02-66, 14.02-67, 14.02-68, 14.02-70, 14.02-71
610	14	14.2	RAI / Changes associated with RAI Batch #85, Suppl 1, Response to Question 14.02-36
611	14	14.2.12.5.5	RAI / Changes associated with RAI Batch #174, Suppl 2, Response to Question 09.02.02-23
612	14	14.2	RAI / Changes associated with RAI Batch #127, Response to Questions 14.02-52, 14.02-53, 14.02-55, 14.02-57, 14.02-58, 14.02-59
613	14	14.2.12.3.6	RAI / Changes associated with RAI Batch #85, Response to Question 14.02-35
614	14	14.2.12.9.16	RAI / Changes associated with RAI Batch #87, Response to Question 09.05.07-9
615	14	14.2	RAI / Changes associated with RAI Batch #145, Response to Question 09.05.08-7
616	14	14.2	Correction- minor / Miscellaneous editorial clarifications and corrections/deletions of some items[for Test #14 - delete 'throttle capability of the discharge valve shall be verified over its full operating range';for Test #15 - delete 2.6 prerequisite, and requirement to "verify the setpoint of LTOP relief valves (3.7), and data item #4.5; for Test#225, delete Test items 3.3 and 3.4 since these are not associated with NRC requirements for potable and sanitary water].
617	14	14.2	Editorial / Clarification of reference to technical specifications (Ch16)
618	14	14.2	Editorial change to wording of COL items for circulating water supply system and cooling tower [to state provide site-specific "test abstract" information]; add COL item that was inadvertently omitted for the raw water supply system.
619	14	14.2.12.8.10	RAI / Changes associated with RAI Batch #RAI 135, Suppl 1, Response to Question 09.04.05-1.1
620	14	14.2.12.9.16	RAI / Changes associated with RAI Batch #RAI 131, Response to Question 09.05-06-6
621	14	14.2.12.11.7	RAI / Changes associated with RAI Batch #RAI 36, Suppl 1 Response to Question 09.05-02-10
622	14	14.2.12.13.14	RAI / Changes associated with RAI Batch #91, Suppl 1 Response to Question 10.02.-2
623	14	14.2.12.21.4, 14.2.12.21.7	RAI / Changes associated with RAI Batch #09, Suppl 1, Response to Question 08-02-6
624	14	14.2.12	RAI / Changes associated with RAI Batch #134, Response to Question 04.03-16
625	14	14.2.12	RAI / Changes associated with RAI Batch #46, Suppl 1, Response to Question 14.02-18
626	14	14.2.12.12	RAI / Changes associated with RAI Batch #106, Response to Question 10.3-1 (Part III)
627	14	14.2.12.21.4	RAI / Changes associated with RAI Batch #216, Response to Question 08.02-7
628	14	14.3.2	RAI / Changes associated with RAI Batch #116, Response to Question 14.03.06-12
629	14	14.3.2	RAI / Changes associated with RAI Batch #43, Suppl 2, Response to Question 14.03.08-1
630	14	14.2, 14.3	Editorial
631	14	14.2, 14.3	Editorial / Correct system name and acronym for ventilation system for SBO Diesels (should be Switchgear Building Ventilation System - SGBVS), and ITP
632	14	14.2.13, 14.3.6	Editorial
633	14	14.2	RAI / Changes associated with RAI Batch #127, Response to Question 14.02-54
634	14	14.3.5	RAI / Changes associated with RAI Batch #115, Response to Question 14.03.02-9
635	14	14.3, Table 14.3-1	RAI / Changes associated with RAI Batch #123 Response to Question 14.03.03-9

Item	Chapter	Subsection	Type of Change
636	14	14.3, Table 14.3-1	RAI / Changes associated with RAI Batch #128, Suppl 2, Response to Question 14.03.03-11
637	14	14.3.2.3, Table 14.3-8	RAI / Changes associated with RAI Batch #78 Response to Questions 14.03.05-5 and 14.03.05-6
638	14	14.3, Table 14.3-2, Table 14.3-6	RAI / Changes associated with RAI Batch #104 Response to Question 14.03.11-2
639	14	14.3 Table 14.3-4	Editorial / Correct typo - item # in Table 14.3-4 should be 4-11 rather than 14-11.
640	14	14.3 Table 14.3-7	Editorial / ITAAC Screening Summary Table -Lightning protection
641	15	15	Editorial / Formatting
642	15	15 Table 15.1-11, Table 15.2-1, Table 15.2-7	Correction - minor / Editorial & minor corrections; these are also included in list of FSAR requested changes from WebCAP 2008-600 [correct 'SG 4' to 'SG 3' in Table 15.1-11 for RSRTs row; correct MSRT capacity from '1229.7 psia' to '1384.7 psia' per train in Table 15.2-1; delete 'Low and Low-Low SG level setpoint delay' rows and correct EFW flow rate in Table 15.2-7]
643	15	15.0.0.3.9	RAI / Changes associated with RAI Batch #34, Suppl 1, Response to Question 15-8
644	15	15.0.0.3	RAI / Changes associated with RAI Batch #34, Suppl 2 (Part 1 of 3), Response to Question 15-1 thru 5
645	15	15.0.3	RAI / Changes associated with RAI Batch #37, Response to Question 02.03.04-5
646	15	15.0.4	RAI / Changes associated with RAI Batch #83, Suppl 4, Response to Question 10.04.09-5
647	15	15 Table 15.0-8	Editorial / Add uncertainty and time delay entries stating "Not Applicable" in table for EBS for existing blank cells [per Quality Engineering Internal Surveillance FHS-07-05]
648	15	15 Table 15.0-14	Correction - minor / Correct transposition of design basis core radionuclide inventories for Y-92 and Y-93 per WebCAP 2008-3060
649	15	15 Table 15.0-11	Correction - minor / Correct Failure mechanism column for 15.5 - Increase in RCS Inventory Events. Per Web 2008-2593, the single failure assumed for these events should be "Closure of one MSRCV when MSRIV opens" rather than "EFW train" - consistent with response to RAI #34, Questions 15-1, 15.0-4 and 15-5.
650	15	15.0.3.9 Table 15.0-40	RAI / Changes to FSAR associated with RAI Batch #17 - Corrections to input for Rod Ejection Accident - should indicate 4% of cladding failure for full-rod fuel overheat, rather than 0.4% - in accordance with RAI Response 15.00.03-16
651	15	15.0 - 15.6, 15.3 Table 15.0-11, Table 15.1-4, Table 15.1-16, Figure 15.6-12	Correct failure mechanism for 'Increase in RCS Inventory Events' in Table 15.0-11 from failure of "EFW Train" to "Closure of one MSRCV when MSRIV opens"; ; provide BOC reactivity input values rather than EOC in Table 15.1-4, provide HZP limiting values in MSLB Table 15.1-16 rather than HFP values; editorial corrections to specify "Delta DNBR" rather than "DNBR" in Section 15.3; editorial update to title in Figure 15.6-12, and other editorial changes --- based on WebCAP 2008-2593
652	15	15.0 - 15.4	Editorial
653	15	15.1.4.1	RAI / Changes associated with RAI Batch #106, Response to Question 10.3-1 (Part III)
654	15	15.1 Table 15.1-1, Table 15.1-4, Table 15.1-7, Table 15.1-10	RAI / Changes to FSAR associated with RAI Batch #34 - Revision/Clarification to units of Scram worth from "pcm/F" to "pcm" in Tables 15.1-1, 15.1-4, 15.1-7, and 15.1-10 - in accordance with RAI Responses 15.01.01 - 15.01.04-2, 15.01.01 - 15.01.04-7
655	15	15.1 Table 15.1-11	Correction - minor / Change from 'SG 4' to 'SG 3' for MSRT Status entry to indicate that SG 3 MSRCV is failed open [per Quality Engineering Internal Surveillance FHS-07-05 and WebCAP 2008-600]

Item	Chapter	Subsection	Type of Change
656	15	15.1	RAI / Changes associated with RAI Batch #34, Suppl 2 (Part 1 of 3), Response to Questions 15-1, 15-2, 15-5
657	15	15.1	RAI / Changes associated with RAI Batch #34, Suppl 1, Response to Questions 15.01.01 - 15.01.04-1, 15.01.01 - 15.01.04-8, 15.01.01 - 15.01.04-11, 15.01.01 - 15.01.04-1, 15.01.05-3, 15.01.05-8, 15.01.05-9
658	15	15.1 Figure 15.1-20	Editorial / Editorial Correction to title of figure
659	15	15.2	Editorial / Internal review items
660	15	15.2 Table 15.2-1	Correction - minor / Clarify the pressure value given in the MSRT capacity entry - this is the corresponding pressure at the MSRIV (same value that is presented in Table 15.0-9) [per Quality Engineering Internal Surveillance FHS-07-05]
661	15	15.2 Table 15.2-7	Correction - minor / Typographical error to state that EFW flowrate decreases linearly to '124.5 gpm' rather than '1245 gpm' at 1568 psia; also delete low and low-low SG level setpoint delay times since these are in Tables 15.0-7 and 15.0-8 [per Quality Engineering Internal Surveillance FHS-07-05]
662	15	15.2	RAI / Changes associated with RAI Batch #34, Suppl 1, Response to Questions 15.02.01 - 15.02.05-7, 15.02.01 - 15.02.05-8, 15.02.06-1, 15.02.08-3
663	15	15.2	RAI / Changes associated with RAI Batch #34, Suppl 2 (Part 1 of 3), Response to Questions 15-1, 15-2, 15-4, 15-5, 15.02.01-1 - 15.02.05-1
664	15	15.3	Editorial / Quality review items
665	15	15.3	RAI / Changes associated with RAI Batch #34, Suppl 2 (Part 1 of 3), Response to Questions 15-1, 15-2, 15-4, 15-5, 15.03.03 -15.03.04-1, 15.03.03 - 15.03.04-4, 15.03.03 -15.03.04-5, 15.03.03 -15.03.04-7, 15.03.03 - 15.03.04-8
666	15	15.4.2	RAI / Changes associated with RAI Batch #29, Suppl 1, Response to Question 15.04.02-1
667	15	15.4	RAI / Changes associated with RAI Batch #34, Suppl 2 (Part 1 of 3), Response to Questions 15-1, 15-2, 15-4, 15-5
668	15	15.4.3.1.3	RAI / Changes associated with RAI Batch #29, Suppl 2, Response to Question 15.04.03-1
669	15	15.4 Table 15.4-4	RAI / Changes to FSAR associated with RAI Batch #29 - in accordance with RAI Responses 15.04.01-1, 15.04.01-2, 15.04.02-2, 15.04.04-15.04.05-1, 15.04.08-4: Added additional plots/figures of parameters for various postulated reactivity events, added scram reactivity to Table 15.4-4
670	15	15.4, Table 15.4-17, Table 15.4-18	Editorial / Correct FH to FΔH (F Delta H) in Tables 15.4-17 and 15.4-18
671	15	15.4 Figure 15.4-5	Editorial / Editorial correction to title of figure
672	15	15.5	Editorial / Quality review items discovered
673	15	15.5 - 15.8	Editorial
674	15	15.5	RAI / Changes associated with RAI Batch #34, Suppl 2 (Part 1 of 3), Response to Questions 15-1, 15-2, 15-4, 15-5
675	15	15.6.1	RAI / Changes associated with RAI Batch #34, Suppl 1, Response to Question 15.06.01-1
676	15	15.6	RAI / Changes associated with RAI Batch #34, Suppl 2 (Part 1 of 3), Response to Questions 15-1, 15-4, 15-5, 15.06.03-3
677	15	15.6	RAI / Changes associated with RAI Batch #34, Suppl 2 (Part 2 of 3), Response to Question 15.06.03-3
678	15	15.6	RAI / Changes associated with RAI Batch #34, Suppl 2 (Part 3 of 3), Response to Question 15.06.03-3
679	15	15.6 Fig. 15.6-26	Correction - minor / Technical Correction to title of figure - change to 'liquid' fractions instead of 'void' fractions
680	15	15.6.5.4	RAI / Changes associated with RAI Batch #30, Suppl 1, Response to Question 15.06.05-8
681	15	15.6	Editorial / Graphics enhancements for clarity

Item	Chapter	Subsection	Type of Change
682	15	15.6	Correction - minor / Include reference to new GSI-191 Technical Rpt - submitted Feb. 2008
683	15	15.6, Table 15.6-4 (Sht 2 of 2)	Editorial / Correction to a typo in parameter title for Table 15.6-4 (sheet 2 of 2) - "Low SG pressure MSIS setpoint" should be "Low SG pressure MSIV setpoint"
684	15	15.6, Table 15.6-20, Table 15.6-22, Table 15.6-23, Fig 15.6-51, Fig 15.6-82, Fig 15.6-83	Changes to SBLOCA tables and figures associated with WebCAP 2008-4618 - minor error in input value for loss coefficient at the accumulator junction for 2 of the loops - only impacts cases with breaks greater than 7.5 inches. Includes clarification to titles of figures
685	15	15.6, Figures 15.6-1 thru 15.6-10	Editorial / Fix Figure Titles to correspond with text in 15.6 - change IOPSV to IOPSRV
686	15	15.6 Figures 15.6-44 and 15.6-45	Editorial / Correction to title of figures
687	15	15.6 Figure 15.6-51	Editorial / Correction to title of figure
688	15	15.6 Figure 15.6-86 Figures 15.6-88 thru 15.6-91	Editorial / Graphics enhancements for clarity - Move Figures Down on page to allow more space between the figure title and the actual graph
689	15	15.7.5	Correction - minor / Since spent fuel cask drop accidents are now discussed in Section 15.0.3 (per March 2007 update to SRP 15.0.3), delete existing text in 15.7.5 and replace with a cross-reference to 15.0.3.10
690	15	15.0, 15.6	Editorial / Clarification of reference to technical specifications (Ch16)
691	16	16	Editorial / Change reference to U.S. EPR STS to U.S. EPR GTS (Generic Technical Specifications) in 16.0(x) and footers to all TS pages
692	16	16	Editorial / Based on Final rule in 09/24/08 issue of Federal Register (effective 10/24/08), NRC is restoring the original paragraph designations in 10 CFR 50.36 before the 2007 Part 52 final rulemaking - these changes change all references in FSAR from 10 CFR 50.36 (d) to 10 CFR 50.36(c)
693	16	16.1	Clarify COL item to indicate that the COL Applicant will "provide the necessary information in response to the Reviewer's Notes and replace preliminary information provided in brackets of the TS and TS Bases with plant-specific values." - per discussion with NRC and to facilitate inclusion of the Setpoint Control Program in COL Tech Specs.
694	16	16 (1.1)	RAI / Changes associated with RAI Batch #122, Suppl 1, Response to Question 16-243
695	16	16 (1.1)	Correction - minor /In 'Dose Equivalent I-131' definition, replace term "thyroid dose conversion factors" with "committed effective dose conversion factors" - for consistency with response to RAI 122, Question 16-256 and NRC approved generic Tech Spec changes in TSTF-490-A.
696	16	16 (1.1)	RAI / Changes associated with RAI Batch #103, Suppl 1, Response to Question 16-193
697	16	16 (1.1)	RAI / Changes associated with RAI Batch #63, Suppl 1, Response to Questions 05.04.02.02-7 and 05.04.02.02-8
698	16	16 (1.1, 1.2, 1.3, 1.4)	RAI / Changes associated with RAI Batch #122, Response to Questions 16-244, 16-245, 16-246, 16-256
699	16	16	Editorial [a portion of these reflect changes to TS Table 3.3.1-2 as specified in WebCAP 2008-1911]

Item	Chapter	Subsection	Type of Change
700	16	16 (2.0, B2.1)	RAI / Changes associated with RAI Batch #102, Response to Questions 16-125 and 16-127
701	16	16	Correction - minor / Miscellaneous editorial and non-editorial corrections, plus deletion of dates for regulations in bases references section.
702	16	16 (1.1, 3.3.1, 3.5, B3.3.1)	Correction - minor / Miscellaneous corrections - new definition for Protection System Response Time, add PS Response Time to 3.3.1 plus Surveillance, delete DOT definition (now have ADOT)
703	16	16	Correction - minor / Misc Changes and corrections
704	16	16	Resolution of customer comments
705	16	16	Correction - minor / Miscellaneous Corrections and internal comments resulting from WebCAP 2008-3445 additional review
706	16	16 (3.4.6, 3.4.8, 3.4.9, B3.1.6)	Editorial
707	16	16 (3.5.5 and B3.1.6)	Editorial
708	16	16 (B3.3.1)	Editorial
709	16	16 (3.7.12 and B3.3.1)	Editorial / Typo and correction to Reference number and title in B3.3.1
710	16	16	Editorial corrections
711	16	16 (3.6.6, B3.6.4, B3.7.6, B3.7.7, B3.7.10, B3.7.11, B3.7.12, B3.9.2)	Editorial / Miscellaneous editorial revisions (consistency, etc..)
712	16	16 (B3.1.4, B3.1.5, B3.1.6, B3.1.7, B3.2.1, B3.2.1, B3.2.2)	Editorial / Miscellaneous corrections
713	16	16 (3.7.1, B3.7.1, B3.7.4)	Correction - minor / Changes in response to WebCAP #2008-3445
714	16	16 (2.0)	RAI / Changes associated with RAI Batch #110, Suppl 1, Response to Question 16-241
715	16	16 (3.0)	RAI / Changes associated with RAI Batch #122, Response to Question 16-247
716	16	16	RAI / Changes associated with RAI Batch #122, Response to Questions 16-257, 16-258, 16-261, 16-265, 16-266, 16-268, 16-270
717	16	16	RAI / Changes associated with RAI Batch #122, Response to Questions 16-276, 16-278, 16-279, 16-282
718	16	16	RAI / Changes associated with RAI Batch #110, Response to Question 16-234
719	16	16	RAI / Changes associated with RAI Batch #110, Suppl 2, Response to Question 16-212
720	16	16 (3.3.1 & B3.3.1, and 5.5)	Clarify Tech Spec 3.3.1 to add a Reviewer's Note that the COL Applicant may revise the Protection System background, applicable safety analyses, LCO and Applicability, Actions and Surveillance Requirements sections to reflect the use of a Setpoint Control Program. - per discussion with NRC and to facilitate inclusion of the Setpoint Control Program in COL Tech Specs.
721	16	16 (3.3.1)	RAI / Changes associated with RAI Batch #103, Suppl 1, Response to Question 16-193
722	16	16 (3.3.1)	RAI / Changes associated with RAI Batch #103, Response to Questions 16-131, 16-132- 16-134, 16-135, 16-141, 16-166, 16-167, 16-170, 16-192
723	16	16 (3.3.1)	RAI / Changes associated with RAI Batch #110, Suppl 1, Response to Question 16-227
724	16	16 (3.3.2)	RAI / Changes associated with RAI Batch #101, Response to Question 16-100
725	16	16 (3.3.2)	RAI / Changes associated with RAI Batch #110, Suppl 1, Response to Question 16-212

Item	Chapter	Subsection	Type of Change
726	16	16 (3.4.2)	RAI / Changes associated with RAI Batch #122, Response to Question 16-258
727	16	16 (3.4.2, 3.4.6, 3.4.13, 3.4.16)	RAI / Changes associated with RAI Batch #101, Response to Questions 16-71, 16-73.2, 16-73.6, 16-73.13, 16-73.15 U-line and 16-75
728	16	16 (3.4.6, 3.4.11, 3.4.14)	RAI / Changes associated with RAI Batch #101, Suppl 1, Response to Questions 16-57, 16-69, 16-72, 16-77
729	16	16 (3.5.1, 3.5.2, 3.5.4, 3.5.5)	RAI / Changes associated with RAI Batch #101, Response to Questions 16-93, 16-95, 16-96, 16-98, 16-99, 16-101, 16-102, and 16-109
730	16	16 (3.5.3, 3.5.4, 3.5.6 3.5.7,	RAI / Changes associated with RAI Batch #142, Suppl 1, Response to Question 19-269
731	16	16 (3.6.3, 3.6.6, 3.6.7)	RAI / Changes associated with RAI Batch #101, Response to Questions 16-112, 16-113, 16-116, 16-122, 16-124
732	16	16 (3.6.4)	RAI / Changes associated with RAI Batch #122, Response to Question 16-249
733	16	16 (3.6.8)	RAI / Changes associated with RAI Batch #101, Suppl 1, Response to Question 16-61
734	16	16 (3.7.1, 3.7.3, 3.7.10, 3.7.15)	RAI / Changes associated with RAI Batch #101, Response to Questions 16-63, 16-86, 16-92, 16-109
735	16	16 (3.7.3)	Editorial / Add "AND" to Required Action for Condition B of LCO 3.7.3 - MFW Valves
736	16	16 (3.7.6, B3.7.6)	RAI / Changes associated with RAI Batch #83, Suppl 4, Response to Question 10.04.09-9
737	16	16 (3.7.10)	RAI / Changes associated with RAI Batch #89, Response to Question 06.04-4
738	16	16 (3.7.10)	RAI / Changes associated with RAI Batch #122, Response to Question 16-250
739	16	16 (3.7.5, 3.7.6)	RAI / Changes associated with RAI Batch #83, Suppl 1, Response to Question 10.04.09-10
740	16	16 (3.7.5, 3.7.6)	RAI / Changes associated with RAI Batch #83, Response to Question 10.04.09-6
741	16	16 (3.7.18)	RAI / Changes associated with RAI Batch #168, Response to Question 03.06.03-19
742	16	16 (3.7.8)	RAI / Changes associated with RAI Batch #119, Response to Question 09.02.01-15
743	16	16 (3.7.8, 3.7.19)	RAI / Changes associated with RAI Batch #166, Suppl 1, Response to Question 16-291
744	16	16 (3.7.10)	RAI / Changes associated with RAI Batch #122, Suppl 1, Response to Question 16-254
745	16	16 (3.7.11)	RAI / Changes associated with RAI Batch #110, Suppl 1, Response to Question 16-237
746	16	16 (3.7.11)	RAI / Changes associated with RAI Batch #135, Suppl 1, Response to Question 09.04.05-1.4
747	16	16 (3.7.15, 3.7.16, 3.7.19)	Editorial / Change occurrences for consistency to "COL applicant"
748	16	16 (3.7.19)	RAI / Changes associated with RAI Batch #119, Suppl 2, Response to Question 09.02.01-17
749	16	16 (3.8)	RAI / Changes associated with RAI Batch #74, Response to Questions 16-6, 16-7, 16-8, 16-9, 16-14, 16-17, 16-19, 16-32, 16-34
750	16	16 (3.8.1, 3.8.3)	RAI / Changes associated with RAI Batch #74, Suppl 1, Response to Questions 16-29, 16-31
751	16	16 (3.9.2, 3.9.3, 3.9.4, 3.9.5)	RAI / Changes associated with RAI Batch #101, Response to Questions 16-83, 16-104, 16-107
752	16	16 (4.0)	RAI / Changes associated with RAI Batch #196, Response to Question 09.01.01-11
753	16	16 (B3.9.5)	RAI / Changes associated with RAI Batch #26, Suppl 1, Response to Questions 19-178

Item	Chapter	Subsection	Type of Change
754	16	16 (3.9.3)	Editorial / Miscellaneous changes - Add definition of "recently irradiated fuel" to Containment Penetration Bases in B3.9.3 - in accordance with RAI Response 15.00.03-22
755	16	16 (3.9.3, B3.9.3)	RAI / Miscellaneous changes to FSAR identified during response to RAI Batch #17
756	16	16 (3.4.12, 3.4.16 and B3.4.12, B3.4.16)	RAI / Changes associated with RAI Batch #63, Supp1; Response to Questions 05.04.02.02-3, 05.04.02.02-9.
757	16	16 (5.2, 5.5, 5.6, 5.7)	RAI / Changes associated with RAI Batch #122, Response to Questions 16-252, 16-253
758	16	16 (5.5)	RAI / Changes associated with RAI Batch #122, Supp1, Response to Question 16-254
759	16	16 (5.5)	RAI / Changes associated with RAI Batch #89, Response to Question 06.04-4
760	16	16 (5.5)	RAI / Add " \leq " for containment leakage rate acceptance criterion - RAI Batch #12 - RAI Response to question 06.02.06-01
761	16	16 (5.5 and 5.6)	RAI / Changes associated with RAI Batch #63, Supp1, Response to Questions 05.04.02.02-1, 05.04.02.02-9, 05.04.02.02-10, 05.04.02.02-11, and 05.04.02.02-14
762	16	16 (5.6)	RAI / Changes associated with RAI Batch #64, Supplement 2, Response to Question 05.03.02-5
763	16	16 (B3.8.3)	RAI / Changes associated with RAI Batch #74, Suppl 1, Response to Question 16-29
764	16	16 (5.6)	Editorial / Update references for COLR methodology
765	16	16 (5.6)	Editorial / Change PLTR sentence to indicate that it will be provided to the "NRC" instead of "applicable regulatory body".
766	16	16 (B2.1.1)	RAI / Changes associated with RAI Batch #110, Suppl 1, Response to Question 16-241
767	16	16 (B2.1.1)	RAI / Editorial - delete brackets from values for peak fuel centerline temperature in bases for SL 2.1.1.2 for consistency with Section 2.1.1
768	16	16 (B3.0)	RAI / Changes associated with RAI Batch #110, Response to Question 16-242
769	16	16	RAI / Changes associated with RAI Batch #122, Response to Questions 16-247, 16-258, 16-259, 16-261, 16-262, 16-263, 16-266, 16-270, 16-272
770	16	16	RAI / Changes associated with RAI Batch #122, Response to Questions 16-273 thru 279, 16-280, 16-282, 16-284, 16-285, 16-287, 16-288, 16-289, 16-290
771	16	16 - B3.3.1	Editorial
772	16	16 (3.3.1, B3.3.1)	RAI / Changes associated with RAI Batch #103, Suppl 1, Response to Question 16-194
773	16	16	RAI / Changes associated with RAI Batch #110, Suppl 1, Response to Questions 16-222, 16-227, 16-228
774	16	16	RAI / Changes associated with RAI Batch #103, Response to Questions 16-127, 16-130, 16-131, 16-132, 16-134, 16-136, 16-139, 16-140, 16-141, 16-152, 16-161, 16-166, 16-167, 16-171, 16-174, 16-187, 16-188, 16-192, 16-200, 16-202, 16-207
775	16	16 (B3.3.1, B3.3.2)	RAI / Changes associated with RAI Batch #110, Response to Questions 16-214, 16-219 thru 221, 16-224, 16-231, 16-232, 16.234, 16-275
776	16	16 (B3.3.1)	RAI / Changes associated with RAI Batch #103, Suppl 1, Response to Questions 16-193, 16-195
777	16	16 (3.3.2, B3.3.2)	RAI / Changes associated with RAI Batch #110, Suppl 2, Response to Question 16-212
778	16	16 (B3.4.14)	RAI / Changes associated with RAI Batch #168, Response to Question 03.06.03-19

Item	Chapter	Subsection	Type of Change
779	16	16 (B3.3.2)	RAI / Changes associated with RAI Batch #110, Suppl 1, Response to Question 16-212
780	16	16 (B3.4.11)	RAI / Changes associated with RAI Batch #101, Suppl 2, Response to Question 16-68
781	16	16 (B3.4.3)	RAI / Changes associated with RAI Batch #64, Supplement 2, Response to Question 05.03.02-5
782	16	16 (B3.4.4, B3.4.6, B3.4.9, B3.4.11, B3.4.14)	RAI / Changes associated with RAI Batch #101, Suppl 1, Response to Questions 16-56, 16-69, 16-72, 16-77, 16-79
783	16	16 (B3.5.3, B3.5.4, B3.5.6, B3.5.7, B3.5.8)	RAI / Changes associated with RAI Batch #142, Suppl 1, Response to Question 19-269
784	16	16 (B3.6.8)	Editorial / Abbreviation for dodecahydrate trisodium phosphate changed to 'PSP-C' for consistency
785	16	16 (B3.6.8)	RAI / Changes associated with RAI Batch #101, Suppl 1, Response to Question 16-61
786	16	16 (B3.6.1, B3.6.6)	RAI / Changes associated with RAI Batch #122, Response to Questions 16-248, 16-250
787	16	16 (B3.7.14, B3.5.5)	Editorial
788	16	16 (B3.7.3, B3.8.2, B3.8.3, B3.8.5)	Editorial
789	16	16 (B3.6.6, B3.7.10, B3.7.12)	RAI / Changes associated with RAI Batch #89, Response to Questions 06.04-4 and 06.02.03-1
790	16	16 (B3.7.7, B3.7.8)	RAI / Changes associated with RAI Batch #122, Response to Questions 16-250, 16-258
791	16	16 (B3.7.8)	RAI / Changes associated with RAI Batch #119, Suppl 1, Response to Question 09.02.01-19
792	16	16 (B3.7.8, B3.7.19)	RAI / Changes associated with RAI Batch #166, Suppl 1, Response to Question 16-291
793	16	16 (B3.7.16)	RAI / Changes associated with RAI Batch #196, Response to Question 09.01.01-12
794	16	16 (B3.7.18)	RAI / Changes associated with RAI Batch #168, Response to Question 03.06.03-19
795	16	16 (B3.8.1)	RAI / Changes associated with RAI Batch #110, Suppl 1, Response to Question 16-237
796	16	16 (B3.8.3)	RAI / Changes associated with RAI Batch #87, Suppl 4, Response to Question 09.05.07-8
797	16	16	RAI / Changes to FSAR associated with RAI Batch #101 - in accordance with RAI Responses to Questions 16-100, 16-107, 16-108, 16-110, 16-112, 16-113, 16-114, 16-115, 16-116, 16-118, 16-124, 16-58, 16-59, 16-60, 16-63, 16-64, 16-65, 16-73.1, 16-73.10, 16-73.11, 16-73.12, 16-73.14, 16-73.16, 16-73.3, 16-73.4, 16-73.5, 16-73.6, 16-73.7, 16-73.8, 16-73.9, 16-75, 16-78, 16-80, 16-81, 16-83, 16-84, 16-85, 16-86, 16-87, 16-89, 16-91, 16-92, 16-93, 16-94, 16-95, 16-96, 16-97, 16-98, 16-99, 19-109
798	16	16 (B3.8.1, B3.8.2, B3.8.6, B3.8.7, B3.8.8, B3.8.9, B3.8.10)	RAI / Changes associated with RAI Batch #74, Response to Questions 16-8, 16-9, 16-14, 16-27, 16-36, 16-39, 16-41, 16-42, 16-43, 16-44, 16-47, 16-51

Item	Chapter	Subsection	Type of Change
799	16	16 (B3.7.10, B3.7.11, B3.7.12)	RAI / Changes associated with RAI Batch #135, Suppl 1, Response to Questions 09.04.05-1.1, 09.04.05-1.3(3), 09.04.05-1.4 and 09.04.05-1.13
800	16	16 (B3.9.5)	RAI / Changes associated with RAI Batch #101, Suppl 1, Response to Question 16-103
801	17	17.4	RAI / Changes to FSAR associated with RAI Batch #21 - in accordance with RAI Responses to 17.04-05 and 17.04-14
802	17	17.5	Correction - minor / Change Title for Section 17.5 from "Quality Assurance Program Guidance" to "Quality Assurance Program Description ", consistent with the title of SRP 17.5. NRC agreed to withdraw Draft Question 17.5-3 if this change is included in Rev. 1 of the FSAR.
803	18	18	Editorial
804	18	18.1.1.5	RAI / Changes to FSAR associated with RAI Batch #27 - in accordance with RAI Response 18-01
805	18	18.1.3.4	RAI / Changes associated with RAI Batch #39, Response to Question 18-3
806	18	18.7	RAI / Changes associated with RAI Batch #47, Response to Questions 18-11 and 18-13
807	18	18.7.1.3.13 18.7.1.3.14	Correction - minor / Correct cross-references. Table 7.1-3 changed to Table 7.1-2 in Sections 18.7.1.3.13 and 18.7.1.3.14. Sentence with cross-Reference to Table 7.4-1 has been deleted (since this table was removed from 7.4 and inserted into 18.7 in FSAR Rev. 0).
808	18	18.8.3	RAI / Changes associated with RAI Batch #115, Suppl 2, Response to Question 14.03.09-6
809	18	18.9.3	RAI / Changes associated with RAI Batch #115, Suppl 2, Response to Question 14.03.09-6
810	18	18.10.3	RAI / Changes associated with RAI Batch #47, Response to Questions 18-16, 18-23, 18-21, 18-22, 18-26 and 18-27
811	18	18.10.3.7	RAI / Changes associated with RAI Batch #115, Suppl 2, Response to Question 14.03.09-6
812	18	18.11.4	RAI / Changes associated with RAI Batch #115, Suppl 2, Response to Question 14.03.09-6
813	19	19.1	Editorial / Requested change - inaccurate description of use of PRA during design phase (delete claim to use PRA to establish AOT for certain equipment tech specs)
814	19	19.1	Editorial / Eliminate terminology of "design certification PRA"
815	19	19.1	RAI / Changes associated with RAI Batch #2, Supp. 2 Response to Question 19-05
816	19	19.1	RAI / Changes associated with RAI Batch #138, Response to Question 19-247
817	19	19.1	RAI / Changes associated with RAI Batch #172, Response to Question 19-270
818	19	19.1	RAI / Changes associated with RAI Batch #53, Response to Question 19-196
819	19	19.1	RAI / Changes to FSAR associated with RAI Batch #22- in accordance with RAI Responses 19-152, 19-153, and 19-155
820	19	19.1	RAI / Changes to FSAR associated with RAI Batch #2- in accordance with RAI Responses 19-28, and 19-45 [RAI Response 19-28 indicates FSAR Section 19.1.3.4.3 (Reliability of Safety Injection Actuation During Mid-Loop Operation) will be deleted; RAI Response 19-45 corrects a typographical error (from 16 percent improvement" to "7 percent improvement")]
821	19	19.1	RAI / Changes to FSAR associated with RAI Batch #26- in accordance with RAI Responses 19-162, 19-168, and 19-188
822	19	19.1 Table 19.1-102	RAI / Changes to FSAR associated with RAI Batch #2, Supplement #1 - revised Table 19.1-102 to include dispositions for each PRA-based insight and added new insights; updated risk metrics pages, uncertainty analysis pages, and uncertainty figures - in accordance with RAI Response to 19-02 and 19-05
823	19	19.1	RAI / Changes associated with RAI Batch #138, Suppl 1, Response to Question 19-249

Item	Chapter	Subsection	Type of Change
824	19	19.1	RAI / Changes associated with RAI Batch #197, Response to Questions 19-274, 19-277, 19-279, 19-281, 19-282, 19.283
825	19	19.1	RAI / Changes associated with RAI Batch #26, Suppl 2, Response to Questions 19-166, and 19-167
826	19	19.1	RAI / Changes associated with RAI Batch #142, Response to Questions 19-266, 19-267
827	19	19.1	RAI / Changes associated with RAI Batch #66, Suppl 1, Response to Question 19.01-39
828	19	19.1	RAI / Changes associated with RAI Batch #97, Response to Questions 19-220, 19-224, 19-225 and 19-226
829	19	19.1	RAI / Changes associated with RAI Batch #22, Supp. 3 Response to Question 19-158
830	19	19.1	Editorial / Title Editorial Change [^o F only] - and matching change to text in 19.1
831	19	19.1 Table 19.1-20	Correction - moderate / Revised severe accident source term (Table 19.1-20) per WebCAP 2008-3905-CR.
832	19	19.1 Table 19.1-26	RAI / Changes to FSAR associated with RAI Batch #6, Supplement 1 - revised Table 19.1-26 in accordance with RAI Response #19-84h
833	19	19.1 Figure 19.1-31 Table 19.1-106 Table 19.1-107 Table 19.1-21 Figure 19.1-8	RAI / Changes to FSAR associated with RAI Batch #8, Supplement #1 - revise description of seismic risk evaluation and results, added new Figure 19.1-31(Comparison of SME and RLE for Hard and Soft Soil Sites), added Table 19.1-106 (Seismic Fragilities of Safety-Related Structures), and Table 19.1-107 (Seismic Fragilities of Mechanical and Electrical Equipment), revised Table 19.1-21 (Probability Distributions for the Six Dominant Failure Modes), and revised Figure 19.1-8 (Composite Containment Fragility Curve at 395°F)
834	19	19.1	RAI / Changes associated with RAI Batch #66, Response to Questions 19.01-21, 19.01-31 and 19.01-41
835	19	19.1 Table 19.1-87	RAI / Changes to FSAR associated with RAI Batch #7 - revised Table 19.1-87 in accordance with RAI Response to 19-75
836	19	19.1 Table 19.1-93, Table 19.1-95	RAI / Changes to FSAR associated with RAI Batch #14 - Added footnote to Tables 19.1-93 and 19.1-95 to explain RAW values of 1E-NA in accordance with RAI Response #19-145
837	19	19.1 Table 19.1-102	RAI / Changes to FSAR associated with RAI Batch #2, Supplement #1 - revised Table 19.1-102 to include disposition for all the PRA insights and addition of 20 new insights or assumptions - in accordance with RAI Response to 19-02
838	19	19.1	RAI / Changes associated with RAI Batch #138, Response to Question 19-255
839	19	19.1	RAI / Changes associated with RAI Batch #138, Response to Question 19-254
840	19	19.1 & 19.2	Editorial
841	19	19.2	Editorial / Delete duplicate reference
842	19	19.2	RAI / Changes associated with RAI Batch #69, Response to Question 06.02.05-02