

2.2.7 Extra Borating System

1.0 Description

The extra borating system (EBS) is a safety-related system. The EBS has two divisions. The EBS provides the following safety related functions:

- Core reactivity control.
- Reactor coolant pressure boundary integrity.
- Containment isolation.

The EBS provides the following non-safety related functions:

- Borated water to the RCS for beyond design basis events.

2.0 Arrangement

2.1 The functional arrangement of the EBS is as shown in Figure 2.2.7-1—Extra Borating System Functional Arrangement.

2.2 The location of the EBS equipment is as listed in Table 2.2.7-1—EBS Equipment Mechanical Design.

2.3 The divisions of the EBS, except for the suction piping interconnect, are separated by a wall in the Fuel Building.

3.0 Mechanical Design Features

3.1 Equipment listed in Table 2.2.7-1 as ASME Code Section III is designed, welded, and hydrostatically tested in accordance with ASME Code Section III.

3.2 Check valves listed in Table 2.2.7-1 will function as listed in Table 2.2.7-1.

3.3 Deleted.

3.4 Equipment identified as Seismic Category I in Table 2.2.7-1 can withstand seismic design basis loads without loss of safety function as listed in Table 2.2.7-1.

3.5 Deleted.

3.6 Components listed as ASME Code Class 1 in Table 2.2.7-1 will be analyzed for fatigue in accordance with ASME Section III Class 1.

3.7 Deleted.

3.8 Deleted.

3.9 Deleted.

- 3.10 Portions of the EBS piping shown as ASME Code Section III in Figure 2.2.7-1 are designed in accordance with ASME Code Section III requirements.
- 3.11 Portions of the EBS piping shown as ASME Code Section III in Figure 2.2.7-1 are installed in accordance with an ASME Code Section III Design Report.
- 3.12 Pressure boundary welds in portions of the EBS piping shown as ASME Code Section III in Figure 2.2.7-1 are in accordance with ASME Code Section III.
- 3.13 Portions of the EBS piping shown as ASME Code Section III in Figure 2.2.7-1 retain their pressure boundary integrity at their design pressure.
- 3.14 Portions of the EBS piping shown as ASME Code Section III in Figure 2.2.7-1 are installed in accordance with ASME Code Section III requirements.

4.0 Instrumentation and Controls (I&C) Design Features, Displays, and Controls

- 4.1 Displays listed in Table 2.2.7-2—EBS Equipment I&C and Electrical Design are retrievable in the main control room (MCR) and the remote shutdown station (RSS) as listed in Table 2.2.7-2.
- 4.2 The EBS equipment controls are provided in the MCR and the RSS as listed in Table 2.2.7-2.
- 4.3 Equipment listed as being controlled by a priority and actuator control system (PACS) module in Table 2.2.7-2 responds to the state requested by a test signal.

5.0 Electrical Power Design Features

- 5.1 The components designated as Class 1E in Table 2.2.7-2 are powered from the Class 1E division as listed in Table 2.2.7-2 in a normal or alternate feed condition.
- 5.2 Valves listed in Table 2.2.7-2 fail as-is on loss of power.

6.0 Environmental Qualifications

- 6.1 Equipment listed in Table 2.2.7-2 for harsh environment can perform the function in Table 2.2.7-1 following exposure to the design basis environments for the time required.

7.0 Equipment and System Performance

- 7.1 The pumps listed in Table 2.2.7-1 have sufficient net positive suction head available (NPSHA).
- 7.2 Class 1E valves listed in Table 2.2.7-2 can perform the function listed in Table 2.2.7-1 under system design conditions.
- 7.3 The EBS provides for flow testing of the EBS pumps during plant operation.
- 7.4 Containment isolation valves listed in Table 2.2.7-1 close within the containment isolation response time following initiation of a containment isolation signal.

8.0 Inspections, Tests, Analyses, and Acceptance Criteria

Table 2.2.7-3 lists the EBS ITAAC.

Table 2.2.7-1—EBS Equipment Mechanical Design

| Equipment Description | Equipment Tag Number⁽¹⁾ | Equipment Location | ASME Code Section III | Function | Seismic Category |
|-----------------------------------------------------------|-------------------------------------------|---------------------------|------------------------------|----------------------------------------|-------------------------|
| EBS Tank Division 1 (Division 4) | 30JDH10 BB001 (30JDH40 BB001) | Fuel Building | yes | storage volume | I |
| EBS Pump Division 1 (Division 4) | 30JDH10 AP001 (30JDH40 AP001) | Fuel Building | yes | run | I |
| Containment Isolation Valve Division 1 (Division 4) | 30JDH10 AA006 (30JDH40 AA006) | Fuel Building | yes | open, close (Containment Isolation) | I |
| Containment Isolation Check Valve Division 1 (Division 4) | 30JDH10 AA007 (30JDH40 AA007) | Reactor Building | yes | open, close (Containment Isolation) | I |
| EBS RCPB Isolation Valve to RCS Cold Leg 1 Division 1 | 30JDH10 AA015 | Reactor Building | yes (Class 1) | open, close | I |
| EBS RCPB Isolation Valve to RCS Cold Leg 2 Division 1 | 30JDH20 AA015 | Reactor Building | yes (Class 1) | open, close | I |
| EBS RCPB Isolation Valve to RCS Cold Leg 3 Division 4 | 30JDH30 AA015 | Reactor Building | yes (Class 1) | open,close | I |
| EBS RCPB Isolation Valve to RCS Cold Leg 4 Division 4 | 30JDH40 AA015 | Reactor Building | yes (Class 1) | open,close | I |
| Test Line Isolation Valve Division 1 (Division 4) | 30JDH10 AA008 (30JDH40 AA008) | Fuel Building | yes | close | I |

1) Equipment tag numbers are provided for information only and are not part of the certified design.

Table 2.2.7-2—EBS Equipment I&C and Electrical Design

| Equipment Description | Equipment Tag Number ⁽¹⁾ | Equipment Location | IEEE Class 1E ⁽²⁾ | EQ –Harsh Env. | PACS | MCR/RSS Displays | MCR/RSS Controls |
|-------------------------------------------------------|-------------------------------------|--------------------|----------------------------------------------------------------------------|----------------|------|-------------------|---------------------------|
| EBS Pump Division 1 (Division 4) | 30JDH10 AP001 (30JDH40 AP001) | Fuel Building | 1 ^N 2 ^A (4 ^N) (3 ^A) | N/A | yes | On-Off/On-Off | Start-Stop/ Start-Stop |
| Containment Isolation Valve Division 1 (Division 4) | 30JDH10 AA006 (30JDH40 AA006) | Fuel Building | 1 ^N 2 ^A (4 ^N) (3 ^A) | N/A | yes | Position/Position | Open-Close/ Open-Close |
| EBS RCPB Isolation Valve to RCS Cold Leg 1 Division 1 | 30JDH10 AA015 | Reactor Building | 1 ^N 2 ^A | yes | yes | Position/Position | Open-Close/ Open-Close |
| EBS RCPB Isolation Valve to RCS Cold Leg 2 Division 1 | 30JDH20 AA015 | Reactor Building | 2 ^N 1 ^A | yes | yes | Position/Position | Open-Close/ Open-Close |
| EBS RCPB Isolation Valve to RCS Cold Leg 3 Division 4 | 30JDH30 AA015 | Reactor Building | 3 ^N 4 ^A | yes | yes | Position/Position | Open-Close/ Open-Close |
| EBS RCPB Isolation Valve to RCS Cold Leg 4 Division 4 | 30JDH40 AA015 | Reactor Building | 4 ^N 3 ^A | yes | yes | Position/Position | Open-Close/ Open-Close |
| Test Line Isolation Valve Division 1 (Division 4) | 30JDH10 AA008 (30JDH40 AA008) | Fuel Building | 1 ^N 2 ^A (4 ^N) (3 ^A) | N/A | yes | Position/Position | Open-Close/ Open-Close |

1) Equipment tag numbers are provided for information only and are not part of the certified design.

2) ^N denotes the division the component is normally powered from. ^A denotes the division the component is powered from when alternate feed is implemented.

Table 2.2.7-3—EBS ITAAC (6 Sheets)

| Commitment Wording | | Inspections, Tests, Analyses | Acceptance Criteria |
|---------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 2.1 | The functional arrangement of the EBS is as shown on Figure 2.2.7-1. | Inspections of the as-built system as shown on Figure 2.2.7-1 will be conducted. | The as-built EBS conforms with the functional arrangement as shown in Figure 2.2.7-1. |
| 2.2 | The location of the EBS equipment is as listed in Table 2.2.7-1. | An inspection will be performed of the location of the equipment listed in Table 2.2.7-1. | The equipment listed in Table 2.2.7-1 is located as listed in Table 2.2.7-1. |
| 2.3 | The divisions of the EBS, except for the suction piping interconnect, are separated by a wall in the Fuel Building. | An inspection will be performed to verify that the divisions of the EBS are separated in the Fuel Building. | The divisions of the EBS, except for the suction piping interconnect, are separated by a wall in the Fuel Building. |
| 3.1 | Equipment listed in Table 2.2.7-1 as ASME Code Section III is designed, welded, and hydrostatically tested in accordance with ASME Code Section III. | <p>a. Analysis of the equipment identified in Table 2.2.7-1 as ASME Code Section III will be performed per ASME Code Section III design requirements.</p> <p>b. Inspections will be conducted on the equipment identified in Table 2.2.7-1 as ASME Code Section III to verify welding has been performed per ASME Code Section III welding requirements.</p> <p>c. Hydrostatic testing of the equipment identified in Table 2.2.7-1 as ASME Code Section III will be performed per ASME Code Section III hydrostatic testing requirements.</p> | <p>a. ASME Code Section III Design Reports (NCA-3550) exist and conclude that the equipment identified in Table 2.2.7-1 as ASME Code Section III meets ASME Code Section III design requirements.</p> <p>b. Equipment identified in Table 2.2.7-1 as ASME Code Section III has been welded per ASME Code Section III welding requirements.</p> <p>c. Equipment identified in Table 2.2.7-1 as ASME Code Section III has been hydrostatically tested per ASME Code Section III hydrostatic testing requirements.</p> |
| 3.2 | Check valves listed in Table 2.2.7-1 will function as listed in Table 2.2.7-1. | Tests will be performed for the operation of the check valves listed in Table 2.2.7-1. | The check valves listed in Table 2.2.7-1 perform the functions listed in Table 2.2.7-1. |
| 3.3 | Deleted.. | Deleted. | Deleted. |

Table 2.2.7-3—EBS ITAAC (6 Sheets)

| Commitment Wording | | Inspections, Tests, Analyses | Acceptance Criteria |
|---------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 3.4 | Equipment identified as Seismic Category I in Table 2.2.7-1 can withstand seismic design basis loads without loss of safety function as listed in Table 2.2.7-1. | <ul style="list-style-type: none"> a. Type tests, analyses, or a combination of type tests and analyses will be performed on the equipment listed as Seismic Category I in Table 2.2.7-1 using analytical assumptions, or under conditions, which bound the Seismic Category I design requirements. b. Inspections will be performed of the as-installed Seismic Category I equipment listed in Table 2.2.7-1 to verify that the equipment including anchorage is installed as specified on the construction drawings. | <ul style="list-style-type: none"> a. Tests/analysis reports exist and conclude that the Seismic Category I equipment listed in Table 2.2.7-1 can withstand seismic design basis loads without loss of safety function. b. Inspection reports exist and conclude that the as-installed Seismic Category I equipment listed in Table 2.2.7-1 including anchorage is installed as specified on the construction drawings. |
| 3.5 | Deleted. | Deleted. | Deleted. |
| 3.6 | Components listed as ASME Code Class 1 in Table 2.2.7-1 will be analyzed for fatigue per ASME Section III Class 1. | An analysis will be performed. | <ul style="list-style-type: none"> a. Fatigue analysis has been performed for components listed as ASME Code Class 1 in Table 2.2.7-1. b. For components listed as ASME Code Class 1 in Table 2.2.7-1 operating modes where peak stresses are within 10% of allowable have been identified. |
| 3.7 | Deleted. | Deleted. | Deleted. |
| 3.8 | Deleted. | Deleted. | Deleted. |
| 3.9 | Deleted. | Deleted. | Deleted. |

Table 2.2.7-3—EBS ITAAC (6 Sheets)

| Commitment Wording | | Inspections, Tests, Analyses | Acceptance Criteria |
|---------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 3.10 | Portions of the EBS piping shown as ASME Code Section III in Figure 2.2.7-1 are designed in accordance with ASME Code Section III requirements. | Inspections will be performed for the existence of ASME Code Section III Design Reports. | ASME Code section III Design Reports (NCA-3550) exist for portions of the EBS piping shown as ASME Code Section III in Figure 2.2.7-1. |
| 3.11 | Portions of the EBS piping shown as ASME Code Section III in Figure 2.2.7-1 are installed in accordance with an ASME Code Section III Design Report. | Inspections will be performed to verify the existence of an analysis which reconciles as-fabricated deviations to the ASME Code Design Report as required by ASME Code Section III. | For portions of the EBS piping shown as ASME Code Section III in Figure 2.2.7-1, ASME Code Data Reports (N-5) exist and conclude that reconciliation (NCA-3554) of the as-installed system with the Design Report (NCA-3550) has occurred. |
| 3.12 | Pressure boundary welds in portions of the EBS piping shown as ASME Code Section III in Figure 2.2.7-1 are in accordance with ASME Code Section III. | Inspections of pressure boundary welds verify that welding is performed in accordance with ASME Code Section III requirements. | ASME Code Section III Data Reports exist and conclude that pressure boundary welding for portions of the EBS piping shown as ASME Code Section III in Figure 2.2.7-1 has been performed in accordance with ASME Code Section III. |
| 3.13 | Portions of the EBS piping shown as ASME Code Section III in Figure 2.2.7-1 retain their pressure boundary integrity at their design pressure. | Hydrostatic tests will be performed on the as-fabricated system. | For portions of the EBS piping shown as ASME Code Section III in Figure 2.2.7-1, ASME Code Section III Data Reports exist and conclude that hydrostatic test results comply with ASME Code Section III requirements. |
| 3.14 | Portions of the EBS piping shown as ASME Code Section III in Figure 2.2.7-1 are installed in accordance with ASME Code Section III requirements. | An inspection for the existence of ASME N-5 Data Reports will be performed. | For portions of the EBS piping shown as ASME Code Section III in Figure 2.2.7-1, N-5 Data Reports exist and conclude that installation is in accordance with ASME Code Section III requirements. |

Table 2.2.7-3—EBS ITAAC (6 Sheets)

| Commitment Wording | | Inspections, Tests, Analyses | Acceptance Criteria |
|--------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 4.1 | Displays exist or can be retrieved in the MCR and the RSS as identified in Table 2.2.7-2. | Inspections will be performed for the existence or retrievability of the displays in the MCR or the RSS as listed in Table 2.2.7-2. | <ul style="list-style-type: none"> a. The displays listed in Table 2.2.7-2 as being retrieved in the MCR can be retrieved in the MCR. b. The displays listed in Table 2.2.7-2 as being retrieved in the RSS can be retrieved in the RSS. |
| 4.2 | Controls exist in the MCR and the RSS as identified in Table 2.2.7-2. | Tests will be performed for the existence of control signals from the MCR and the RSS to the equipment listed in Table 2.2.7-2. | <ul style="list-style-type: none"> a. The controls listed in Table 2.2.7-2 as being in the MCR exist in the MCR. b. The controls listed in Table 2.2.7-2 as being in the RSS exist in the RSS. |
| 4.3 | Equipment listed as being controlled by a PACS module in Table 2.2.7-2 responds to the state requested by a test signal. | A test will be performed using test signals. | Equipment listed as being controlled by a PACS module in Table 2.2.7-2 responds to the state requested by the test signal. |
| 5.1 | The components designated as Class 1E in Table 2.2.7-2 are powered from the Class 1E division as listed in Table 2.2.7-2 in a normal or alternate feed condition. | <ul style="list-style-type: none"> a. Testing will be performed for components designated as Class 1E in Table 2.2.7-2 by providing a test signal in each normally aligned division. b. Testing will be performed for components designated as Class 1E in Table 2.2.7-2 by providing a test signal in each division with the alternate feed aligned to the divisional pair. | <ul style="list-style-type: none"> a. The test signal provided in the normally aligned division is present at the respective Class 1E component identified in Table 2.2.7-2. b. The test signal provided in each division with the alternate feed aligned to the divisional pair is present at the respective Class 1E component identified in Table 2.2.7-2. |
| 5.2 | Valves listed in Table 2.2.7-2 fail as-is on loss of power. | Testing will be performed for the valves listed in Table 2.2.7-2 to fail as-is on loss of power. | Following loss of power, the valves listed in Table 2.2.7-2 fail as-is. |

Table 2.2.7-3—EBS ITAAC (6 Sheets)

| Commitment Wording | | Inspections, Tests, Analyses | Acceptance Criteria |
|---------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 6.1 | Components listed as Class 1E in Table 2.2.7-2 that are designated as harsh environment will perform the function listed in Table 2.2.7-1 in the environments that exist before and during the time required to perform their function. | <p>a. Type tests, tests, analyses or a combination of tests and analyses will be performed to demonstrate the ability of the equipment listed for harsh environment in Table 2.2.7-2 to perform the function listed in Table 2.2.7-1 for the environmental conditions that could occur before and during a design basis accident.</p> <p>b. For equipment listed for harsh environment in Table 2.2.7-2, an inspection will be performed of the as-installed Class 1E equipment and the associated wiring, cables, and terminations.</p> | <p>a. The Class 1E equipment listed for harsh environment in Table 2.2.7-2 can perform the function listed in Table 2.2.7-1 before and during design basis accidents for the time required to perform the listed function.</p> <p>b. Inspection concludes the as-installed Class 1E equipment and associated wiring, cables, and terminations as listed in Table 2.2.7-2 for harsh environment conform with the design.</p> |
| 7.1 | The pumps listed in Table 2.2.7-1 have sufficient NPSHA. | Testing and analyses will be performed to verify NPSHA for pumps listed in Table 2.2.7-1. | The pumps listed in Table 2.2.7-1 have NPSHA that is greater than net positive suction head required (NPSHR) at system run-out flow. |
| 7.2 | Class 1E valves listed in Table 2.2.7-2 perform the function listed in Table 2.2.7-1 under system conditions. | Tests and analyses or a combination of tests and analyses will be performed to demonstrate the ability of the valves listed in Table 2.2.7-2 to change position as listed in Table 2.2.7-1 under system design conditions. | The as-installed valve changes position as listed Table 2.2.7-1 under system design conditions. |
| 7.3 | The EBS has provisions to allow flow testing of the EBS pumps during plant operation. | Testing for flow of the EBS pumps back to the EBS tank will be performed. | The flow test line allows EBS pump flow back to the EBS tank. |

Table 2.2.7-3—EBS ITAAC (6 Sheets)

| Commitment Wording | | Inspections, Tests, Analyses | Acceptance Criteria |
|---------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------|
| 7.4 | Containment isolation valves listed in Table 2.2.7-1 close within the containment isolation response time following initiation of a containment isolation signal. | Tests will be performed to demonstrate the ability of the containment isolation valves listed in Table 2.2.7-1 to close within the containment isolation response time following initiation of a containment isolation signal. | Containment isolation valves listed in Table 2.2.7-1 close within 60 seconds following initiation of a containment isolation signal. |