

## 2.8.6 Main Feedwater System

### 1.0 Description

The main feedwater system (MFWS) is a non-safety-related system with portions that are safety related. It transports and controls feedwater from the deaerator/feedwater storage tank to the steam generators (SG). It includes the startup/shutdown feedwater supply. The MFWS is safety related from the connections to the SGs to the fixed seismic restraint in each main feedwater line and to the fixed seismic restraint in each startup/shutdown feedwater line.

The MFWS provides the following safety-related function:

- Shut off main feedwater supply and startup/shutdown feedwater supply.

The MFWS provides the following non-safety-related functions:

- The MFWS supplies feedwater to the SGs for power operation.
- A startup/shutdown system supplies feedwater to the SGs for low-power operation.

### 2.0 Arrangement

2.1 The functional arrangement of the MFWS is as shown in Figure 2.8.6-1—MFWS Functional Arrangement.

2.2 The location of the MFWS equipment is as listed in Table 2.8.6-1—MFWS Equipment Mechanical Design.

2.3 Physical separation exists between the safety-related portions of the main feedwater divisions. The safety-related valves in Divisions 1 and 2 are located in separate valve rooms in Safeguard Building (SB) 1. The safety-related valves in Divisions 3 and 4 are located in separate valve rooms in SB 4.

### 3.0 Mechanical Design Features

3.1 Equipment listed in Table 2.8.6-1 as ASME Code Section III is designed, welded, and hydrostatically tested in accordance with ASME Code Section III.

3.2 Check valves listed in Table 2.8.6-1 will function as listed in Table 2.8.6-1.

3.3 Deleted.

3.4 Equipment identified as Seismic Category I in Table 2.8.6-1 can withstand seismic design basis loads without loss of safety function as listed in Table 2.8.6-1.

3.5 Deleted.

3.6 Deleted.

3.7 Deleted.

- 
- 3.8 Deleted.
  - 3.9 Portions of the MFWS piping shown as ASME Code Section III in Figure 2.8.6-1 are designed in accordance with ASME Code Section III requirements.
  - 3.10 Portions of the MFWS piping shown as ASME Code Section III in Figure 2.8.6-1 are installed in accordance with an ASME Code Section III Design Report.
  - 3.11 Pressure boundary welds in portions of the MFWS piping shown as ASME Code Section III in Figure 2.8.6-1 are in accordance with ASME Code Section III.
  - 3.12 Portions of the MFWS piping shown as ASME Code Section III in Figure 2.8.6-1 retain their pressure boundary integrity at their design pressure.
  - 3.13 Portions of the MFWS piping shown as ASME Code Section III in Figure 2.8.6-1 are installed in accordance with ASME Code Section III requirements.

#### **4.0 Instrumentation and Control (I&C) Design Features, Displays, and Controls**

- 4.1 Displays listed in Table 2.8.6-2—MFWS Equipment I&C and Electrical Design are retrievable in the main control room (MCR) as listed in Table 2.8.6-2.
- 4.2 The MFWS equipment controls are provided in the MCR as listed in Table 2.8.6-2.
- 4.3 Equipment listed as being controlled by a priority and actuator control system (PACS) module in Table 2.8.6-2 responds to the state requested by a test signal.

#### **5.0 Electrical Power Design Features**

- 5.1 The components designated as Class 1E in Table 2.8.6-2 are powered from the Class 1E division as listed in Table 2.8.6-2 in a normal or alternate feed condition.
- 5.2 The main feedwater full load isolation valves (MFWFLIV) fail closed on loss of hydraulic pressure to the valve actuator.
- 5.3 Other valves listed in Table 2.8.6-2 except the MFWFLIVs fail as-is on loss of electric power to the valve actuator.

#### **6.0 Environmental Qualifications**

- 6.1 Electrical drivers for equipment listed in Table 2.8.6-2 for harsh environment can perform the safety function in Table 2.8.6-1 following exposure to the design basis environments for the time required.

#### **7.0 Equipment and System Performance**

- 7.1 Class 1E valves listed in Table 2.8.6-2 can perform the function listed in Table 2.8.6-1 under system design conditions.

#### **8.0 Inspections, Tests, Analyses, and Acceptance Criteria**

Table 2.8.6-3 lists the MFWS ITAAC.

**Table 2.8.6-1—MFWS Equipment Mechanical Design (2 Sheets)**

<b>Equipment Description</b>	<b>Equipment Tag Number<sup>(1)</sup></b>	<b>Equipment Location</b>	<b>ASME Code Section III</b>	<b>Function</b>	<b>Seismic Category</b>
Main Feedwater Full Load Isolation Valves (MFWFLIV)	30LAB60AA001 30LAB70AA001 30LAB80AA001 30LAB90AA001	SB 1 SB 1 SB 4 SB 4	Yes	Close	I
Main Feedwater Full Load Control Valves (MFWFLCV)	30LAB60AA101 30LAB70AA101 30LAB80AA101 30LAB90AA101	SB 1 SB 1 SB 4 SB 4	Yes	Close	I
Main Feedwater Isolation Valves (MFWIV)	30LAB60AA002 30LAB70AA002 30LAB80AA002 30LAB90AA002	SB 1 SB 1 SB 4 SB 4	Yes	Close	I
Main Feedwater Check Valves (MFWCkV)	30LAB60AA003 30LAB70AA003 30LAB80AA003 30LAB90AA003	RB RB RB RB	Yes	Close	I
Main Feedwater Low Load Isolation Valves (MFWLLIV)	30LAB64AA001 30LAB74AA001 30LAB84AA001 30LAB94AA001	SB 1 SB 1 SB 4 SB 4	Yes	Close	I
Main Feedwater Low Load Control Valves (MFWLLCV)	30LAB64AA101 30LAB74AA101 30LAB84AA101 30LAB94AA101	SB 1 SB 1 SB 4 SB 4	Yes	Close	I
Main Feedwater Very Low Load Control Valves (MFWVLLCV)	30LAB64AA102 30LAB74AA102 30LAB84AA102 30LAB94AA102	SB 1 SB 1 SB 4 SB 4	Yes	Close	I

**Table 2.8.6-1—MFWS Equipment Mechanical Design (2 Sheets)**

Equipment Description	Equipment Tag Number <sup>(1)</sup>	Equipment Location	ASME Code Section III	Function	Seismic Category
Deaerator/Feedwater Storage Tank	30LAA10BB001	Turbine Building	N/A	N/A	N/A
High-Pressure Feedwater Heaters	N/A	Turbine Building	N/A	N/A	N/A
Main Feedwater Pump	30LAC11AP001	Turbine Building	N/A	N/A	N/A
Main Feedwater Pump	30LAC12AP001	Turbine Building	N/A	N/A	N/A
Main Feedwater Pump	30LAC13AP001	Turbine Building	N/A	N/A	N/A
Startup/Shutdown Feedwater Pump	30LAJ10AP001	Turbine Building	N/A	N/A	N/A

- 1) Equipment tag numbers are provided for information only and are not part of the certified design.

**Table 2.8.6-2—MFWS Equipment I&C and Electrical Design (2 Sheets)**

<b>Equipment Description</b>	<b>Equipment Tag Number<sup>(1)</sup></b>	<b>Equipment Location</b>	<b>IEEE Class 1E <sup>(2)</sup></b>	<b>EQ – Harsh Env.</b>	<b>PACS</b>	<b>MCR/RSS Displays</b>	<b>MCR/RSS Controls</b>
Main Feedwater Full Load Isolation Valves (MFWFLIV)	30LAB60AA001	SB 1	3 <sup>N</sup> , 1 <sup>N</sup> 4 <sup>A</sup> , 2 <sup>A</sup>	yes	yes	Pos./ N/A	Close/ N/A
	30LAB70AA001	SB 1	4 <sup>N</sup> , 2 <sup>N</sup>				
	30LAB80AA001	SB 4	3 <sup>A</sup> , 1 <sup>A</sup> 1 <sup>N</sup> , 3 <sup>N</sup> 2 <sup>A</sup> , 4 <sup>A</sup>				
	30LAB90AA001	SB 4	2 <sup>N</sup> , 4 <sup>N</sup> 1 <sup>A</sup> , 3 <sup>A</sup>				
Main Feedwater Full Load Control Valves (MFWFLCV)	30LAB60AA101	SB 1	1 <sup>N</sup> , 2 <sup>A</sup>	yes	yes	Pos./ N/A	Close/ N/A
	30LAB70AA101	SB 1	2 <sup>N</sup> , 1 <sup>A</sup>				
	30LAB80AA101	SB 4	3 <sup>N</sup> , 4 <sup>A</sup>				
	30LAB90AA101	SB 4	4 <sup>N</sup> , 3 <sup>A</sup>				
Main Feedwater Isolation Valves (MFWIV)	30LAB60AA002	SB 1	1 <sup>N</sup> , 2 <sup>A</sup>	yes	yes	Pos./ N/A	Close/ N/A
	30LAB70AA002	SB 1	2 <sup>N</sup> , 1 <sup>A</sup>				
	30LAB80AA002	SB 4	3 <sup>N</sup> , 4 <sup>A</sup>				
	30LAB90AA002	SB 4	4 <sup>N</sup> , 3 <sup>A</sup>				
Main Feedwater Low Load Isolation Valves (MFWLLIV)	30LAB64AA001	SB 1	3 <sup>N</sup> , 4 <sup>A</sup>	yes	yes	Pos./ N/A	Close/ N/A
	30LAB74AA001	SB 1	4 <sup>N</sup> , 3 <sup>A</sup>				
	30LAB84AA001	SB 4	1 <sup>N</sup> , 2 <sup>A</sup>				
	30LAB94AA001	SB 4	2 <sup>N</sup> , 1 <sup>A</sup>				
Main Feedwater Low Load Control Valves (MFWLLCV)	30LAB64AA101	SB 1	1 <sup>N</sup> , 2 <sup>A</sup>	yes	yes	Pos./ N/A	Close/ N/A
	30LAB74AA101	SB 1	2 <sup>N</sup> , 1 <sup>A</sup>				
	30LAB84AA101	SB 4	3 <sup>N</sup> , 4 <sup>A</sup>				
	30LAB94AA101	SB 4	4 <sup>N</sup> , 3 <sup>A</sup>				
Main Feedwater Very Low Load Control Valves (MFWVLLCV)	30LAB64AA102	SB 1	1 <sup>N</sup> , 2 <sup>A</sup>	yes	yes	Pos./ N/A	Close/ N/A
	30LAB74AA102	SB 1	2 <sup>N</sup> , 1 <sup>A</sup>				
	30LAB84AA102	SB 4	3 <sup>N</sup> , 4 <sup>A</sup>				
	30LAB94AA102	SB 4	4 <sup>N</sup> , 3 <sup>A</sup>				

- 
- 1) Equipment tag numbers are provided for information only and are not part of the certified design.
  - 2) <sup>N</sup> denotes the division the component is normally powered from; <sup>A</sup> denotes the division the component is powered from when alternate feed is implemented.

**Table 2.8.6-3—MFWS ITAAC (5 Sheets)**

<b>Commitment Wording</b>		<b>Inspections, Tests, Analyses</b>	<b>Acceptance Criteria</b>
2.1	The functional arrangement of the MFWS is as shown on Figure 2.8.6-1.	Inspections of the as-built system as shown on Figure 2.8.6-1 will be conducted.	The as-built MFWS conforms with the functional arrangement as shown in Figure 2.8.6-1.
2.2	The location of the MFWS equipment is as listed in Table 2.8.6-1.	An inspection will be performed of the location of the equipment listed in Table 2.8.6-1.	The equipment listed in Table 2.8.6-1 is located as listed in Table 2.8.6-1.
2.3	Physical separation exists between divisions of the safety-related parts of MFWS.	An inspection will be performed to verify that the divisions of the MFWS are located in separate SBs.	The divisions of the MFWS are located in separate SBs.
3.1	Equipment listed in Table 2.8.6-1 as ASME Code Section III is designed, welded, and hydrostatically tested in accordance with ASME Code Section III.	<p>a. Analysis of the equipment identified in Table 2.8.6-1 as ASME Code Section III will be performed per ASME Code Section III design requirements.</p> <p>b. Inspections will be conducted on the equipment identified in Table 2.8.6-1 as ASME Code Section III to verify welding has been performed per ASME Code Section III welding requirements.</p> <p>c. Hydrostatic testing of the equipment identified in Table 2.8.6-1 as ASME Code Section III will be performed per ASME Code Section III hydrostatic testing requirements.</p>	<p>a. ASME Code Section III Design Reports (NCA-3550) exist and conclude that the equipment identified in Table 2.8.6-1 as ASME Code Section III meets ASME Code Section III design requirements.</p> <p>b. Equipment identified in Table 2.8.6-1 as ASME Code Section III has been welded per ASME Code Section III welding requirements.</p> <p>c. Equipment identified in Table 2.8.6-1 as ASME Code Section III has been hydrostatically tested per ASME Code Section III hydrostatic testing requirements.</p>
3.2	Check valves listed in Table 2.8.6-1 will function as listed in Table 2.8.6-1.	Tests will be performed for the operation of the check valves listed in Table 2.8.6-1.	The check valves listed in Table 2.8.6-1 perform the functions listed in Table 2.8.6-1.
3.3	Deleted.	Deleted.	Deleted.

**Table 2.8.6-3—MFWS ITAAC (5 Sheets)**

Commitment Wording	Inspections, Tests, Analyses	Acceptance Criteria
3.4 Equipment identified as Seismic Category I in Table 2.8.6-1 can withstand seismic design basis loads without loss of safety function as listed in Table 2.8.6-1.	<p>a. Type tests, analyses, or a combination of type tests and analyses will be performed on the equipment designated as Seismic Category I in Table 2.8.6-1 using analytical assumptions, or under conditions, which bound the Seismic Category I design requirements.</p> <p>b. Inspections will be performed of the as-installed Seismic Category I equipment listed in Table 2.8.6-1 to verify that the equipment including anchorage is installed as specified on the construction drawings.</p>	<p>a. Tests/analysis reports exists and conclude that the Seismic Category I equipment listed in Table 2.8.6-1 can withstand seismic design basis loads without loss of safety function.</p> <p>b. Inspection reports exist and conclude that the as-installed Seismic Category I equipment listed in Table 2.8.6-1 including anchorage is installed as specified on the construction drawings.</p>
3.5 Deleted.	Deleted.	Deleted.
3.6 Deleted.	Deleted.	Deleted.
3.7 Deleted.	Deleted.	Deleted.
3.8 Deleted.	Deleted.	Deleted.
3.9 Portions of the MFWS piping shown as ASME Code Section III in Figure 2.8.6-1 are designed in accordance with ASME Code Section III requirements.	Inspections will be performed for the existence of ASME Code Section III Design Reports.	ASME Code section III Design Reports (NCA-3550) exist for portions of the MFWS piping shown as ASME Code Section III in Figure 2.8.6-1.
3.10 Portions of the MFWS piping shown as ASME Code Section III in Figure 2.8.6-1 are installed in accordance with an ASME Code Section III Design Report.	Inspections will be performed to verify the existence of an analysis which reconciles as-fabricated deviations to the ASME Code Design Report as required by ASME Code Section III.	For portions of the MFWS piping shown as ASME Code Section III in Figure 2.8.6-1, ASME Code Data Reports (N-5) exist and conclude that reconciliation (NCA-3554) of the as-installed system with the Design Report (NCA-3550) has occurred.

**Table 2.8.6-3—MFWS ITAAC (5 Sheets)**

Commitment Wording	Inspections, Tests, Analyses	Acceptance Criteria
3.11 Pressure boundary welds in portions of the MFWS piping shown as ASME Code Section III in Figure 2.8.6-1 are in accordance with ASME Code Section III.	Inspections of pressure boundary welds verify that welding is performed in accordance with ASME Code Section III requirements.	ASME Code Section III Data Reports exist and conclude that pressure boundary welding for portions of the MFWS piping shown as ASME Code Section III in Figure 2.8.6-1 has been performed in accordance with ASME Code Section III.
3.12 Portions of the MFWS piping shown as ASME Code Section III in Figure 2.8.6-1 retain their pressure boundary integrity at their design pressure.	Hydrostatic tests will be performed on the as-fabricated system.	For portions of the MFWS piping shown as ASME Code Section III in Figure 2.8.6-1, ASME Code Section III Data Reports exist and conclude that hydrostatic test results comply with ASME Code Section III requirements.
3.13 Portions of the MFWS piping shown as ASME Code Section III in Figure 2.8.6-1 are installed in accordance with ASME Code Section III requirements.	An inspection for the existence of ASME N-5 Data Reports will be performed.	For portions of the MFWS piping shown as ASME Code Section III in Figure 2.8.6-1, N-5 Data Reports exist and conclude that installation is in accordance with ASME Code Section III requirements.
4.1 Displays exist or can be retrieved in the MCR as identified in Table 2.8.6-2.	Inspections will be performed for the existence or retrievability of the displays in the MCR as listed in Table 2.8.6-2.	The displays listed in Table 2.8.6-2 as being retrieved in the MCR can be retrieved in the MCR.
4.2 Controls exist in the MCR as identified in Table 2.8.6-2.	Tests will be performed for the existence of control signals from the MCR to the equipment listed in Table 2.8.6-2.	The controls listed in Table 2.8.6-2 as being in the MCR exist in the MCR.
4.3 Equipment listed as being controlled by a PACS module in Table 2.8.6-2 responds to the state requested by a test signal.	A test will be performed using test signals.	Equipment listed as being controlled by a PACS module in Table 2.8.6-2 responds to the state requested by the test signal.

**Table 2.8.6-3—MFWS ITAAC (5 Sheets)**

Commitment Wording	Inspections, Tests, Analyses	Acceptance Criteria
5.1 The components designated as Class 1E in Table 2.8.6-2 are powered from the Class 1E division as listed in Table 2.8.6-2 in a normal or alternate feed condition.	<ul style="list-style-type: none"> <li>a. Testing will be performed for components designated as Class 1E in Table 2.8.6-2 by providing a test signal in each normally aligned division.</li> <li>b. Testing will be performed for components designated as Class 1E in Table 2.8.6-2 by providing a test signal in each division with the alternate feed aligned to the divisional pair.</li> </ul>	<ul style="list-style-type: none"> <li>a. The test signal provided in the normally aligned division is present at the respective Class 1E component identified in Table 2.8.6-2.</li> <li>b. The test signal provided in each division with the alternate feed aligned to the divisional pair is present at the respective Class 1E component identified in Table 2.8.6-2.</li> </ul>
5.2 MFWFLIVs fail closed on loss of hydraulic pressure to the valve actuator.	Testing will be performed for the MFWFLIVs to close on loss of hydraulic pressure in each redundant dump line to the valve actuator.	MFWFLIVs fail closed on loss of hydraulic pressure in each redundant dump line to the valve actuator.
5.3 Other valves listed in Table 2.8.6-2 except the MFWFLIVs fail as-is on loss of electric power to the valve actuator.	Testing will be performed for the other valves listed in Table 2.8.6-2 except the MFWFLIVs to fail as-is on loss of electric power to the valve actuator.	Each other valves listed in Table 2.8.6-2 except the MFWFLIVs fails as-is on loss of electric power to the valve actuator.
6.1 Components listed as Class 1E in Table 2.8.6-2 that are designated as harsh environment will perform the function listed in Table 2.8.6-1 in the environments that exist before and during the time required to perform their safety function.	<ul style="list-style-type: none"> <li>a. Type tests, tests, analyses, or a combination of tests and analyses will be performed to demonstrate the ability of the equipment listed for harsh environment in Table 2.8.6-2 to perform the function listed in Table 2.8.6-1 for the environmental conditions that could occur before and during a design basis accident.</li> </ul>	<ul style="list-style-type: none"> <li>a. The Class 1E equipment listed for harsh environment in Table 2.8.6-2 can perform the function listed in Table 2.8.6-1 before and during design basis accidents for the time required to perform the listed function.</li> </ul>

**Table 2.8.6-3—MFWS ITAAC (5 Sheets)**

<b>Commitment Wording</b>		<b>Inspections, Tests, Analyses</b>	<b>Acceptance Criteria</b>
		b. For equipment listed for harsh environment in Table 2.8.6-2, an inspection will be performed of the as-installed Class 1E equipment and the associated wiring, cables and terminations.	b. Inspection concludes the as-installed Class 1E equipment and associated wiring, cables, and terminations as listed in Table 2.8.6-2 for harsh environment conform with the design.
7.1	Class 1E valves listed in Table 2.8.6-2 perform the function listed in Table 2.8.6-1 under system conditions.	Tests and analyses or a combination of tests and analyses will be performed to demonstrate the ability of the valves listed in Table 2.8.6-2 to change position as listed in Table 2.8.6-1 under system design conditions.	The as-installed valve changes position as listed Table 2.8.6-1 under system design conditions.

[Next File](#)