

## 6.2.6 Containment Leakage Testing

The reactor containment, containment penetrations, and isolation barriers are designed to permit periodic leakage rate testing in accordance with GDC 52, GDC 53, and GDC 54. The containment leakage rate testing (CLRT) program complies with 10 CFR 50, Appendix J, Option B and follows the guidance of RG 1.163. The program is implemented in accordance with ANSI N45.4 (Reference 9) and ANSI/ANS 56.8 (Reference 10). The program is fully described, as defined in SRM-SECY-04-0032 (Reference 11), in this section.

A COL applicant that references the U.S. EPR design certification will identify the implementation milestones for the CLRT program described under 10 CFR 50, Appendix J.

### 6.2.6.1 Containment Integrated Leakage Rate Test (Type A)

#### Prerequisites

Following completion of the Reactor Building construction, preoperational and periodic leakage rate tests are conducted for all portions of mechanical, fluid, electrical, and instrumentation systems penetrating the containment.

The preoperational containment integrated leakage rate test (CILRT) is described in Section 14.2 (Test abstract #029) and is performed after the preoperational structural integrity test (SIT). CILRT is performed periodically at intervals that are specified by 10 CFR 50, Appendix J.

The following prerequisites and system alignment are required prior to test performance:

- Type B and Type C local leakage rate tests are performed.
- Containment isolation system functionality is verified.
- A general inspection of the accessible interior and exterior surfaces of the primary containment structure and components is performed to identify evidence of structural deterioration that might affect either the primary containment structural integrity or tightness.
- The visual examination of containment concrete surfaces is performed in accordance with the requirements specified by the ASME Boiler and Pressure Vessel Code (ASME Code) Section XI (Reference 12), Subsection IWL, except where relief has been authorized by the NRC.
- The visual examination of the steel liner plate inside containment is performed in accordance with the requirements specified by the ASME Code Section XI, Subsection IWE, except where relief has been authorized by the NRC. Corrective

action is taken prior to performing the Type A test if there is evidence of structural deterioration.

- Containment visual inspections will be performed during two refueling outages when Type A test intervals have been extended to 10 years.
- The structural deterioration and corrective action are reported in accordance with 10 CFR 50, Appendix J.
- During the period between the initiation of the containment inspection and the performance of the Type A test, no repairs or adjustments are made so that the containment can be tested in as close to the “as-is” condition as practical.
- All test instrument calibrations are verified as being current prior to initiation of the CILRT.
- The containment isolation valves are closed without performing preliminary exercising or adjustments. Table 6.2.4-1 provides the postaccident position for the valves and identifies any exceptions to valve position during testing.
- During the CILRT, flow paths that would be open to the containment atmosphere following a loss of coolant accident (LOCA) are drained and vented to the containment atmosphere. Flowpaths that are considered open are those that may have the system fluid drained or driven off by the LOCA or as a result of the line rupturing inside the containment.
- Fluid systems that are open directly to the containment atmosphere under post-accident conditions are opened or vented to the containment atmosphere prior to and during the test.
- Systems that would be normally operating under post-LOCA conditions are not vented during the test and are identified as essential systems in Table 6.2.4-1.
- Tanks inside the containment are vented to the containment atmosphere as necessary to protect them from the effects of external test pressure or to preclude leakage that could affect test results. Similarly, instrumentation and other components that could be adversely affected by the test pressure are vented or removed from containment.
- Certain instrumentation lines that penetrate containment are identified in the test plan and isolated during the CILRT. For those lines isolated, valves are aligned as appropriate and local leak rate testing (LLRT) performed. Results of these LLRTs are added to the CILRT result. Upon completion of the CILRT, valves are realigned to return these instrumentation lines to their normal configurations.

In accordance with 10 CFR 50, Appendix J, the containment atmospheric conditions are allowed to stabilize for a period of time prior to beginning the leakage rate test. The CILRT test procedure addresses the specific time period.

## Methodology

The Type A test is conducted in accordance with ANSI N45.4, the Total Time and Point-to-Point methods, or ANSI/ANS-56.8, the Mass Point Method. The duration of testing after the stabilization period is established consistent with these standards. Changes in containment air mass during this time are calculated using periodic measurements of containment pressure, dry bulb temperature, and dew point temperatures (i.e., water vapor pressure).

Accuracy of the Type A test results is then verified by a supplemental verification test. The supplemental verification test is performed using the methodology for this purpose described by ANSI N45.4.

Type A tests use temporary air compressors, which are installed and connected to the permanent system piping. The number and capacity of the compressors is sufficient to pressurize the primary containment to test pressure. The compressors include air coolers, moisture separators, and air dryers to reduce the moisture content of the air entering the primary containment. Temperature and humidity sensors are installed inside containment for Type A testing. Data acquisition hardware and instrumentation is available outside containment. Instrumentation that is not required during normal plant operation may be installed temporarily for the Type A test.

The maximum allowable containment leakage rate denoted  $L_a$ , is not to exceed 0.25% of containment air weight per day at  $P_a$ . The conservative value for  $P_a$ , 55 psig, is greater than the calculated peak internal pressure associated with the design basis accident (DBA).

As soon as practical after completion of a Type A test that identified leakage, and prior to initiation of containment inspection for the subsequent Type A test, repairs or adjustments are made to components that exceeded individual leakage limits.

## Preservice Test

Preoperational Type A tests are conducted at peak pressure in accordance with 10 CFR 50, Appendix J, as follows:

- Peak pressure tests—A test is performed at pressure  $P_a$  to measure the leakage rate  $L_{am}$ .
- Peak pressure acceptance criteria—The leakage rate  $L_{am}$  is less than  $0.75 L_a$  at pressure  $P_a$ .
- If the Type A test fails to meet this criterion, a retest is conducted in accordance with the requirements of 10 CFR 50, Appendix J.

### Inservice Test

- Peak pressure tests—A test is performed at pressure  $P_a$  to measure the leakage rate  $L_{am}$ .
- Peak pressure acceptance criteria—The leakage rate  $L_{am}$  is less than  $0.75 L_a$ . If local leakage measurements are taken to effect repairs in order to meet the acceptance criteria, these measurements are taken at a test pressure  $P_a$ .
- The as-found value for  $L_a$  shall be  $\leq 1.0$ .
- The as-left value for  $L_a$  shall be  $\leq 0.75 L_a$ . This applies to both the preoperational (prior to unit initial startup) and the subsequent periodic Type A tests.
- If a Type A test fails to meet this criterion, the test schedule for subsequent tests is adjusted in accordance with the requirements of 10 CFR 50, Appendix J, as directed by the CLRT program.

#### 6.2.6.2 Containment Penetration Leakage Rate Tests (Type B)

Preoperational and periodic testing of containment penetrations (i.e., Type B leakage rate tests) are performed in accordance with 10 CFR 50, Appendix J. A list of containment penetrations subject to Type B tests is provided in Table 6.2.4-1.

The following containment penetrations receive preoperational and periodic Type B leakage rate tests:

- Penetrations designed with resilient seals, gaskets or sealant compounds.
- Air locks and associated door seals.
- Equipment and access hatches and associated seals.
- Electrical penetrations.

Portable test panels are used to perform the testing of containment penetration and isolation valve leak testing using either air or nitrogen. The panels include pressure regulators, filters, pressure gauges, and flow instrumentation as required to perform specific tests.

Containment penetrations and testing requirements are identified in Table 6.2.4-1. Type B testing is performed at a pressure of  $P_a$ .

Airlock testing acceptance criteria are:

- Overall air lock leakage  $\leq 0.05 L_a$  tested at  $\geq P_a$ .
- Leakage for each door  $\leq 0.01 L_a$  when pressurized to  $\geq 10$  psig.

The combined leakage rate for all penetrations and valves subject to Type B and C tests shall be less than  $0.60 L_a$ .

### 6.2.6.3 Containment Isolation Valve Leakage Rate Test (Type C)

Preoperational and periodic testing of CIVs (i.e., Type C leakage rate tests) are performed in accordance with 10 CFR 50, Appendix J. A list of CIVs subject to Type C tests is provided in Table 6.2.4-1. The applicable system piping and instrumentation diagrams (P&ID) illustrate CIV arrangements and test connections for Type C testing.

Type C leakage tests are performed by local pressurization. Each tested valve is closed by normal means without preliminary exercising or adjustments, and pressure is applied in the same direction as would be present during the DBA. If pressure is to be applied in the opposite direction, justification for the deviation is provided.

Portable test panels are used to perform the testing of containment penetration and isolation valve leak testing using either air or nitrogen. The panels include pressure regulators, filters, pressure gauges and flow instrumentation as required to perform specific tests.

Fixed test connections used for Type C testing are shown on the respective system P&IDs.

The valves are tested by pressurizing with either air or nitrogen at a pressure of  $P_a$ .

The combined leakage rate for all penetrations and valves subject to Type B and C tests shall be less than  $0.60 L_a$ .

### 6.2.6.4 Scheduling and Reporting of Periodic Tests

The NRC regulations in 10 CFR 50, Appendix J allow for a performance-based Option B for containment leakage testing. Test intervals are based on criteria established in Nuclear Energy Institute (NEI) 94-01 (Reference 13) in accordance with the regulatory positions stated in RG 1.163.

A summary report documents the preoperational and periodic tests and includes a schematic arrangement of the leakage rate measurement system, the instrumentation used, the supplemental test method, and the test program selected as applicable to the preoperational test and subsequent periodic tests. The report contains analysis and interpretation of the leakage rate test data for the Type A test and provides an evaluation of the results against the acceptance criteria.

The summary report includes periodic leakage test results from the Type A, B, and C tests and contains an analysis and interpretation of the Type A test results and a summary analysis of the periodic Type B and Type C tests that were performed since

the last Type A test. Leakage test results from Type A, B, and C tests that failed to meet the acceptance criteria are included in a separate accompanying summary report that includes an analysis and interpretation of the test data, the least squares fit analysis of the test data, the instrumentation error analysis, and the structural conditions of the containment or components, if any, that contributed to the failure in meeting the acceptance criteria. Results and analyses of the supplemental verification test employed to demonstrate the validity of the leakage rate test measurements are also included.

The CLRT program requirements and acceptance criteria are listed in the Technical Specifications program (Chapter 16), Section 5.5.15 for the Type A, B, and C leakage tests.

#### **6.2.6.5 Special Testing Requirements and Bypass Leakage**

The U.S. EPR Reactor Containment Building is completely enclosed by the Reactor Shield Building, forming an annulus between the two structures. The combined containment and shield buildings are penetrated by a variety of pipes, air locks, and hatches. These penetrations provide an escape mechanism by which atmosphere from the containment may leak when pressurized during accident conditions. A DBA will pressurize the containment to a pressure above atmospheric, providing the motive force for leakage from the containment to the annulus and other buildings.

Two basic categories of leakage paths are evaluated. The first category includes penetrations and seals that terminate within the secondary containment volume and the second category includes penetrations and seals that terminate outside the secondary containment volume. The latter category is the potential source of bypass leakage for which a reasonable and acceptable design leak rate must be established and periodically verified to remain within acceptable operational limits.

The first category of leakage is captured within the secondary containment. The annulus provides a volume to capture containment leakage that may occur during accident conditions. The annulus ventilation system (AVS) provides a subatmospheric pressure in relationship to the containment during normal and accident conditions. The leak-off system collects leakage from airlock door seals, ventilation system containment isolation valves, and fuel transfer tube isolation valves. These potential leakage paths of the leak-off system are routed to the annulus floor drains by the subatmospheric pressure provided by the AVS. The leak-off system forms part of the secondary containment bypass leakage barrier and is leakage rate tested in accordance with 10 CFR 50, Appendix J. Test connections are provided to facilitate leakage rate testing. The AVS and leak-off system provide the collection of the containment leakage and are discussed in Section 6.2.3.

The second category of leakage is considered bypass leakage and is evaluated by examining the potential bypass of the secondary containment. Penetrations and seals that terminate outside the secondary containment (outside the annulus) exit the Reactor Shield Building structure into either the Fuel Building or one of the four Safeguard Buildings. The ventilation systems for the Fuel Building and Safeguard Buildings are provided with filtering systems to capture radiological contaminants that may occur from a DBA. Therefore, any bypass leakage is processed by engineered safety features (ESF) filter systems before release. The ESF filters are described in Section 6.5.1. The fuel building ventilation system and the safeguard building controlled-area ventilation system are described in Section 9.4.2 and Section 9.4.5, respectively.

All penetrations that are welded or have mechanical connections are tested using methods that conform to regulatory requirements and guidance for measuring the leakage rate of potential bypass leakage paths in dual containment plant designs.

Containment penetrations identified as potential bypass leakage paths are listed in Table 6.2.4-1. The table provides a brief description of each penetration and provides a determination of potential bypass leakage path.

U.S. EPR design has no primary containment penetrations or seals that terminate outside the secondary containment to the general environment. Leakage through penetrations and seals that terminate in the secondary containment do not become bypass leakage during normal or accident operation modes. Therefore, the maximum combined leakage rate for all bypass penetrations is assumed to be zero ( $0.00 L_a$ ) at a primary containment pressure of  $P_a$ .

### 6.2.7 Fracture Prevention of Containment Pressure Vessel

Section 3.8.2 identifies the ferritic steel parts of the reactor containment pressure boundary and specifies how they meet the requirements of GDC 1 and GDC 16. The selected materials provide sufficient margin to assure that under operating, maintenance, testing, and postulated accident conditions:

- Ferritic materials behave in a nonbrittle manner.
- Probability of rapidly propagating fracture of the pressure boundary is minimized (GDC 51).

The materials of the carbon steel liner plate and carbon steel and low alloy steel attachments and appurtenances subject to ASME Section III (Reference 14), Division 2 requirements meet the fracture toughness requirements of ASME Section III, Division 2, Article CC-2520. Materials used in ASME Section III, Division 1 attachments and appurtenances meet the fracture toughness requirements of ASME Section III, Division 1, Article NE-2300. This provision meets the requirement that the reactor

containment pressure boundary remain intact during the harshest expected conditions, thereby precluding release of radioactivity to the environment.

### 6.2.8 References

1. BAW-10252(NP)-A, Revision 0, "Analysis of Containment Response to Postulated Pipe Ruptures Using GOTHIC," Framatome ANP, September 2005.
2. BAW-10168P-A, Revision 3, "BWNT Loss-of-Coolant Accident Evaluation Model for Recirculating Steam Generator Plants – Volume I – Large Break," B&W Nuclear Technologies, December 1996.
3. BAW-10164P-A, Revision 6, "RELAP5/ MOD2-BAW – An Advanced Computer Program for Light Water Reactor LOCA and Non-LOCA Transient Analyses," AREVA NP Inc., June 2007.
4. NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment," Revision 1, U.S. Nuclear Regulatory Commission, July 1981.
5. BAW-10169P-A, "B&W Safety Analysis Methodology for Recirculating Steam Generator Plants," B&W Fuel Company, October 1989.
6. Karwat, H., "State of the Art Report on Containment Thermal Hydraulics and Hydrogen Distribution," NEA/CSNI, June 1999.
7. ANSI/ANS-56.2, "Containment Isolation Provisions for Fluid Systems After a LOCA," American National Standards Institute/American Nuclear Society, 1989.
8. ANP-10268P, Revision 0, "U.S. EPR Severe Accident Evaluation," AREVA NP Inc., October 2006.
9. ANSI N45.4, "Leakage Rate Testing of Containment Structures for Nuclear Reactors," American National Standards Institute, 1972.
10. ANSI/ANS 56.8, "Containment System Leakage Testing Requirements," American National Standards Institute/American Nuclear Society, 1994.
11. SRM-SECY-04-0032, "Review of Operational Programs in a Combined License Application and Generic Emergency Planning Inspections, Tests, Analyses, and Acceptance Criteria," U.S. Nuclear Regulatory Commission, 2004.
12. ASME Boiler and Pressure Vessel Code, Section XI, "Rules for Inservice Inspection of Nuclear Power Plant Components," The American Society of Mechanical Engineers, 2004 Edition.
13. NEI 94-01, "Industry Guideline for Implementing Performance-Based Option of 10 CFR 50, Appendix J," Nuclear Energy Institute, 1995.



14. ASME Boiler and Pressure Vessel Code, Section III, "Rules for Construction of Nuclear Power Plant Components," The American Society of Mechanical Engineers, 2004 Edition.