

**From:** Vaidya, Bhalchandra  
**Sent:** Wednesday, June 17, 2009 8:22 AM  
**To:** 'Coddington, Cornelius T'; 'ckhoffman@pplweb.com';  
'dlfilchner@pplweb.com'; 'O'Rourke, Brenda W'  
**Cc:** Pickett, Douglas; Boska, John; Guzman, Richard; Miller, Kenn; Mathew, Roy  
**Subject:** Susq Units 1 and 2, ME0969 & ME0970, Revised RAIs from ITSB -Amd for T-20 Replacement, One-time Ext of AOT in TS 3.8.1

Brenda,

Revised wording for the RAIs (as approved by the ITSB/BC) are given below. The basic information needs have not changed.

Hope this version provides some clarity and would save some time in our discussions this afternoon.

=====

Request for Additional Information:

Susquehanna TS LCO 3.0.2 Bases State that "Entering ACTIONS for [Corrective Maintenance] must be done in a manner that does not compromise safety." PPL Susquehanna had requested and received two previous extensions for LCO 3.8.1, Required Action A.3, due to deficiencies in ST performance and operation in 2002 & 2003.

1. Justify that the third request to extend TS 3.8.1 Required Action A.3, for ST replacement at power since 2002, represents a plant corrective maintenance practice that is done in a manner that does not compromise safety.
2. Show that in making the third request for extending the completion time of LCO 3.8.1 Required Action A.3, to replace damaged/degraded station transformers considered the previous two requests thereby ensuring that intentional entry into ACTIONS was not made for operational convenience in accordance with LCO 3.0.2.
3. Explain why a third extension for replacing station transformers is not symptomatic of a design inadequacy with PPL Susquehanna in meeting the 72 hours Completion Time as required by LCO 3.8.1.

Bhalchandra K. Vaidya  
Licensing Project Manager  
NRC/NRR/DORL/LPL1-1  
(301)-415-3308 (O)  
[bhalchandra.vaidya@nrc.gov](mailto:bhalchandra.vaidya@nrc.gov)

---

**E-mail Properties**

Mail Envelope Properties ()

**Subject:** Susq Units 1 and 2, ME0969 & ME0970, Revised RAIs from ITSB -Amd for T-20 Replacement, One-time Ext of AOT in TS 3.8.1

Sent Date: 06/17/2009 8:10:41 AM  
Received Date: 06/17/2009 8:22:00 AM  
From: Vaidya, Bhalchandra

Created By: Bhalchandra.Vaidya@nrc.gov

Recipients:

ctcoddington@pplweb.com ('Coddington, Cornelius T')  
Tracking Status: None  
ckhoffman@pplweb.com ('ckhoffman@pplweb.com')  
Tracking Status: None  
dlfilchner@pplweb.com ('dlfilchner@pplweb.com')  
Tracking Status: None  
BWORourke@pplweb.com ('O'Rourke, Brenda W')  
Tracking Status: None  
Douglas.Pickett@nrc.gov (Pickett, Douglas)  
Tracking Status: None  
John.Boska@nrc.gov (Boska, John)  
Tracking Status: None  
Richard.Guzman@nrc.gov (Guzman, Richard)  
Tracking Status: None  
Kenneth.Miller2@nrc.gov (Miller, Kenn)  
Tracking Status: None  
Roy.Mathew@nrc.gov (Mathew, Roy)  
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	18002	06/17/2009

Options

Expiration Date:  
Priority: o!ImportanceNormal  
ReplyRequested: False  
Return Notification: False

Sensitivity: o!Normal

Recipients received: