


Path Name: C:\VPROJETS\252610\Draw - Unit 1 - Final\WP000571.005 - Contour Reporting and Recovery\DWG\WATER 17.dwg Dr: 2008/05/04 10:25:14 AM EST TABLE ELEVATION CONTOURS - JANUARY 2008.dwg
 Plot Date: 05/27/2009 1:28 PM
 User: M. Sharpe, Charlotte
 Page Set Up Name: -----
 © 2009 ARCADIS G&M, Inc.



- LEGEND:**
- WELL R** ■ MONITORING WELL SCREENED IN THE SHALLOW, WATER-BEARING UNIT WITHIN THE LIMITS OF THE COFFERDAM, 20 FEET DEEP-TYPICAL (WELLS M, N, O, R, AC, AE, AI AND AM).
 - WELL S** ⊙ MONITORING WELL SCREENED IN THE SHALLOW, WATER-BEARING UNIT OUTSIDE THE LIMITS OF THE COFFERDAM, 35 FEET DEEP-TYPICAL (WELLS S, T, U, W, Y, Z, AA, AB, AD, AF, AG(SHALLOW & DEEP, AH(SHALLOW & DEEP), AJ AND AL).
 - WELL L** ⊙ MONITORING WELL SCREENED IN THE VINCENTOWN FORMATION, 80 FEET DEEP-TYPICAL (WELLS K, L, P, Q AND V).
 - 23.00** HISTORIC GROUNDWATER ELEVATION (FEET ABOVE MEAN SEA LEVEL - NAVD 1988)
 - 3.19** GROUNDWATER ELEVATION (FEET ABOVE MEAN SEA LEVEL - NAVD 1988)
 - 1.00** GROUNDWATER ELEVATION CONTOUR (0.5 FOOT INTERVAL)
 - GROUNDWATER FLOW DIRECTION
 - LIMIT OF GROUNDWATER WITH TRITIUM ABOVE 1,000,000 pCi/L
 - LIMIT OF GROUNDWATER WITH TRITIUM ABOVE 500,000 pCi/L
 - LIMIT OF GROUNDWATER WITH TRITIUM ABOVE 100,000 pCi/L
 - LIMIT OF GROUNDWATER WITH TRITIUM ABOVE THE NEW JERSEY GROUNDWATER QUALITY CRITERION (20,000 pCi/L)
 - PROPERTY BOUNDARY
 - BLOW DOWN PIPING
 - LIQUID "RAD" WASTE LINE
 - SERVICE WATER PIPING
 - CIRCULATING WATER OUTLET PIPING
 - CIRCULATING WATER INLET PIPING
 - STORM SEWER PIPING
 - CATCH BASIN
 - MANHOLE (STORM SEWER)
 - SHEET PILE - EXTENDS FROM ABOVE THE WATER TABLE THROUGH THE KIRKWOOD FORMATION
 - SHEET PILE - DOES NOT EXTEND TO AN ELEVATION ABOVE THE WATER TABLE.
 - AFST** AUXILIARY FEEDWATER STORAGE TANK
 - PWST** PRIMARY WATER STORAGE TANK
 - RWST** REFUELING WATER STORAGE TANK
- NOTE:**
1. THE MEAN TIDE LEVEL OF THE DELAWARE RIVER AT ARTIFICIAL ISLAND IS 0.11 FT (NAVD 1988)
 2. CONTOUR INTERVAL FOR WATER LEVELS LESS THAN -1.0 FEET MSL IS LOGARITHMIC.
 3. EXTENT OF TRITIUM IN GROUNDWATER REPRESENTS DATA THROUGH DECEMBER 2007.
- * ESTIMATED BASED ON HISTORICAL DATA



Area Manager	R. GAN
Project Director	P. MILIONIS
Task Manager	C. SHARPE
Technical Review	C. SHARPE

6 Terry Drive
 Suite 300
 Newtown, Pa 18940
 Tel: 267/685-1800 Fax: 267/685-1801
 www.arcadis-us.com

PSEG NUCLEAR, LLC
SALEM GENERATING STATION
WATER TABLE ELEVATION CONTOURS DURING OPERATION OF THE
PERMANENT SYSTEM JANUARY 2008
HANCOCK'S BRIDGE, NEW JERSEY

Project Number	NP000571.005
Date	20 MAY, 2009
Figure	4

D-04