

Doris Mendiola

From: Ron Clow [ronald.clow@xenuclear.com]
Sent: Monday, June 15, 2009 11:07 AM
To: NRCREP Resource
Subject: Response from "Comment on NRC Documents"

6/20/09
74FR 2644D

Below is the result of your feedback form. It was submitted by

Ron Clow (ronald.clow@xenuclear.com) on Monday, June 15, 2009 at 11:07:16

(2)

Document_Title: DG-1192
Inservice Inspection Code Case Acceptability, ASME Section XI, Division 1

Comments: ASME XI Code Case N-508-4 is now included in published ASME Nuclear Codes Cases. It would be beneficial to plants to include this latest revision of CC N-508 in the next revision of RG-1.147.

At present the Draft Guide is at N-508-3 for this code case.

organization: NSPM Nuclear Fleet, DBA Xcel Energy

address1: 1717 Wakonade Dr. E.

address2:

city: Welch

state: MN

zip: 55089

country: USA

phone: 6513881121

RECEIVED

2009 JUN 16 PM 1:47

RULES AND DIRECTIVES
BRANCH
1819 PC

SUNSI Review Complete
Template = ADM-013

E-RFDs = ADM-03
Add = m. Baysie (MMBI)