

From: Chawla, Mahesh
Sent: Thursday, June 18, 2009 6:09 PM
To: Alan I Hassoun
Cc: Audrain, Margaret; Wengert, Thomas
Subject: Fermi 2 - Submittal of Inservice Inspection Program Relief Request RR-A35 - ME0867

By letter dated March 13, 2009, Detroit Edison (the licensee) requested relief (RR-A35) from certain American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section XI requirements. The licensee proposed an alternative to the sample population for Class 2, Category C-F-2, circumferential welds. Based on this review, it was determined that additional information is required to complete the staff's evaluation for the above request for relief. Please arrange a teleconference after 6/30/09 to discuss the following questions with the staff.

2.0 QUESTIONS

- 2.1 Identify the 17 welds that will no longer be reinspected.
- 2.2 Given these 17 welds would require volumetric examinations, and the 17 proposed new welds would not, provide a basis for the relaxed requirement. Is this safety based? Is this hardship based? Provide justification for either determination.
- 2.3 Please indicate the end date of the Second 10-year ISI Interval.

Mahesh Chawla
Phone: 301-415-8371
Fax: 301-415-1222

mahesh.chawla@nrc.gov

E-mail Properties

Mail Envelope Properties ()

Subject: Fermi 2 - Submittal of Inservice Inspection Program Relief Request RR-A35 - ME0867
Sent Date: 6/18/2009 6:05:44 PM
Received Date: 6/18/2009 6:08:00 PM
From: Chawla, Mahesh
Created By: Mahesh.Chawla@nrc.gov

Recipients:

hassouna@dteenergy.com (Alan I Hassoun)
Tracking Status: None
Margaret.Audrain@nrc.gov (Audrain, Margaret)

Tracking Status: None
Thomas.Wengert@nrc.gov (Wengert, Thomas)
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	8419	6/18/2009

Options

Expiration Date:

Priority: olImportanceNormal

ReplyRequested: False

Return Notification: False

Sensitivity: olNormal

Recipients received: