

REQUEST FOR ADDITIONAL INFORMATION 406-2896 REVISION 1

6/24/2009

US-APWR Design Certification

Mitsubishi Heavy Industries

Docket No. 52-021

SRP Section: 18 - Human Factors Engineering
Application Section: 18.2 Operating Experience Review

QUESTIONS for Operating Licensing and Human Performance Branch (AP1000/EPR Projects) (COLP)

18-48

Section 3.4.1 of NUREG-0711, Criterion 5 states: The OER should identify risk-important Human Actions (HAs) that have been assessed as being different or those actions in which errors have occurred. These human actions should be identified as requiring special attention during the design process to lessen their probability.

The Staff has reviewed MUAP-08014-P for the OER processes and MHI makes no mention in the report of risk-important HAs that have been either considered applicable or not applicable. MHI should clarify which elements of the OER report include the risk-important HA analysis.