

CCNPP3COLA PEmails

From: Rycyna, John
Sent: Tuesday, June 16, 2009 10:31 AM
To: Poche, Robert; katie.thurstin@unistarnuclear.com; Thompson, Jenise; michael.stevenson@unistarnuclear.com
Cc: CCNPP3COL Resource; Crane, Samantha; Peralta, Juan; Miernicki, Michael; Jennings, Jason; Colaccino, Joseph; Biggins, James; Vrahoretis, Susan; Simon, Marcia
Subject: Draft RAI No 121 CQVP 2434.doc
Attachments: Draft RAI No 121 CQVP 2434.doc

Rob,

Attached is DRAFT RAI No. 121. You have until June 30, 2009 to review it and to decide whether you need a conference call to discuss it. After the call or after June 30, 2009 the RAI will be finalized and sent to you. You then have 30 days to respond.

John Rycyna, PE
Sr. Project Manager
Division of New Reactor Licensing
Office of New Reactors
U.S. Nuclear Regulatory Commission
301-415-4122

Hearing Identifier: CalvertCliffs_Unit3Cola_Public_EX
Email Number: 757

Mail Envelope Properties (499C2FC6BB962446994CA8682D8ADF33188A486AA5)

Subject: Draft RAI No 121 CQVP 2434.doc
Sent Date: 6/16/2009 10:31:18 AM
Received Date: 6/16/2009 10:31:19 AM
From: Rycyna, John

Created By: John.Rycyna@nrc.gov

Recipients:

"CCNPP3COL Resource" <CCNPP3COL.Resource@nrc.gov>
Tracking Status: None
"Crane, Samantha" <Samantha.Crane@nrc.gov>
Tracking Status: None
"Peralta, Juan" <Juan.Peralta@nrc.gov>
Tracking Status: None
"Miernicki, Michael" <Michael.Miernicki@nrc.gov>
Tracking Status: None
"Jennings, Jason" <Jason.Jennings@nrc.gov>
Tracking Status: None
"Colaccino, Joseph" <Joseph.Colaccino@nrc.gov>
Tracking Status: None
"Biggins, James" <James.Biggin@nrc.gov>
Tracking Status: None
"Vrahoretis, Susan" <Susan.Vrahoretis@nrc.gov>
Tracking Status: None
"Simon, Marcia" <Marcia.Simon@nrc.gov>
Tracking Status: None
"Poche, Robert" <Robert.Poche@constellation.com>
Tracking Status: None
"katie.thurstin@unistarnuclear.com" <katie.thurstin@unistarnuclear.com>
Tracking Status: None
"Thompson, Jenise" <Jenise.Thompson@nrc.gov>
Tracking Status: None
"michael.stevenson@unistarnuclear.com" <michael.stevenson@unistarnuclear.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	434	6/16/2009 10:31:19 AM
Draft RAI No 121 CQVP 2434.doc		23662

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 121
DRAFT
6/16/2009

Calvert Cliffs Unit 3
UniStar
Docket No. 52-016

SRP Section: 14.02 - Initial Plant Test Program - Design Certification and New License Applicants
Application Section: 14.2

QUESTIONS for Quality and Vendor Branch 1 (AP1000/EPR Projects) (CQVP)

14.02-41

Revision 3 of the CCNPP3 FSAR incorporates by reference Section 9.4.11 of the U.S. EPR FSAR, "Essential Service Water Pump Building Ventilation System." In Revision 3 of the CCNPP3 FSAR, UniStar removed the supplemental text from Section 9.4.11, "Essential Service Water Pump Building Ventilation System," that describes the UHS Makeup Water Intake Structure Ventilation System and the UHS Electrical Building Ventilation System. Therefore, please revise Section 14.2.14.8, "UHS Makeup Water Intake Structure Ventilation System," and 14.2.14.9, "UHS Electrical Building Ventilation System," of the CCNPP3 FSAR to reflect this change.