



**Pacific Gas and
Electric Company®**

James R. Becker
Site Vice President

Diablo Canyon Power Plant
Mail Code 104/5/601
P. O. Box 56
Avila Beach, CA 93424

805.545.3462
Internal: 691.3462
Fax: 805.545.6445

June 16, 2009

PG&E Letter DCL-09-042

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Docket No. 50-275, OL-DPR-80
Diablo Canyon Unit 1

Completion of Unit 1 Actions in Response to Generic Letter 2004-02, "Potential
Impact of Debris Blockage on Emergency Recirculation During Design Basis
Accidents at Pressurized Water Reactors"

Reference:

1. PG&E Letter DCL-08-059, "Supplemental Response to Generic Letter 2004-02, 'Potential Impact of Debris Blockage on Emergency Recirculation During Design Basis Accidents at Pressurized Water Reactors' (Revision 1)," dated July 10, 2008.

Dear Commissioners and Staff:

By letter dated July 10, 2008 (Reference 1), Pacific Gas and Electric Company (PG&E) provided a revised supplemental response to Generic Letter (GL) 2004-02, "Potential Impact of Debris Blockage on Emergency Recirculation During Design Basis Accidents At Pressurized Water Reactors," for Diablo Canyon Power Plant Units 1 and 2.

Reference 1 identified the following actions to be completed prior to restart from the Unit 1 Fifteenth Refueling Outage (steam generator replacement outage): (1) installation of reflective metal insulation and stainless steel-jacketed Temp-Mat insulation on the replacement steam generators; and (2) installation of stainless steel-jacketed Temp-Mat insulation on pressurizer safety valve 8010A. Both actions have been completed.

There are no additional physical modifications required for Unit 1. Accordingly, Unit 1 is in compliance with the regulatory requirements listed in the Applicable Regulatory Requirements section of GL 2004-02.

PG&E makes no regulatory commitments (as defined by NEI 99-04) in this letter.

If you have any questions, or require additional information, please contact Stan Ketelsen at (805) 545-4720.

ALL
NRR



I state under penalty of perjury that the foregoing is true and correct.

Executed on June 16, 2009.

Sincerely,

James R. Becker
Site Vice President

tcg/4231/50036807

cc: Gary W. Butner, Acting Branch Chief,
California Department of Public Health
Elmo E. Collins, NRC Region IV
Michael S. Peck, NRC Senior Resident Inspector
Alan B. Wang, NRC Project Manager
Diablo Distribution