

Shearon Harris Nuclear Power Plant Units 2 and 3

COL Application

Part 10

Proposed License Conditions (Including ITAAC)

|

Revision 1

|

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

Shearon Harris Nuclear Power Plant, Units 2 and 3 Proposed License Conditions

1. ITAAC (Inspections, Tests, Analyses, and Acceptance Criteria):

There are several ITAAC identified in the COLA. Once incorporated into the COL, the regulations identify the requirements that must be met.

PROPOSED LICENSE CONDITION:

The ITAAC identified in the tables in Appendix B are hereby incorporated into this Combined License. After the Commission has made the finding required by 10 CFR 52.103(g), the ITAAC do not constitute regulatory requirements; except for specific ITAAC, which are the subject of a Section 103(a) hearing; their expiration will occur upon final Commission action in such proceeding.

2. COL HOLDER ITEMS:

There are several COL information items that cannot be resolved prior to issuance of the Combined License. The referenced AP1000 design certification has already justified why each COL Holder item (as identified in the AP1000 DCD Tier 2 Table 1.8-2) cannot be resolved before the COL is issued, provides sufficient information on these items to support the NRC licensing decision, and identifies an appropriate implementation milestone. Each COL information item that cannot be resolved completely before the COL is issued is also identified as a COL Holder item in the COLA FSAR Table 1.8-202. Therefore, in accordance with the guidance in Regulatory Guide 1.206, Section C.III.4.3, the following License Condition is proposed to address these COL Holder items. Holder items (per DCD Table 1.8-2) that are addressed by the COLA are not included in the proposed condition. These include COL information item numbers 3.11-1, 9.5-6, 10.1-1, and 13.6-5.

PROPOSED LICENSE CONDITION:

Each COL Holder item identified below shall be completed by the identified implementation milestone through completion of the action therein identified.

SUMMARY OF COMBINED LICENSE INFORMATION HOLDER ITEMS			
COL Item No.	Subject	From DCD Tier 2 Subsection	Implementation Milestone
3.6-1a	Pipe Break Hazards Analysis	3.6.4.1	a. Prior to fabrication and installation of the piping and connected components
a. After a Combined License is issued, the following activity will be completed by the COL holder. An as-designed pipe rupture hazard evaluation will be available for review. This evaluation will be based on a completed piping layout and will be completed to support the combined license. A pipe rupture hazard analysis is part of the piping design. It is used to identify postulated break locations and layout changes, support design, whip			

Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC

SUMMARY OF COMBINED LICENSE INFORMATION HOLDER ITEMS			
COL Item No.	Subject	From DCD Tier 2 Subsection	Implementation Milestone
	<p>restraint design, and jet shield design. A report addressing environmental, spray, and flooding effects of cracks in moderate energy piping is also completed for the as-designed condition. The as-designed pipe rupture hazard evaluation reports are prepared on a generic basis to address all COL applications referencing the AP1000 Design Certification.</p> <p>The final piping design includes the properties and characteristics of procured components connected to the piping and target characteristics and locations. The evaluations will be provided prior to fabrication and installation of the piping and connected parts.</p>		
3.6-1b	Pipe Break Hazards Analysis	3.6.4.1	b. Prior to initial fuel load
	<p>b. After a Combined License is issued, the following activity will be completed by the COL holder. The as-built reconciliation of the pipe break hazards analysis in accordance with the criteria outlined in subsections 3.6.1.3.2 and 3.6.2.5 will be completed prior to fuel load.</p>		
3.7-3	Seismic Interaction Review	3.7.5.3	Prior to initial fuel load
	<p>The seismic interaction review will be updated by the Combined License holder for as-built information. This review is performed in parallel with the seismic margin evaluation. The review is based on as-procured data, as well as the as-constructed condition. The as-built seismic interaction review is not provided with the COL application, but is completed prior to fuel load.</p>		
3.7-4	Reconciliation of Seismic Analyses of Nuclear Island Structures	3.7.5.4	Prior to initial fuel load
	<p>The Combined License holder will reconcile the seismic analyses described in subsection 3.7.2 for detail design changes, such as those due to as-procured or as-built changes in component mass, center of gravity, and support configuration based on as-procured equipment information. Deviations are acceptable based on an evaluation consistent with the methods and procedure of Section 3.7 provided the amplitude of the seismic floor response spectra, including the effect due to these deviations, does not exceed the design basis floor response spectra by more than 10 percent. The Combined License holder will complete this reconciliation prior to fuel load.</p>		
3.9-2	Design Specification and Reports	3.9.8.2	Prior to initial fuel load
	<p>After a Combined License is issued, the following activities are completed by the COL holder:</p> <p>Reconciliation of the as-built piping (verification of the thermal cycling and stratification loadings considered in the stress analysis discussed in subsection 3.9.3.1.2) is completed by the COL holder after the construction of the piping systems and prior to fuel load.</p>		
4.4-2	Confirm Assumptions for Safety Analyses DNBR Limits	4.4.7	Prior to initial fuel load
	<p>Combined License applicants referencing the AP1000 certified design will address changes to</p>		

Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC

SUMMARY OF COMBINED LICENSE INFORMATION HOLDER ITEMS			
COL Item No.	Subject	From DCD Tier 2 Subsection	Implementation Milestone
	<p>the reference design of the fuel, burnable absorber rods, rod cluster control assemblies, or initial core design from that presented in the DCD.</p> <p>Following selection of the actual plant operating instrumentation and calculation of the instrumentation uncertainties of the operating plant parameters as discussed in subsection 7.1.6, Combined License applicants will calculate the design limit DNBR values using the RTDP with these instrumentation uncertainties and confirm that either the design limit DNBR values as described in Section 4.4 remain valid, or that the safety analysis minimum DNBR bounds the new design limit DNBR values plus DNBR penalties, such as rod bow penalty.</p>		
5.3-1	Reactor Vessel Pressure – Temperature Limit Curves	5.3.6.1	Prior to initial fuel load
	The COL Holder shall update the P/T limits using the PTLR methodologies approved in the AP1000 DCD using plant-specific material properties or confirm that the reactor vessel material properties meet the specifications and use the Westinghouse generic PTLR curves.		
5.3-4	Reactor Vessel Materials Properties Verification	5.3.6.4.1	Prior to initial fuel load
	The Combined License holder will complete prior to fuel load verification of plant-specific belt line material properties consistent with the requirements in subsection 5.3.3.1 and Tables 5.3-1 and 5.3-3. The verification will include a pressurized thermal shock evaluation based on as-procured reactor vessel material data and the projected neutron fluence for the plant design objective of 60 years. This evaluation report will be submitted for NRC staff review.		
9.1-7	Coupon Monitoring Program	9.1.6	Prior to commercial operation
	A spent fuel rack Metamic coupon monitoring program is to be implemented when the plant is placed into commercial operation. This program includes tests to monitor bubbling, blistering, cracking, or flaking; and a test to monitor for corrosion, such as weight loss measurements and or visual examination.		
10.2-1	Turbine Maintenance and Inspection	10.2.6	Prior to initial fuel load
	The Combined License holder will submit to the NRC staff for review prior to fuel load, and then implement a turbine maintenance and inspection program. The program will be consistent with the maintenance and inspection program plan activities and inspection intervals identified in subsection 10.2.3.6. The Combined License holder will have available plant-specific turbine rotor test data and calculated toughness curves that support the material property assumptions in the turbine rotor analysis after the fabrication of the turbine and prior to fuel load.		
14.4-2	Test Specifics and Procedures	14.4.2	Prior to initial fuel load
	NOTE –addressed by proposed License Condition Number 6.		
14.4-3	Conduct of Test Program	14.4.3	Prior to initiating test program
	A site-specific startup administration manual (procedure), which contains the administration		

Rev. 1

Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC

SUMMARY OF COMBINED LICENSE INFORMATION HOLDER ITEMS			
COL Item No.	Subject	From DCD Tier 2 Subsection	Implementation Milestone
	procedures and requirements that govern the activities associated with the plant initial test program, as identified in DCD Subsection 14.2.3 and as described in APP-GW-GLR-038 (DCD Reference 2), is provided prior to initiating the plant initial test program.		
14.4-4	Review and Evaluation of Test Results	14.4.4	Prior to initial fuel load
	The Combined License holder is responsible for review and evaluation of individual test results as well as final review of overall test results and for review of selected milestones or hold points within the test phases. Test exceptions or results which do not meet acceptance criteria are identified to the affected and responsible design organizations, and corrective actions and retests, as required, are performed.		
14.4-6	First-Plant-Only and Three-Plant-Only Tests	14.4.6	Prior to preoperational testing
	<p>The COL holder for the first plant and the first three plants will perform the tests listed in subsection 14.2.5. For subsequent plants, either tests listed in subsection 14.2.5 shall be performed, or the COL applicant shall provide a justification that the results of the first-plant-only tests or first-three-plant tests are applicable to the subsequent plant.</p> <p>The Combined License holder(s) for the first AP1000 plant (or first three plants) available for testing will perform the tests defined during preoperational and startup testing as identified in subsections 14.2.9 and 14.2.10. Combined License holders referencing the results of the tests will provide the report as necessary. The schedule for providing this information will be provided prior to preoperational testing.</p>		
19.59.10-1	As-Built SSC HCLPF Comparison to Seismic Margin Evaluation	19.59.10.5	Prior to initial fuel load
	<p>The Combined License holder referencing the AP1000 certified design will review differences between the as-built plant and the design used as the basis for the AP1000 seismic margins analysis prior to fuel load. A verification walkdown will be performed with the purpose of identifying differences between the as-built plant and the design. Any differences will be evaluated to determine if there is a significant adverse effect on the seismic margins analysis results. Spatial interactions are addressed by COL information item 3.7-3. Details of the process will be developed by the Combined License holder.</p> <p>The Combined License holder referencing the AP1000 certified design should compare the as-built SSC HCLPFs to those assumed in the AP1000 seismic margin evaluation prior to fuel load. Deviations from the HCLPF values or assumptions in the seismic margin evaluation due to the as-built configuration and final analysis should be evaluated to determine if vulnerabilities have been introduced. The requirements to which the equipment is to be purchased are included in the equipment specifications. Specifically, the equipment specifications include:</p> <ol style="list-style-type: none"> 1. Specific minimum seismic requirements consistent with those used to define the Table 19.55-1 HCLPF values. This includes the known frequency range used to define the HCLPF by 		

Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC

SUMMARY OF COMBINED LICENSE INFORMATION HOLDER ITEMS			
COL Item No.	Subject	From DCD Tier 2 Subsection	Implementation Milestone
<p>comparing the required response spectrum (RRS) and test response spectrum (TRS). The range of frequency response that is required for the equipment with its structural support is defined.</p> <p>2. Hardware enhancements that were determined in previous test programs and/or analysis programs will be implemented.</p>			
19.59.10-2	Evaluation of As-Built Plant Versus Design in AP1000 PRA and Site-Specific PRA External Events	19.59.10.5	Prior to initial fuel load
<p>The Combined License holder referencing the AP1000 certified design will review differences between the as-built plant and the design used as the basis for the AP1000 PRA and Table 19.59-18 prior to fuel load. If the effects of the differences are shown, by a screening analysis, to potentially result in a significant increase in core damage frequency or large release frequency, the PRA will be updated to reflect these differences.</p>			
19.59.10-3	Internal Fire and Internal Flood Analyses	19.59.10.5	Prior to initial fuel load
<p>The Combined License holder referencing the AP1000 certified design will review differences between the as-built plant and the design used as the basis for the AP1000 internal fire and internal flood analysis prior to fuel load. Differences will be evaluated to determine if there is significant adverse effect on the internal fire and internal flood analysis results.</p>			
19.59.10-4	Develop and Implement Severe Accident Management Guidance	19.59.10.5	Prior to startup testing
NOTE – addressed by proposed License Condition #6.			
19.59.10-5	Equipment Survivability	19.59.10.5	Prior to initial fuel load
<p>The Combined License holder referencing the AP1000 certified design will perform a thermal lag assessment of the as-built equipment listed in Tables 6b and 6c in Attachment A of APP-GW-GLR-069 to provide additional assurance that this equipment can perform its severe accident functions during environmental conditions resulting from hydrogen burns associated with severe accidents. This assessment is performed prior to fuel load and is required only for equipment used for severe accident mitigation that has not been tested at severe accident conditions. The Combined License holder will assess the ability of the as-built equipment to perform during severe accident hydrogen burns using the Environment Enveloping method or the Test Based Thermal Analysis method discussed in EPRI NP-4354.</p>			

3. OPERATIONAL PROGRAM IMPLEMENTATION:

The provisions of the regulations address implementation milestones for some operational programs. The NRC will use license conditions to ensure implementation for those operational programs whose implementation is not addressed in the regulations. COLA FSAR Section

Rev. 1

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

13.4, Table 13.4-201, identifies several programs required by regulations that must be implemented by a milestone to be identified in a license condition.

PROPOSED LICENSE CONDITION:

The licensee shall implement the programs or portions of programs identified in FSAR Table 13.4-201 on or before the associated milestones in FSAR Table 13.4-201.

- A. Construction Initiation – The licensee shall implement each operational program identified below prior to initiating construction of nuclear safety or security related structures, systems, or components.
 - A.1 – Fitness for Duty (Construction)
- B. 18 Months Prior to Fuel Load – The licensee shall implement each operational program identified below at least 18 months prior to scheduled date of initial fuel load.
 - B.1 – Reactor Operator Training
- C. Receipt of Materials – The licensee shall implement each operational program identified below prior to initial receipt of byproduct, source, or special nuclear materials on-site (excluding Exempt Quantities as described in 10 CFR 30.18).
 - C.1 – Radiation Protection (applicable portions)
- D. Fuel Receipt – The licensee shall implement each operational program identified below prior to initial receipt of fuel on-site.
 - D.1 – Fire Protection (applicable portions)
 - D.2 – Radiation Protection (applicable portions)
 - D.3 – Security Program (applicable portions)
- E. Construction Testing – The licensee shall implement each operational program identified below prior to initial construction testing.
 - E.1 – Initial Test Program – Construction Testing
- F. Preoperational Testing – The licensee shall implement each operational program identified below prior to initial preoperational testing.
 - F.1 – Initial Test Program – Preoperational Testing
- G. Fuel Loading – The licensee shall implement each operational program identified below prior to initial fuel load.
 - G.1 – Environmental Qualification
 - G.2 – Pre-Service Testing
 - G.3 – Process and Effluent Monitoring and Sampling
 - G.4 – Radiation Protection (applicable portions)
 - G.5 – Motor-Operated Valve Testing
 - G.6 – Fire Protection
 - G.7 – Fitness for Duty (Operation)
 - G.8 – Containment Leakage Rate Testing Program
- H. Startup Testing – The licensee shall implement each operational program identified below prior to initial startup testing.

Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC

H.1-Initial Test Program – Startup Testing

- I. MODE 4 – Not Used.
- J. Initial Criticality – The licensee shall implement each operational program identified below prior to initial criticality.
 - J.1 – Reactor Vessel Material Surveillance
- K. Waste Shipment – The licensee shall implement each operational program identified below prior to initial radioactive waste shipment.
 - K.1 – Radiation Protection

4. Not Used.

5. SECURITY PROGRAM REVISIONS:

An implementation license condition approved in the SRM regarding SECY-05-0197 applies to the Security Program.

PROPOSED LICENSE CONDITION:

The licensee shall maintain in effect the provisions of the physical security plan, security personnel training and qualification plan, and safeguards contingency plan, and all amendments made pursuant to the authority of 10 CFR 50.90, 50.54(p), 52.97, and Section VIII of Appendix D to Part 52 when nuclear fuel is on-site, and continuing until all nuclear fuel is permanently removed from the site.

6. OPERATIONAL PROGRAM READINESS:

The NRC inspection of operational programs will be the subject of the following license condition in accordance with SECY-05-0197:

PROPOSED LICENSE CONDITION:

The licensee shall submit to the appropriate Director of the NRC, a schedule, no later than 12 months after issuance of the COL, that supports planning for and conduct of NRC inspections of operational programs listed in the operational program FSAR Table 13.4-201. The schedule shall be updated every 6 months until 12 months before scheduled fuel loading, and every month thereafter until either the operational programs in the FSAR table have been fully implemented or the plant has been placed in commercial service, whichever comes first.

- a. This schedule shall include a submittal schedule for the emergency planning implementing procedures to the NRC consistent with 10 CFR Part 50, Appendix E, Section V.
- b. This schedule shall include a schedule for the development of a site specific Severe Accident Management Guidance.
- c. This schedule shall include a submittal schedule for the reactor vessel pressurized thermal shock evaluation at least 18 months prior to initial fuel load.
- d. This schedule shall include a submittal schedule for approved preoperational and startup test procedures in accordance with FSAR Section 14.2.3.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

7. VENDOR AE CONSTRUCTOR QUALIFICATIONS:

COLA FSAR Subsection 1.4.1 indicates that the applicant has not yet identified some of the major participants in the construction of the power plant. Thus, the technical qualifications of the NSSS vendor, architect-engineer, and constructor, and the division of responsibility among them could not be reviewed.

PROPOSED LICENSE CONDITION:

Prior to commencement of construction, the licensee shall submit a license amendment request that 1) identifies the NSSS vendor, architect-engineer, and constructor; 2) describes their technical qualifications; and 3) describes the division of responsibility among them.

8. STARTUP TESTING:

COLA FSAR Section 14.2 specifies certain startup tests that must be completed after fuel load. Operating licenses typically have included the following condition related to startup testing.

PROPOSED LICENSE CONDITION:

Any changes to the Initial Startup Test Program described in Chapter 14 of the FSAR made in accordance with the provisions of 10 CFR 50.59 or Section VIII of Appendix D to 10 CFR Part 52 shall be reported in accordance with 50.59(d) within one month of such change.

9. Not used.

10. ENVIRONMENTAL PROTECTION PLAN:

Operating licenses typically have included the following condition related to environmental protection.

PROPOSED LICENSE CONDITION:

The issuance of this COL, subject to the Environmental Protection Plan and the conditions for the protection of the environment set forth herein, is in accordance with the National Environmental Policy Act of 1969, as amended, and with applicable sections of 10 CFR Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions," as referenced by Subpart C of 10 CFR Part 52, "Early Site Permits; Standard Design Certifications; and Combined Licenses for Nuclear Power Plants," and all applicable requirements therein have been satisfied.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

Appendix A: Environmental Protection Plan (Nonradiological)

1.0 Objectives of the Environmental Protection Plan

The purpose of the Environmental Protection Plan (EPP) is to provide for protection of nonradiological environmental resources during construction and operation of the nuclear facility. The principal objectives of the EPP are as follows:

- (1) Verify that the facility is operated in an environmentally acceptable manner, as established by the Final Environmental Impact Statement (FEIS) and other NRC environmental impact assessments.
- (2) Coordinate NRC requirements and maintain consistency with other Federal, State and local requirements for environmental protection.
- (3) Keep NRC informed of the environmental effects of facility construction and operation and of actions taken to control those effects.

Environmental concerns identified in the FEIS, which relate to water quality matters, are regulated by way of the licensee's NPDES permit.

2.0 Environmental Protection Issues

In the FEIS dated [month year], the staff considered the environmental impacts associated with the construction and operation of the Shearon Harris Nuclear Power Plant, Units 2 and 3 (HAR 2 and 3). Certain environmental issues were identified which required study or license conditions to resolve environmental concerns and to assure adequate protection of the environment.

2.1 Aquatic Issues

No specific nonradiological aquatic impact issues were identified by NRC staff in the FEIS.

2.2 Terrestrial Issues

No specific nonradiological terrestrial impact issues were identified by NRC staff in the FEIS.

3.0 Consistency Requirements

3.1 Plant Design, Construction, and Operation Activities

The licensee may make changes in station design or operation or perform tests or experiments affecting the environment provided such activities do not involve an unreviewed environmental question and do not involve a change in the EPP*. Changes in station design or operation or performance of tests or experiments which do not affect the environment are not subject to the requirements of this EPP. Activities governed by Section 3.3 are not subject to the requirements of this section.

Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC

Before engaging in additional construction or operational activities, which may significantly affect the environment, the licensee shall prepare and record an environmental evaluation of such activity. Activities are excluded from this requirement if all measurable nonradiological environmental effects are confined to the on-site-areas previously disturbed during site preparation and plant construction. When the evaluation indicates that such activity involves an unreviewed environmental question, the licensee shall provide a written evaluation of such activity and obtain prior NRC approval. When such activity involves a change in the EPP, such activity and change to the EPP may be implemented only in accordance with an appropriate license amendment as set forth in Section 5.3 of this EPP.

A proposed change, test, or experiment shall be deemed to involve an unreviewed environmental question if it concerns: (1) a matter which may result in a significant increase in any adverse environmental impact previously evaluated in the FEIS, environmental impact appraisals, or in any decisions of the Atomic Safety and Licensing Board; or (2) a significant change in effluents or power level; or (3) a matter, not previously reviewed and evaluated in the documents specified in (1) of this Subsection, which may have a significant adverse environmental impact.

The licensee shall maintain records of changes in facility design or operation and of tests and experiments carried out pursuant to this Subsection. These records shall include written evaluations which provide bases for the determination that the change, test, or experiment does not involve an unreviewed environmental question or constitute a decrease in the effectiveness of this EPP to meet the objectives specified in Section 1.0. The licensee shall include as part of the Annual Environmental Operating Report (per Subsection 5.4.1 of this EPP) brief descriptions, analyses, interpretations, and evaluations of such changes, tests, and experiments.

* This provision does not relieve the licensee of the requirements of 10 CFR 50.59.

3.2 Reporting Related to the NPDES Permit and State Certification

Changes to, or renewals of, the NPDES Permits or the State certification shall be reported to the NRC within 30 days following the date the change or renewal is approved. If a permit or certification, in part or in its entirety, is appealed and stayed, the NRC shall be notified within 30 days following the date the stay is granted.

The licensee shall notify the NRC of changes to the effective NPDES Permit proposed by the licensee by providing NRC with a copy of the proposed change at the same time it is submitted to the permitting agency. The licensee shall provide the NRC a copy of the application for renewal of the NPDES Permit at the same time the application is submitted to the permitting agency.

3.3 Changes Required for Compliance with Other Environmental Regulations

Changes in plant design or operation and performance of tests or experiments which are required to achieve compliance with other Federal, State, and local environmental regulations are not subject to the requirements of Section 3.1 of this EPP.

Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC

4.0 Environmental Conditions

4.1 Unusual or Important Environmental Events

The licensee shall evaluate and report to the NRC Operations Center within 24 hours (followed by a written report in accordance with Section 5.4 of this EPP) any occurrence of an unusual or important event that indicates or could result in significant environmental impact causally related to the construction activities or plant operation. The following are examples of unusual or important environmental events: on-site plant or animal disease outbreaks, mortality or unusual occurrence of any species protected by the Endangered Species Act of 1973, unusual fish kills, unusual increase in nuisance organisms or conditions, and unanticipated or emergency discharge of waste water or chemical substances.

Routine monitoring programs are not required to implement this condition.

4.2 Environmental Monitoring

4.2.1 Aquatic Monitoring

No specific nonradiological aquatic monitoring requirements were identified by NRC staff in the FEIS.

4.2.2 Terrestrial Monitoring

No specific nonradiological terrestrial monitoring requirements were identified by NRC staff in the FEIS.

5.0 Administrative Procedures

5.1 Review and Audit

The licensee shall provide for review and audit of compliance with the EPP. The audits shall be conducted independently; they may not be conducted by the individual or groups responsible for performing the specific activity. A description of the organizational structure utilized to achieve the independent review and audit function and results of the audit activities shall be maintained and made available for inspection.

5.2 Records Retention

The licensee shall make and retain records associated with this EPP in a manner convenient for review and inspection and shall make them available to the NRC on request.

The licensee shall retain records of construction and operation activities determined to potentially affect the continued protection of the environment for the life of the station. The licensee shall retain all other records relating to this EPP for five years or, where applicable, in accordance with the requirements of other agencies.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

5.3 Changes in the Environmental Protection Plan

Requests for changes in the EPP shall include an assessment of the environmental impact of the proposed change and a supporting justification. Implementation of such changes in the EPP shall not commence prior to NRC approval of the proposed changes in the form of a permit amendment incorporating the appropriate revision to the EPP.

5.4 Reporting Requirements

5.4.1 Routine Reports

An Annual Nonradiological Environmental Report describing implementation of this EPP for the previous year shall be submitted to the NRC prior to June 1 of each year. The initial report shall be submitted prior to June 1 of the year following issuance of the operating license.

The report shall include summaries and analyses of the results of the environmental protection activities required by Section 4.2 of this EPP for the report period, including a comparison with related preoperational studies, operational controls (as appropriate), and previous nonradiological environmental monitoring reports, and an assessment of the observed impacts of the plant operation on the environment. If harmful effects or evidence of trends toward irreversible damage to the environment are observed, the licensee shall provide a detailed analysis of the data and a proposed course of mitigating action.

The Annual Nonradiological Environmental Report shall also include:

- (1) A list of EPP noncompliances and the corrective actions taken to remedy them.
- (2) A list of changes in station design or operation, tests, and experiments made in accordance with Section 3.1 of this EPP, which involved a potentially significant unreviewed environmental question.
- (3) A list of nonroutine reports submitted in accordance with Subsection 5.4.2 of this EPP.

In the event that some results are not available by the report due date, the report shall be submitted noting and explaining the missing results. The missing results shall be submitted as soon as possible in a supplementary report.

5.4.2 Nonroutine Reports

The licensee shall submit a written report to the NRC within 30 days of occurrence of any event described in Section 4.1 of this plan. The report should:

- (1) Describe, analyze, and evaluate the event, including the extent and magnitude of the impact, and site preparation and preliminary construction activities underway at the time of the event,
- (2) Describe the likely cause of the event.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

- (3) Indicate the action taken to correct the reported event.
- (4) Indicate the corrective action taken to preclude repetition of the event and to prevent similar occurrences involving similar site preparation and preliminary construction activities.
- (5) Indicate the agencies notified and their preliminary responses.

For events reportable under this subsection that also require reports to other Federal, State or local agencies, the licensee shall report in accordance with those reporting requirements in lieu of the requirements of this subsection. The licensee shall provide the NRC with a copy of such report at the same time it submits it to the other agency.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

Appendix B. Inspections, Tests, Analysis and Acceptance Criteria

AP1000 DCD Tier 1 ITAAC

The Tier 1 information (including the ITAAC) of the referenced DCD is incorporated by reference with the following departures and/or supplements.

Security Hardware ITAAC

The security related ITAAC are included in the referenced DCD Tier 1 Subsection 2.6.9 as incorporated by reference above.

Plant Specific ITAAC

Add the following information to the information provided in the referenced DCD Tier 1 following Section 2.3.29:

2.3.30 Storm Drain System

No entry for this system.

2.3.31 Raw Water System

No entry for this system.

2.3.32 Harris Lake Makeup Water System

No entry for this system.

2.3.33 Yard Fire Water System

No entry for this system.

Add the following information to the information provided in the referenced DCD Tier 1 following Section 2.5.10:

2.5.11 Closed Circuit TV System

No entry for this system.

2.5.12 Meteorological and Environmental Monitoring System

No entry for this system.

Add the following information to the information provided in the referenced DCD Tier 1 following Section 2.6.11:

2.6.12 Transmission Switchyard and Offsite Power System

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

No entry for this system.

Emergency Planning ITAAC

The emergency planning ITAAC are included in the attached Table 3.8-1. Include these ITAAC after DCD Tier 1 Section 3.7.

Waterproof Membrane ITAAC

The waterproof membrane ITAAC is included in the attached Table 3.8-2. Include this ITAAC after DCD Tier 1 Section 3.7

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 1 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
1.0 Emergency Classification System			
10 CFR 50.47(b)(4) – A standard emergency classification and action level scheme, the bases of which include facility system and effluent parameters, is in use by the nuclear facility licensee, and State and local response plans call for reliance on information provided by facility licensees for determinations of minimum initial offsite response measures.	1.1 A standard emergency classification and emergency action level (EAL) scheme exists, and identifies facility system and effluent parameters constituting the bases for the classification scheme. [D.2]	1.1 An inspection of the Control Rooms, Technical Support Center (TSC), and Emergency Operations Facility (EOF) will be performed to verify that they have displays for retrieving facility system and effluent parameters as specified in the Emergency Classification and EAL scheme, and the displays are functional.	1.1 The specified parameters are retrievable in the Control Rooms, TSC and EOF, and the ranges of the displays encompass the values specified in the Emergency Classification and EAL scheme.
2.0 Notification Methods and Procedures			
10 CFR 50.47(b)(5) – Procedures have been established for notification, by the licensee, of State and local response organizations and for notification of emergency personnel by all organizations; the content of initial and follow-up messages to response organizations and the public has been established; and means to provide early notification and clear instruction to the populace within the plume exposure pathway Emergency Planning Zone have been established.	<p>2.1 The means exist to notify responsible State and local organizations within 15 minutes after the licensee declares an emergency. [E.2]</p> <p>2.2 The means exist to notify emergency response personnel. [E.1]</p>	<p>2.1 A test will be performed to demonstrate the capabilities for providing initial notification to the offsite authorities after a simulated emergency classification.</p> <p>2.2 A test of the primary and back-up ERO notification systems will be performed.</p>	<p>2.1 The State of North Carolina and the counties of Wake, Lee, Harnett, and Chatham receive notification within 15 minutes after the declaration of an emergency from the Control Room and the EOF.</p> <p>2.2 The primary and back-up ERO notification system tests result in:</p> <ul style="list-style-type: none"> • Emergency response personnel receiving the notification message; • Mobilization communication is validated by personnel response to the notification system or by telephone; • Response to electronic notification and plant page system is accomplished

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 2 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
	2.3 The means exist to notify and provide instructions to the populace within the plume exposure EPZ. [E.3]	2.3 The full test of notification capabilities will be conducted.	during normal working hours, and off hours. 2.3 Notification and clear instructions to the public are successfully accomplished in accordance with the emergency plan requirements.
3.0 Emergency Communications			
10 CFR 50.47(b)(6) – Provisions exist for prompt communications among principal response organizations to emergency personnel and to the public.	3.1 The means exist for communications among the Control Rooms, TSC, EOF, principal State and local emergency operations centers (EOCs), and environmental monitoring teams. [F3, F.5] 3.2 The means exist for communications from the Control Rooms, TSC, and EOF to the NRC headquarters and regional office EOCs (including establishment of the Emergency Response Data System (ERDS) [or its successor system] between the onsite computer system and	3.1 A test will be performed of the capabilities. The test for the contact with the principal EOCs and the environmental monitoring teams will be from the Control Room and the EOF. The TSC communication with the Control Room and the EOF will be performed. 3.2 A test is performed of the capabilities to communicate using ENS from each operating Control Room, TSC and EOF to the NRC headquarters and regional office EOCs. The Health Physics Network (HPN) is tested to ensure communications between the TSC and EOF with the NRC Operations Center. ERDS is established [or its	3.1 Communications (both primary and secondary methods/systems) are established between the Control Rooms, TSC and the EOF with the North Carolina Division of Emergency Management (NCDDEM) warning point and EOC; Wake County Warning Point and EOC; Lee County Warning Point and EOC; Harnett County Warning Point and EOC; and Chatham County Warning Point and EOC. Communications are established between the Control Rooms, TSC and the EOF with the HNP environmental monitoring teams. 3.2 Communications are established between the Control Rooms, TSC and EOF to the NRC headquarters and regional office EOCs utilizing the ENS. The TSC and EOF demonstrate communications with the NRC Operations Center using HPN. The access port for ERDS [or its successor system] is provided and successfully completes a transfer of data from the

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 3 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
	the NRC Operations Center.) [F.2.6]	successor system] between the onsite computer systems and the NRC Operations Center.	Operating Units to the NRC Operations Center.
4.0 Public Education and Information			
10 CFR 50.47(b)(7) – Information is made available to the public on a periodic basis on how they will be notified and what their initial actions should be in an emergency (e.g., listening to a local broadcast station and remaining indoors), the principal points of contact with the news media for dissemination of information during an emergency (including the physical location or locations) are established in advance, and procedures for coordinated dissemination of information to the public are established.	4.1 The licensee has provided space which may be used for a limited number of the news media. [H.1.5]	4.1 An inspection of the as-built facility/area provided for the news media will be performed in the Joint Information Center (JIC). The space provides adequate equipment to support JIC operation, including communications with the site and with the Emergency Operation Centers in the state and counties as well as a limited number of news media.	4.1 The as-built JIC includes equipment to support JIC operations, including communications with the EOF and State and County EOCs. Designated space is available for news media briefings.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 4 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
5.0 Emergency Facilities and Equipment			
10 CFR 50.47(b)(8) – Adequate emergency facilities and equipment to support the emergency response are provided and maintained.	5.1 The licensee has established a TSC and onsite OSC. [The TSC and OSC may be combined at a single location.] [H.1.2, H.1.3, Annexes 1 and 2]	5.1.1 An inspection of the as-built TSC and OSCs will be performed, including a test of the capabilities. These facilities will meet the criteria of NUREG-0696 with exceptions.	<p>5.1.1 The TSC has at least 1875 ft² of floor space (75 ft² per person for a minimum of 25 persons).</p> <p>5.1.2 Communications equipment is installed, and voice transmission and reception are accomplished between the Control Rooms, OSCs, and the EOF.</p> <p>5.1.3 The TSC ventilation systems include a high efficiency particulate air (HEPA), and charcoal filter and radiation monitors are installed.</p> <p>5.1.4 The TSC receives, stores, processes, and displays plant and environmental information, and enables the initiation of emergency measures and the conduct of emergency assessment. These capabilities are demonstrated during testing and acceptance activities.</p> <p>5.1.5 There is an OSC located inside the Unit's Protected Area. It is separate from the Control Room within the Protected Area.</p>

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 5 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
	5.2 The licensee has established an EOF. [H.1.4]	5.2 An inspection of the as-built EOF will be performed, including a test of the capabilities. This facility will meet the criteria of NUREG-0696, with exceptions.	<p>5.1.6 Communications equipment is installed, and voice transmission and reception are accomplished between the OSC and OSC Teams, the TSCs, and Control Rooms.</p> <p>5.2.1 The EOF working space size is at least 4800 ft² consistent with NUREG-0696 (at least 75 ft²/person).</p> <p>5.2.2 The EOF habitability is consistent with Table 2 of NUREG 0696:</p> <ul style="list-style-type: none"> • Well engineered for design life of plant. • Protection factor ≥ 5. • Located within 10 to 20 mi of the TSC. <p>5.2.3 Communications equipment is installed and voice transmission and reception are accomplished between the Control Rooms, TSC, EOF, environmental monitoring teams, NRC, State and county agencies, and JIC.</p> <p>5.2.4 Radiological data, meteorological data, and plant system data is displayed in the EOF.</p>

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 6 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
6.0 Accident Assessment			
10 CFR 50.47(b)(9) – Adequate methods, systems, and equipment for assessing and monitoring actual or potential offsite consequences of a radiological emergency condition are in use.	6.1 The means exist to provide initial and continuing radiological assessment throughout the course of an accident. [I, I.3]	6.1 A test will be performed to demonstrate that the means exist to provide initial and continuing radiological assessment throughout the course of an accident through the plant computer or communications with the Control Room.	6.1 Using selected monitoring parameters, simulated degraded plant conditions are assessed, and protective actions are initiated in accordance with the following criteria:
	6.2 The means exist to determine the source term of releases of radioactive material within plant systems, and the magnitude of the release of radioactive materials based on plant system parameters and effluent monitors. [I.3]	6.2 A test will be performed to demonstrate that the means exist to determine the source term of releases of radioactive material within plant systems, and the magnitude of the release of radioactive materials based on plant system parameters and effluent monitors.	A. Accident Assessment and Classification 1. Demonstrate the ability to identify initiating conditions, determine emergency action level (EAL) parameters, and correctly classify the emergency throughout the drill.
	6.3 The means exist to continuously assess the impact of the release of radioactive materials to the environment, accounting for the relationship between effluent monitor readings, and onsite and offsite exposures and contamination for various meteorological conditions. [I.4]	6.3 A test will be performed that provides evidence that the impact of a radiological release to the environment is able to be assessed by utilizing the relationship between effluent monitor readings, and onsite and offsite exposures and contamination for various meteorological conditions.	B. Radiological Assessment and Control 1. Demonstrate the ability to obtain onsite radiological surveys and samples. 2. Demonstrate the ability to continuously monitor and control radiation exposure to emergency workers. 3. Demonstrate the ability to activate environmental monitoring teams within 75 minutes of event declaration. 4. Demonstrate the ability to satisfactorily collect and disseminate field team data. 5. Demonstrate the ability to develop dose projections.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 7 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
			<p>6. Demonstrate the ability to make the decision whether to issue radioprotective drugs (KI) to emergency workers.</p> <p>7. Demonstrate the ability to develop appropriate protective action recommendations (PARs) and notify appropriate authorities within 15 minutes of development.</p> <p>6.2 Emergency plan implementing procedures provide sufficient direction to accurately calculate the source terms and the magnitude of the release of postulated accident scenario releases.</p> <p>6.3 Response personnel can continuously assess the impact of the release of radioactive materials to the environment, accounting for the relationship between effluent monitor readings, and onsite and offsite exposures and contamination for various meteorological conditions under drill conditions.</p>

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 8 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
	6.4 The means exist to acquire and evaluate meteorological information. [I.6]	6.4 A test will be performed to acquire and evaluate meteorological data/information.	<p>6.4 The following parameters are displayed in the TSC and control room:</p> <ul style="list-style-type: none"> • Windspeed (at 12m and 61m) • Wind direction (at 12m and 61m) • Barometric pressure (at 15m) • Delta-temperature (between 12m and 61m) • Ambient temperature (at 12m and 61m) • Dewpoint temperature (at 12m) • Precipitation (at 1.5m) • Solar radiation (at 1.5m) <p>This data is in the form needed to use in the appropriate emergency plan implementing procedures during drills and exercises.</p>
	6.5 The means exist to determine the release rate and projected doses if the instrumentation used for assessment is off-scale or inoperable. [I.4]	6.5 A test will be performed of the capabilities to determine the release rate and projected doses if the instrumentation used for assessment is off-scale or inoperable.	6.5 A drill or exercise is conducted that demonstrates the capability to determine the release rate and projected doses with the instrumentation used for assessment off-scale or inoperable.
	6.6 The means exist for environmental monitoring within the plume exposure EPZ. [I.7]	6.6 A test will be performed of the capabilities for environmental monitoring within the plume exposure EPZ.	6.6 A drill or exercise is conducted that demonstrates the ability of the environmental monitoring teams to be dispatched and locate and monitor a radiological release within the plume exposure EPZ.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 9 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
	6.7 The means exist to make rapid assessments of actual or potential magnitude and locations of radiological hazards through liquid or gaseous release pathways, including activation, notification means, field team composition, transportation, communication, monitoring equipment, and estimated deployment times. [I]	6.7 A test will be performed of the capabilities to make rapid assessments of actual or potential magnitude and locations of radiological hazards through liquid or gaseous release pathways, including activation, notification means, field team composition, transportation, communication, monitoring equipment, and estimated deployment times.	6.7 A drill or exercise is conducted that demonstrates the capability to activate the environmental monitoring teams). The team(s) demonstrates the capability to make rapid assessment of actual or potential magnitude and locations of any radiological hazards through simulated liquid or gaseous release pathways. A qualified environmental monitoring team is capable of being notified, activated, briefed and dispatched from the EOF during a radiological release scenario. The team demonstrates conformance with procedural guidance for team composition, use of monitoring equipment, communication from the field, and locating specific sampling locations.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 10 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
	<p>6.8 The capability exists to detect and measure radioiodine concentrations in air in the plume exposure EPZ, as low as 10^{-7} $\mu\text{Ci/cc}$ (microcuries per cubic centimeter) under field conditions. [I.7.1]</p> <p>6.9 The means exist to estimate integrated dose from the projected and actual dose rates, and for comparing these estimates with the EPA protective action guides (PAGs). [I.4]</p>	<p>6.8 A test will be performed of the capabilities to detect and measure radioiodine concentrations in air in the plume exposure EPZ, as low as 10^{-7} $\mu\text{Ci/cc}$ (microcuries per cubic centimeter) under field conditions.</p> <p>6.9 A test will be performed of the capabilities to estimate integrated dose from the projected and actual dose rates, and for comparing these estimates with the EPA protective action guides.</p>	<p>6.8 A drill or exercise is conducted that demonstrates the capability of an environmental monitoring team to be dispatched during a radiological release scenario and use sampling and detection equipment for air concentrations in the plume exposure EPZ, as low as 10^{-7} $\mu\text{Ci/cc}$.</p> <p>6.9 A drill or exercise is conducted that demonstrates the ability to estimate integrated dose from the dose assessment program and the environmental monitoring team reading during a radioactive release scenario. The results are successfully compared with the EPA Protective Action Guides (PAGs).</p>
7.0 Protective Response			
<p>10 CFR 50.47(b)(10) – A range of protective actions has been developed for the plume exposure EPZ for emergency workers and the public. In developing this range of actions, consideration has been given to evacuation, sheltering, and, as a supplement to these, the prophylactic use of potassium iodide (KI), as appropriate. Guidelines for the choice of protective actions during an emergency, consistent with Federal guidance, are developed and in place, and protective actions for the</p>	<p>7.1 The means exist to warn and advise onsite individuals of an emergency, including those in areas controlled by the operator, including:[J.1.1]</p> <ol style="list-style-type: none"> 1. employees not having emergency assignments; 2. visitors; 3. contractor and construction personnel; and 4. other persons who may be in the public access areas, on or passing through the 	<p>7.1 A test will be performed of the capabilities of the onsite warning system.</p>	<p>7.1 The following objectives to warn and advise onsite individuals are successfully satisfied during a drill or exercise:</p> <ol style="list-style-type: none"> A. Demonstrate the ability to perform assembly and accountability for all onsite individuals, including those identified below, within 30 minutes of an emergency requiring protected area evacuation and accountability: <ol style="list-style-type: none"> 1. non-essential employees;

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 11 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
ingestion exposure EPZ appropriate to the locale have been developed.	site, or within the owner controlled area.		2. visitors; 3. contractor and construction personnel. B. Demonstrate the ability to warn and advise other personnel within the owner controlled area. C. Demonstrate the ability to perform site dismissal.
	7.2 The means exist to radiologically monitor people evacuated from the site. [J.1.2] 7.3 The means exist to notify and protect all segments of the transient and resident populations. [J.2.1]	7.2 A test will be performed of the capabilities. 7.3 A test will be performed of the capabilities.	7.2 A drill or exercise is conducted that demonstrates the capability to radiologically monitor people evacuated from the site. Equipment is available, and personnel have been assigned and trained to procedures that are approved and in place to accomplish this activity. 7.3 A drill or exercise is conducted to demonstrate the capability of the Public Notification and Alerting System to successfully initiate a broadcast message to notify and protect all segments of the transient and resident populations.
8.0 Exercises and Drills			
10 CFR 50.47(b)(14) – Periodic exercises are (will be) conducted to evaluate major portions of	8.1 Licensee conducts a full participation exercise to evaluate major portions of	8.1 A full participation exercise (test) will be conducted within the specified time periods of Appendix E to 10 CFR	8.1.1 The exercise is completed within the specified time periods of Appendix E to 10 CFR Part 50,

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 12 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
emergency response capabilities, periodic drills are (will be) conducted to develop and maintain key skills, and deficiencies identified as a result of exercises or drills are (will be) corrected.	emergency response capabilities, which includes participation by each State and local agency within the plume exposure EPZ, and each State within the ingestion control EPZ. [N.1]	Part 50.	<p>onsite exercise objectives listed below have been met, and there are no uncorrected onsite exercise deficiencies.</p> <p><i>A. Accident Assessment and Classification</i></p> <p>1. Demonstrate the ability to identify initiating conditions, determine emergency action level (EAL) parameters, and correctly classify the emergency throughout the exercise in accordance with emergency plan implementing procedures.</p> <p><u>Standard Criteria:</u></p> <ul style="list-style-type: none"> a. The appropriate EAL condition associated with a parameter or symptom was recognized. b. The correct emergency classification is declared within 15 minutes of the time that the EAL condition was present. <p><i>B. Notifications</i></p> <p>1. Demonstrate the ability to alert, notify and mobilize site emergency response personnel, in accordance with emergency plan implementing procedures.</p> <p><u>Standard Criteria:</u></p>

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 13 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
			<p>a. Initiate a plant page announcement using the appropriate message scenario for ERO notification.</p> <p>b. Activate the computer based automated callout system at declaration of an Alert classification or higher.</p> <p>2. Demonstrate the ability to notify responsible State and local government agencies within 15 minutes and the NRC within 60 minutes after declaring an emergency, in accordance with emergency plan implementing procedures.</p> <p><u>Standard Criteria:</u></p> <p>a. Transmit information accurately to state and local agencies within 15 minutes of event classification.</p> <p>b. Transmit follow-up information accurately to state and local agencies within 60 minutes of last transmittal.</p> <p>c. Transmit information accurately within 60 minutes of event classification for an initial notification to the NRC.</p> <p>3. Demonstrate the ability to warn or</p>

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 14 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
			<p>advise onsite individuals of emergency conditions, in accordance with emergency plan implementing procedures.</p> <p><u>Standard Criteria:</u></p> <p>a. Initiate notification of onsite individuals of event declaration (via plant page, telephone, etc.),</p> <p>4. Demonstrate the capability of the Public Notification and Alerting System to operate properly for public notification when required, in accordance with emergency plan implementing procedures.</p> <p><u>Standard Criteria:</u></p> <p>a. Greater than 94% of ANS sirens are capable of performing their function as indicated by the feedback system. The clarifying notes listed in NEI 99-02, Regulatory Assessment Performance Indicator Guideline, will be used for this test.</p> <p>b. A NOAA tone alert radio is activated.</p> <p><i>C. Emergency Response</i></p> <p>1. Demonstrate the capability to direct and control emergency</p>

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 15 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
			<p>operations, in accordance with emergency plan implementing procedures.</p> <p><u>Standard Criteria:</u></p> <p>a. Facility command and control is demonstrated by the Shift Superintendent - Operations in the Control Room (simulator) upon event declaration, and by the Site Emergency Coordinator (SEC) in the Technical Support Center (TSC), and the Emergency Response Manager in the Emergency Operations Facility (EOF) within 60-75 minutes of ERO notification.</p> <p>2. Demonstrate the ability to transfer overall command and control from the Shift Superintendent-Operations in the Control Room (simulator) to the Site Emergency Coordinator (SEC) in the TSC and Emergency Response Manager in the EOF, in accordance with emergency plan implementing procedures.</p> <p><u>Standard Criteria:</u></p> <p>a. Evaluation of briefings that were conducted prior to turnover includes current plant conditions, radiological release information, response efforts and priorities, and the formal relief of delegable</p>

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 16 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
			<p>and non-delegable responsibilities.</p> <p>3. Demonstrate the ability to maintain continuous staffing of the emergency response facilities for a protracted period, in accordance with emergency plan implementing procedures.</p> <p><u>Standard Criteria:</u></p> <p>a. Complete shift relief schedule adequate to support 24-hour staffing.</p> <p>4. Demonstrate the ability to perform assembly and accountability for all onsite individuals within 30 minutes of an emergency requiring a Protected Area evacuation and accountability, in accordance with emergency plan implementing procedures.</p> <p><u>Standard Criteria:</u></p> <p>a. All Protected Area personnel are assembled in their designated assembly area and accountability is completed within 30 minutes of an emergency requiring Protected Area evacuation and accountability.</p>

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 17 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
			<p><i>D. Emergency Response Facilities</i></p> <p>1. Demonstrate activation of the Operations Support Center (OSC), Technical Support Center (TSC), Emergency Operations Facility (EOF), and Joint Information Center (JIC), in accordance with emergency plan implementing procedures.</p> <p><u>Standard Criteria:</u></p> <p>a. The TSC, OSC, and EOF are activated within approximately one (1) hour of an Alert or higher emergency declaration with at least minimum staffing.</p> <p>b. JIC minimum staffing positions are available within approximately two (2) hours of an Alert or higher emergency declaration.</p> <p>2. Demonstrate the adequacy of equipment, security provisions, and habitability precautions for the TSC, OSC, EOF, and Joint Information Center (JIC), as appropriate, in accordance with emergency plan implementing procedures.</p> <p><u>Standard Criteria:</u></p> <p>a. The adequacy of the emergency equipment in the emergency response facilities,</p>

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 18 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
			<p>including availability and consistency with emergency plan implementing procedures, supported the accomplishment of all of the evaluated performance objectives.</p> <p>b. The Security Director implements and performs all appropriate steps from the emergency plan implementing procedures for the ingress, egress, and control of onsite and offsite personnel responding to the site during the scenario.</p> <p>c. The Radiological Control Director (TSC) and staff correctly implement and perform all appropriate steps from the emergency plan implementing procedures when a simulated onsite/offsite release has occurred during the scenario.</p> <p>3. Demonstrate communications from the emergency response facilities and the adequacy of communications for all emergency support resources, in accordance with emergency plan implementing procedures.</p> <p><u>Standard Criteria:</u></p> <p>a. Emergency response communications are available and operational.</p>

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 19 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
			<ul style="list-style-type: none"> b. Communications systems are adequate to support CR, TSC, OSC, EOF, and JIC activation. c. Demonstrate emergency response facility personnel are able to operate all specified communication systems. d. Clear primary and backup communications links are established and maintained for the duration of the exercise. <p><i>E. Radiological Assessment and Control</i></p> <ul style="list-style-type: none"> 1. Demonstrate the ability to obtain onsite radiological surveys and samples. <p><u>Standard Criteria:</u></p> <ul style="list-style-type: none"> a. RP personnel demonstrate the ability to obtain appropriate instruments (range and type) and take surveys for scenario conditions that allow EPA PAGs to be exceeded. b. Airborne samples are properly taken, reported and assessed and utilized when the conditions indicate the need for the information. 2. Demonstrate the capability to establish emergency exposure

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 20 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
			<p>guidelines consistent with EPA-400 and the ability to continuously monitor and control radiation exposure to emergency workers.</p> <p><u>Standard Criteria:</u></p> <ul style="list-style-type: none"> a. Demonstrate the ability to determine doses received by emergency personnel and volunteers 24 hours/day and provisions for distribution of both self-reading and permanent record devices. b. Demonstrate that exposures are controlled to 10 CFR Part 20 limits until the SEC authorizes the use of emergency EPA limits. c. Exposure records are available, either from the ALARA computer or a hard copy dose report, and are updated and reviewed throughout the scenario. <p>3. Demonstrate the methods, equipment, and expertise available to make rapid assessments of the actual or potential magnitude and locations of radiological hazards from both gaseous and liquid pathways.</p> <p><u>Standard Criteria:</u></p>

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 21 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
			<p>a. Environmental monitoring team activation must be within 75 minutes of event declaration.</p> <p>b. Team deployment occurs rapidly (within approximately 10 minutes) of receipt of instructions to deploy.</p> <p>4. Demonstrate the ability to satisfactorily collect and disseminate field team data.</p> <p><u>Standard Criteria:</u></p> <p>a. Offsite radiological environmental data collected is provided as dose rate and counts per minute (cpm) from the plume, both open and closed window, and air sample (gross and net cpm) for particulate and iodine, if applicable.</p> <p>b. Offsite radiological environmental data is promptly and accurately communicated from the environmental monitoring team to the Environmental Field Coordinator.</p> <p>5. Demonstrate the ability to estimate integrated dose from projected and actual dose rates and to compare these estimates with EPA Protective Action Guidelines</p>

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 22 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
			<p>(PAGs).</p> <p><u>Standard Criteria:</u></p> <p>a. The Dose Projection Team Leader and Dose Projection Team perform timely and accurately dose projections using dose projection software, in accordance with emergency plan implementing procedures, and report them to the Radiological Control Manager.</p> <p>6. Demonstrate the availability and use of potassium iodide (KI) for on-site emergency response personnel.</p> <p><u>Standard Criteria:</u></p> <p>a. KI is considered as a potential dose reducing option for situations where airborne radioactive iodine is present.</p> <p>b. KI was administered for activities where personnel dose to the thyroid was calculated, or estimated, to be ≥ 50 Rem CDE.</p> <p>c. Follow-up care for individuals exposed to >25 Rem CDE was identified, as applicable.</p> <p>7. Demonstrate the ability to recommend protective actions to appropriate offsite authorities, in accordance with emergency plan implementing procedures.</p>

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 23 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
			<p><u>Standard Criteria:</u></p> <ul style="list-style-type: none"> a. Total effective dose equivalent (TEDE) and committed dose equivalent (CDE) to the thyroid dose projections from the dose assessment computer code are compared to the PAGs. b. PAR's are accurately developed within 15 minutes of the time information of the condition warranting a PAR was available to the ERO. c. PARs are accurately transmitted within 15 minutes of PAR development. Changes to recommendations are communicated to offsite authorities within 15 minutes of a new PAR. <p><i>F. Public Information</i></p> <ul style="list-style-type: none"> 1. Demonstrate the capability to develop and disseminate clear, accurate, and timely information to the news media, in accordance with emergency plan implementing procedures. <p><u>Standard Criteria:</u></p> <ul style="list-style-type: none"> a. Information provided to the media/public is prepared at a level that the public can understand. Visuals and

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 24 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
			<p>handouts are provided as needed to clarify the information.</p> <p>b. Information is coordinated with Federal, State and local agencies to maintain factual consistency.</p> <p>c. Media briefings are provided within approximately 60 minutes of significant events (i.e., declaration of a Site Area Emergency or initiation of a radiological release.)</p> <p>2. Demonstrate the capability to establish and effectively operate rumor control in a coordinated fashion, in accordance with emergency plan implementing procedures.</p> <p><u>Standard Criteria:</u></p> <p>a. Calls are answered in a timely manner with the correct information.</p> <p>b. Calls are returned or forwarded, as appropriate, to demonstrate responsiveness.</p> <p>c. Rumors are identified and addressed, and recurring rumors are addressed in subsequent press briefings and news releases.</p>

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 25 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
			<p><i>G. Evaluation</i></p> <p>1. Demonstrate the ability to conduct a post-exercise critique, to determine areas requiring improvement and corrective action, in accordance with emergency plan implementing procedures.</p> <p><u>Standard Criteria:</u></p> <ul style="list-style-type: none"> a. An exercise time line is developed, followed by an evaluation of the objectives against the expectations of the timeline. b. Significant problems in achieving the objectives are discussed to ensure understanding of why objectives were not fully achieved. c. Areas requiring improvement are entered in the Harris Corrective Action Program.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-1
Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 26 of 26)**

Planning Standard	EP Program Elements	Inspections, Tests, Analyses	Acceptance Criteria
			<p>8.1.2 Onsite emergency response personnel are mobilized in sufficient numbers to fill emergency response positions and successfully perform assigned responsibilities (see Note 1).</p> <p>8.1.3 The exercise is completed within the specified time periods of Appendix E to 10 CFR Part 50, offsite exercise objectives were met, and there were no uncorrected offsite exercise deficiencies.</p> <p>(Note 1: The assigned responsibilities for onsite Emergency Response Organization members are identified in Sections B.1 through B.4 of the COL Application Emergency Plan)</p>
9.0 Implementing Procedures			
10 CFR Part 50, App. E.V – No less than 180 days prior to the scheduled issuance of an operating license for a nuclear power reactor or a license to possess nuclear material, the applicant's detailed implementing procedures for its emergency plan shall be submitted to the Commission.	9.1 The licensee has submitted detailed implementing procedures for its emergency plan no less than 180 days prior to fuel load.	9.1 An inspection of the submittal letter will be performed.	9.1 Date of submittal letter from the licensee demonstrates that the detailed implementing procedures for the onsite emergency plan were submitted no less than 180 days prior to fuel load.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 10, License Conditions and ITAAC**

**Table 3.8-2
Waterproof Membrane Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 1 of 1)**

Design Commitment	Inspections, Tests, Analyses	Acceptance Criteria
The friction coefficient to resist sliding is ≥ 0.7 .	Testing will be performed to confirm that the mudmat-waterproofing interface beneath the Nuclear Island basemat has a coefficient of friction to resist sliding of ≥ 0.7 .	A report exists and documents that the as-built waterproof system (mudmat-waterproofing interface) has a coefficient of friction of ≥ 0.7 as demonstrated through material qualification testing.