

MANUAL HARD COPY DISTRIBUTION  
DOCUMENT TRANSMITTAL 2009-28217

---

USER INFORMATION:

GERLACH\*ROSE M           EMPL#: 028401   CA#: 0363  
Address: NUCSA2  
Phone#: 254-3194

TRANSMITTAL INFORMATION:

TO:       GERLACH\*ROSE M           06/16/2009  
LOCATION:   USNRC

FROM:   NUCLEAR RECORDS DOCUMENT CONTROL CENTER (NUCSA-2)  
THE FOLLOWING CHANGES HAVE OCCURRED TO THE HARDCOPY OR ELECTRONIC MANUAL ASSIGNED TO YOU. HARDCOPY USERS MUST ENSURE THE DOCUMENTS PROVIDED MATCH THE INFORMATION ON THIS TRANSMITTAL. WHEN REPLACING THIS MATERIAL IN YOUR HARDCOPY MANUAL, ENSURE THE UPDATE DOCUMENT ID IS THE SAME DOCUMENT ID YOU'RE REMOVING FROM YOUR MANUAL. TOOLS FROM THE HUMAN PERFORMANCE TOOL BAG SHOULD BE UTILIZED TO ELIMINATE THE CHANCE OF ERRORS.

ATTENTION: "REPLACE" directions do not affect the Table of Contents, Therefore no TOC will be issued with the updated material.

TRM2 - TECHNICAL REQUIREMENTS MANUAL UNIT 2

REMOVE MANUAL TABLE OF CONTENTS   DATE: 06/10/2009

ADD       MANUAL TABLE OF CONTENTS   DATE: 06/15/2009

CATEGORY: DOCUMENTS   TYPE: TRM2

A001  
ARR

ID: TEXT 3.8.7  
REMOVE: REV:0

ADD: REV: 1

CATEGORY: DOCUMENTS TYPE: TRM2  
ID: TEXT B3.8.7  
ADD: REV: 1

REMOVE: REV:0

CATEGORY: DOCUMENTS TYPE: TRM2  
ID: TEXT LOES  
ADD: REV: 51

REMOVE: REV:50

ANY DISCREPANCIES WITH THE MATERIAL PROVIDED, CONTACT DCS @ X3107 OR X3136 FOR ASSISTANCE. UPDATES FOR HARDCOPY MANUALS WILL BE DISTRIBUTED WITHIN 3 DAYS IN ACCORDANCE WITH DEPARTMENT PROCEDURES. PLEASE MAKE ALL CHANGES AND ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX UPON COMPLETION OF UPDATES. FOR ELECTRONIC MANUAL USERS, ELECTRONICALLY REVIEW THE APPROPRIATE DOCUMENTS AND ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX.

# SSSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

## Table Of Contents

Issue Date: 06/15/2009

<u>Procedure Name</u>	<u>Rev</u>	<u>Issue Date</u>	<u>Change ID</u>	<u>Change Number</u>
TEXT LOES	51	06/15/2009		
Title: LIST OF EFFECTIVE SECTIONS				
TEXT TOC	15	05/14/2009		
Title: TABLE OF CONTENTS				
TEXT 1.1	0	11/19/2002		
Title: USE AND APPLICATION DEFINITIONS				
TEXT 2.1	1	02/04/2005		
Title: PLANT PROGRAMS AND SETPOINTS PLANT PROGRAMS				
TEXT 2.2	8	05/14/2009		
Title: PLANT PROGRAMS AND SETPOINTS INSTRUMENT TRIP SETPOINT TABLE				
TEXT 3.0	4	05/23/2008		
Title: APPLICABILITY TECHNICAL REQUIREMENT FOR OPERATION (TRO) APPLICABILITY				
TEXT 3.1.1	1	11/09/2007		
Title: REACTIVITY CONTROL SYSTEMS ANTICIPATED TRANSIENT WITHOUT SCRAM ALTERNATE ROD INJECTION (ATWS-ARI) INSTRUMENTATION				
TEXT 3.1.2	0	11/19/2002		
Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD DRIVE (CRD) HOUSING SUPPORT				
TEXT 3.1.3	4	05/14/2009		
Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD BLOCK INSTRUMENTATION				
TEXT 3.1.4	0	11/19/2002		
Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD SCRAM ACCUMULATORS INSTRUMENTATION AND CHECK VALVE				
TEXT 3.2.1	8	05/14/2009		
Title: CORE OPERATING LIMITS CORE OPERATING LIMITS REPORT (COLR)				

LDCN

4712

## SSSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.3.1 0 11/19/2002

**Title:** INSTRUMENTATION RADIATION MONITORING INSTRUMENTATION

TEXT 3.3.2 2 11/09/2007

**Title:** INSTRUMENTATION SEISMIC MONITORING INSTRUMENTATION

TEXT 3.3.3 2 11/09/2007

**Title:** INSTRUMENTATION METEOROLOGICAL MONITORING INSTRUMENTATION

TEXT 3.3.4 5 05/23/2008

**Title:** INSTRUMENTATION TRM POST-ACCIDENT MONITORING INSTRUMENTATION

TEXT 3.3.5 0 11/19/2002

**Title:** INSTRUMENTATION THIS PAGE INTENTIONALLY LEFT BLANK

TEXT 3.3.6 2 10/19/2005

**Title:** INSTRUMENTATION TRM ISOLATION ACTUATION INSTRUMENTATION

TEXT 3.3.7 1 11/09/2007

**Title:** INSTRUMENTATION MAIN TURBINE OVERSPEED PROTECTION SYSTEM

TEXT 3.3.8 1 10/22/2003

**Title:** INSTRUMENTATION TRM RPS INSTRUMENTATION

TEXT 3.3.9 3 05/14/2009

**Title:** INSTRUMENTATION LPRM UPSCALE ALARM INSTRUMENTATION

TEXT 3.3.10 1 12/14/2004

**Title:** INSTRUMENTATION REACTOR RECIRCULATION PUMP MG SET STOPS

TEXT 3.3.11 1 10/22/2003

**Title:** INSTRUMENTATION MVP ISOLATION INSTRUMENTATION

TEXT 3.3.12 0 04/16/2009

**Title:** WATER MONITORING INSTRUMENTATION

## SSS MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.4.1 1 04/26/2006

**Title:** REACTOR COOLANT SYSTEM REACTOR COOLANT SYSTEM CHEMISTRY

TEXT 3.4.2 1 04/16/2009

**Title:** REACTOR COOLANT SYSTEM STRUCTURAL INTEGRITY

TEXT 3.4.3 1 11/09/2007

**Title:** REACTOR COOLANT SYSTEM REACTOR COOLANT SYSTEM (RCS)

TEXT 3.4.4 2 05/14/2009

**Title:** REACTOR COOLANT SYSTEM REACTOR RECIRCULATION FLOW AND ROD LINE LIMIT

TEXT 3.4.5 1 04/26/2006

**Title:** REACTOR COOLANT SYSTEM REACTOR VESSEL MATERIALS

TEXT 3.5.1 1 02/04/2005

**Title:** ECCS AND RCIC ADS MANUAL INHIBIT

TEXT 3.5.2 1 11/09/2007

**Title:** ECCS AND RCIC ECCS AND RCIC SYSTEM MONITORING INSTRUMENTATION

TEXT 3.5.3 0 11/19/2002

**Title:** ECCS AND RCIC LONG TERM NITROGEN SUPPLY TO ADS

TEXT 3.6.1 0 11/19/2002

**Title:** CONTAINMENT VENTING OR PURGING

TEXT 3.6.2 0 11/19/2002

**Title:** CONTAINMENT SUPPRESSION CHAMBER-TO-DRYWELL VACUUM BREAKER POSITION INDICATION

TEXT 3.6.3 0 11/19/2002

**Title:** CONTAINMENT SUPPRESSION POOL ALARM INSTRUMENTATION

TEXT 3.6.4 0 11/19/2002

**Title:** CONTAINMENT PRIMARY CONTAINMENT CLOSED SYSTEM BOUNDARIES

## SSSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.7.1 0 11/19/2002  
**Title:** PLANT SYSTEMS EMERGENCY SERVICE WATER SYSTEM (ESW) SHUTDOWN

TEXT 3.7.2 0 11/19/2002  
**Title:** PLANT SYSTEMS ULTIMATE HEAT SINK (UHS) AND GROUND WATER LEVEL

TEXT 3.7.3.1 2 04/16/2009  
**Title:** PLANT SYSTEMS FIRE SUPPRESSION WATER SUPPLY SYSTEM

TEXT 3.7.3.2 3 04/16/2009  
**Title:** PLANT SYSTEMS SPRAY AND SPRINKLER SYSTEMS

TEXT 3.7.3.3 3 04/16/2009  
**Title:** PLANT SYSTEMS CO2 SYSTEMS

TEXT 3.7.3.4 2 04/16/2009  
**Title:** PLANT SYSTEMS HALON SYSTEMS

TEXT 3.7.3.5 2 04/16/2009  
**Title:** PLANT SYSTEMS FIRE HOSE STATIONS

TEXT 3.7.3.6 2 04/16/2009  
**Title:** PLANT SYSTEMS YARD FIRE HYDRANTS AND HYDRANT HOSE HOUSES

TEXT 3.7.3.7 1 04/26/2006  
**Title:** PLANT SYSTEMS FIRE RATED ASSEMBLIES

TEXT 3.7.3.8 7 11/09/2007  
**Title:** PLANT SYSTEMS FIRE DETECTION INSTRUMENTATION

TEXT 3.7.4 1 04/26/2006  
**Title:** PLANT SYSTEMS SOLID RADWASTE SYSTEM

TEXT 3.7.5.1 0 11/19/2002  
**Title:** PLANT SYSTEMS MAIN CONDENSER OFFGAS HYDROGEN MONITOR

## SSS MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.7.5.2 0 11/19/2002

**Title:** PLANT SYSTEMS MAIN CONDENSER OFFGAS EXPLOSIVE GAS MIXTURE

TEXT 3.7.5.3 1 04/26/2006

**Title:** PLANT SYSTEMS LIQUID HOLDUP TANKS

TEXT 3.7.6 2 06/27/2008

**Title:** PLANT SYSTEMS ESSW PUMPHOUSE VENTILATION

TEXT 3.7.7 2 09/05/2008

**Title:** PLANT SYSTEMS MAIN CONDENSER OFFGAS PRETREATMENT LOGARITHMIC RADIATION  
MONITORING INSTRUMENTATION

TEXT 3.7.8 6 06/21/2007

**Title:** PLANT SYSTEMS SNUBBERS

TEXT 3.7.9 1 08/28/2006

**Title:** PLANT SYSTEMS CONTROL STRUCTURE HVAC

TEXT 3.7.10 1 12/14/2004

**Title:** PLANT SYSTEMS SPENT FUEL STORAGE POOLS (SFSPS)

TEXT 3.7.11 0 04/16/2009

**Title:** PLANT SYSTEMS

TEXT 3.8.1 2 02/04/2005

**Title:** ELECTRICAL POWER PRIMARY CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT  
PROTECTIVE DEVICES

TEXT 3.8.2.1 2 11/09/2007

**Title:** ELECTRICAL POWER MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION -  
CONTINUOUS

TEXT 3.8.2.2 2 12/14/2004

**Title:** ELECTRICAL POWER MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION -  
AUTOMATIC

TEXT 3.8.3 0 11/19/2002

**Title:** ELECTRICAL POWER DIESEL GENERATOR (DG) MAINTENANCE ACTIVITIES

## SSSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.8.4 1 02/04/2005  
**Title:** ELECTRICAL POWER 24 VDC ELECTRICAL SUBSYSTEM

TEXT 3.8.5 0 11/19/2002  
**Title:** ELECTRICAL POWER DEGRADED VOLTAGE PROTECTION

TEXT 3.8.6 0 11/19/2002  
**Title:** ELECTRICAL POWER EMERGENCY SWITCHGEAR ROOM COOLING

TEXT 3.8.7 1 06/15/2009  
**Title:** BATTERY MAINTENANCE AND MONITORING PROGRAM

TEXT 3.9.1 0 11/19/2002  
**Title:** REFUELING OPERATIONS DECAY TIME

TEXT 3.9.2 0 11/19/2002  
**Title:** REFUELING OPERATIONS COMMUNICATIONS

TEXT 3.9.3 0 11/19/2002  
**Title:** REFUELING OPERATIONS REFUELING PLATFORM

TEXT 3.10.1 1 04/26/2006  
**Title:** MISCELLANEOUS SEALED SOURCE CONTAMINATION

TEXT 3.10.2 1 04/09/2007  
**Title:** MISCELLANEOUS SHUTDOWN MARGIN TEST RPS INSTRUMENTATION

TEXT 3.10.3 1 04/26/2006  
**Title:** MISCELLANEOUS INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI)

TEXT 3.11.1.1 1 04/26/2006  
**Title:** RADIOACTIVE EFFLUENTS LIQUID EFFLUENTS CONCENTRATION

TEXT 3.11.1.2 1 04/26/2006  
**Title:** RADIOACTIVE EFFLUENTS LIQUID EFFLUENTS DOSE



## SSS MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.11.1.3 1 04/26/2006  
**Title:** RADIOACTIVE EFFLUENTS LIQUID WASTE TREATMENT SYSTEM

TEXT 3.11.1.4 1 12/14/2004  
**Title:** RADIOACTIVE EFFLUENTS LIQUID RADWASTE EFFLUENT MONITORING INSTRUMENTATION

TEXT 3.11.1.5 2 05/02/2007  
**Title:** RADIOACTIVE EFFLUENTS RADIOACTIVE LIQUID PROCESS MONITORING INSTRUMENTATION

TEXT 3.11.2.1 3 04/26/2006  
**Title:** RADIOACTIVE EFFLUENTS DOSE RATE

TEXT 3.11.2.2 1 04/26/2006  
**Title:** RADIOACTIVE EFFLUENTS DOSE - NOBLE GASES

TEXT 3.11.2.3 1 04/26/2006  
**Title:** RADIOACTIVE EFFLUENTS DOSE - IODINE, TRITIUM, AND RADIONUCLIDES IN PARTICULATE FORM

TEXT 3.11.2.4 0 11/19/2002  
**Title:** RADIOACTIVE EFFLUENTS GASEOUS RADWASTE TREATMENT SYSTEM

TEXT 3.11.2.5 3 11/14/2006  
**Title:** RADIOACTIVE EFFLUENTS VENTILATION EXHAUST TREATMENT SYSTEM

TEXT 3.11.2.6 3 05/02/2007  
**Title:** RADIOACTIVE EFFLUENTS RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

TEXT 3.11.3 1 04/26/2006  
**Title:** RADIOACTIVE EFFLUENTS TOTAL DOSE

TEXT 3.11.4.1 3 04/26/2006  
**Title:** RADIOACTIVE EFFLUENTS MONITORING PROGRAM

TEXT 3.11.4.2 2 04/26/2006  
**Title:** RADIOACTIVE EFFLUENTS LAND USE CENSUS

## SSSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.11.4.3 1 04/26/2006

**Title:** RADIOACTIVE EFFLUENTS INTERLABORATORY COMPARISON PROGRAM

TEXT 3.12.1 0 11/19/2002

**Title:** LOADS CONTROL PROGRAM CRANE TRAVEL-SPENT FUEL STORAGE POOL

TEXT 3.12.2 4 04/17/2008

**Title:** LOADS CONTROL PROGRAM HEAVY LOADS REQUIREMENTS

TEXT 3.12.3 0 11/19/2002

**Title:** LOADS CONTROL PROGRAM LIGHT LOADS REQUIREMENTS

TEXT B3.0 4 05/23/2008

**Title:** APPLICABILITY BASES TECHNICAL REQUIREMENT FOR OPERATION (TRO) APPLICABILITY

TEXT B3.1.1 1 11/09/2007

**Title:** REACTIVITY CONTROL SYSTEM BASES ANTICIPATED TRANSIENT WITHOUT SCRAM ALTERNATE ROD INJECTION (ATWS-ARI) INSTRUMENTATION

TEXT B3.1.2 0 11/19/2002

**Title:** REACTIVITY CONTROL SYSTEM BASES CONTROL ROD DRIVE (CRD) HOUSING SUPPORT

TEXT B3.1.3 3 04/10/2007

**Title:** REACTIVITY CONTROL SYSTEM BASES CONTROL ROD BLOCK INSTRUMENTATION

TEXT B3.1.4 0 11/19/2002

**Title:** REACTIVITY CONTROL SYSTEM BASES CONTROL ROD SCRAM ACCUMULATORS INSTRUMENTATION AND CHECK VALVE

TEXT B3.2.1 0 11/19/2002

**Title:** CORE OPERATING LIMITS BASES CORE OPERATING LIMITS REPORT (COLR)

TEXT B3.3.1 0 11/19/2002

**Title:** INSTRUMENTATION BASES RADIATION MONITORING INSTRUMENTATION

TEXT B3.3.2 1 11/09/2007

**Title:** INSTRUMENTATION BASES SEISMIC MONITORING INSTRUMENTATION

## SSSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.3.3 2 11/09/2007

**Title:** INSTRUMENTATION BASES METEOROLOGICAL MONITORING INSTRUMENTATION

TEXT B3.3.4 3 11/09/2007

**Title:** INSTRUMENTATION BASES TRM POST ACCIDENT MONITORING (PAM) INSTRUMENTATION

TEXT B3.3.5 2 11/09/2007

**Title:** INSTRUMENTATION BASES THIS PAGE INTENTIONALLY LEFT BLANK

TEXT B3.3.6 3 10/19/2005

**Title:** INSTRUMENTATION BASES TRM ISOLATION ACTUATION INSTRUMENTATION

TEXT B3.3.7 1 11/09/2007

**Title:** INSTRUMENTATION BASES MAIN TURBINE OVERSPEED PROTECTION SYSTEM

TEXT B3.3.8 1 10/22/2003

**Title:** INSTRUMENTATION BASES TRM RPS INSTRUMENTATION

TEXT B3.3.9 3 05/14/2009

**Title:** INSTRUMENTATION BASES LPRM UPSCALE ALARM INSTRUMENTATION

TEXT B3.3.10 1 12/18/2008

**Title:** INSTRUMENTATION BASES REACTOR RECIRCULATION PUMP MG SET STOPS

TEXT B3.3.11 1 10/22/2003

**Title:** INSTRUMENTATION BASES MVP ISOLATION INSTRUMENTATION

TEXT B3.3.12 0 04/16/2009

**Title:** WATER MONITORING INSTRUMENTATION

TEXT B3.4.1 0 11/19/2002

**Title:** REACTOR COOLANT SYSTEM BASES REACTOR COOLANT SYSTEM CHEMISTRY

TEXT B3.4.2 1 04/16/2009

**Title:** REACTOR COOLANT SYSTEM BASES STRUCTURAL INTEGRITY

## SSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.4.3 1 11/09/2007  
**Title:** REACTOR COOLANT SYSTEM BASES HIGH/LOW PRESSURE INTERFACE LEAKAGE MONITOR

TEXT B3.4.4 0 11/19/2002  
**Title:** REACTOR COOLANT SYSTEM BASES REACTOR RECIRCULATION FLOW AND ROD LINE LIMIT

TEXT B3.4.5 0 11/19/2002  
**Title:** REACTOR COOLANT SYSTEM BASES REACTOR VESSEL MATERIALS

TEXT B3.5.1 0 11/19/2002  
**Title:** ECCS AND RCIC BASES ADS MANUAL INHIBIT

TEXT B3.5.2 1 11/09/2007  
**Title:** ECCS AND RCIC BASES ECCS AND RCIC SYSTEM MONITORING INSTRUMENTATION

TEXT B3.5.3 1 11/09/2007  
**Title:** ECCS AND RCIC BASES LONG TERM NITROGEN SUPPLY TO ADS

TEXT B3.6.1 0 11/19/2002  
**Title:** CONTAINMENT BASES VENTING OR PURGING

TEXT B3.6.2 0 11/19/2002  
**Title:** CONTAINMENT BASES SUPPRESSION CHAMBER-TO-DRYWELL VACUUM BREAKER POSITION INDICATION

TEXT B3.6.3 1 04/19/2007  
**Title:** CONTAINMENT BASES SUPPRESSION POOL ALARM INSTRUMENTATION

TEXT B3.6.4 1 12/14/2004  
**Title:** CONTAINMENT BASES PRIMARY CONTAINMENT CLOSED SYSTEM BOUNDARIES

TEXT B3.7.1 0 11/19/2002  
**Title:** PLANT SYSTEMS BASES EMERGENCY SERVICE WATER SYSTEM (SHUTDOWN)

TEXT B3.7.2 0 11/19/2002  
**Title:** PLANT SYSTEMS BASES ULTIMATE HEAT SINK (UHS) GROUND WATER LEVEL

## SSSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.7.3.1 2 01/07/2008

**Title:** PLANT SYSTEMS BASES FIRE SUPPRESSION WATER SUPPLY SYSTEM

TEXT B3.7.3.2 2 04/26/2006

**Title:** PLANT SYSTEMS BASES SPRAY AND SPRINKLER SYSTEMS

TEXT B3.7.3.3 0 11/19/2002

**Title:** PLANT SYSTEMS BASES CO2 SYSTEMS

TEXT B3.7.3.4 1 04/26/2006

**Title:** PLANT SYSTEMS BASES HALON SYSTEMS

TEXT B3.7.3.5 1 04/26/2006

**Title:** PLANT SYSTEMS BASES FIRE HOSE STATIONS

TEXT B3.7.3.6 1 04/26/2006

**Title:** PLANT SYSTEMS BASES YARD FIRE HYDRANTS AND HYDRANT HOSE HOUSES

TEXT B3.7.3.7 0 11/19/2002

**Title:** PLANT SYSTEMS BASES FIRE RATED ASSEMBLIES

TEXT B3.7.3.8 1 01/12/2004

**Title:** PLANT SYSTEMS BASES FIRE DETECTION INSTRUMENTATION

TEXT B3.7.4 0 11/19/2002

**Title:** PLANT SYSTEMS BASES SOLID RADWASTE SYSTEM

TEXT B3.7.5.1 0 11/19/2002

**Title:** PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS HYDROGEN MONITOR

TEXT B3.7.5.2 0 11/19/2002

**Title:** PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS EXPLOSIVE GAS MIXTURE

TEXT B3.7.5.3 0 11/19/2002

**Title:** PLANT SYSTEMS BASES LIQUID HOLDUP TANKS

## SSSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.7.6 2 06/27/2008

**Title:** PLANT SYSTEMS BASES ESSW PUMPHOUSE VENTILATION

TEXT B3.7.7 2 01/31/2008

**Title:** PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS PRETREATMENT LOGARITHMIC RADIATION MONITORING INSTRUMENTATION

TEXT B3.7.8 3 06/21/2007

**Title:** PLANT SYSTEMS BASES SNUBBERS

TEXT B3.7.9 1 12/14/2004

**Title:** PLANT SYSTEMS BASES CONTROL STRUCTURE HVAC

TEXT B3.7.10 1 12/14/2004

**Title:** PLANT SYSTEMS BASES SPENT FUEL STORAGE POOLS

TEXT B3.7.11 0 04/16/2009

**Title:** STRUCTURAL INTEGRITY

TEXT B3.8.1 1 02/04/2005

**Title:** ELECTRICAL POWER BASES PRIMARY CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

TEXT B3.8.2.1 0 11/19/2002

**Title:** ELECTRICAL POWER BASES MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - CONTINUOUS

TEXT B3.8.2.2 1 09/17/2004

**Title:** ELECTRICAL POWER BASES MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - AUTOMATIC

TEXT B3.8.3 0 11/19/2002

**Title:** ELECTRICAL POWER BASES DIESEL GENERATOR (DG) MAINTENANCE ACTIVITIES

TEXT B3.8.4 0 11/19/2002

**Title:** ELECTRICAL POWER BASES 24 VDC ELECTRICAL POWER SUBSYSTEM

TEXT B3.8.5 0 11/19/2002

**Title:** ELECTRICAL POWER BASES DEGRADED VOLTAGE PROTECTION

## SSSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.8.6 1 02/04/2005

**Title:** ELECTRICAL POWER BASES EMERGENCY SWITCHGEAR ROOM COOLING

TEXT B3.8.7 1 06/15/2009

**Title:** BATTERY MAINTENANCE AND MONITORING PROGRAM

TEXT B3.9.1 0 11/19/2002

**Title:** REFUELING OPERATIONS BASES DECAY TIME

TEXT B3.9.2 0 11/19/2002

**Title:** REFUELING OPERATIONS BASES COMMUNICATIONS

TEXT B3.9.3 0 11/19/2002

**Title:** REFUELING OPERATIONS BASES REFUELING PLATFORM

TEXT B3.10.1 0 11/19/2002

**Title:** MISCELLANEOUS BASES SEALED SOURCE CONTAMINATION

TEXT B3.10.2 1 04/10/2007

**Title:** MISCELLANEOUS BASES SHUTDOWN MARGIN TEST RPS INSTRUMENTATION

TEXT B3.10.3 0 11/19/2002

**Title:** MISCELLANEOUS BASES INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI)

TEXT B3.11.1.1 0 11/19/2002

**Title:** RADIOACTIVE EFFLUENTS BASES LIQUID EFFLUENTS CONCENTRATION

TEXT B3.11.1.2 0 11/19/2002

**Title:** RADIOACTIVE EFFLUENTS BASES LIQUID EFFLUENTS DOSE

TEXT B3.11.1.3 0 11/19/2002

**Title:** RADIOACTIVE EFFLUENTS BASES LIQUID WASTE TREATMENT SYSTEM

TEXT B3.11.1.4 0 11/19/2002

**Title:** RADIOACTIVE EFFLUENTS BASES LIQUID RADWASTE EFFLUENT MONITORING INSTRUMENTATION

## SSS MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.11.1.5 0 11/19/2002  
**Title:** RADIOACTIVE EFFLUENTS BASES RADIOACTIVE LIQUID PROCESS MONITORING INSTRUMENTATION

TEXT B3.11.2.1 1 12/14/2004  
**Title:** RADIOACTIVE EFFLUENTS BASES DOSE RATE

TEXT B3.11.2.2 0 11/19/2002  
**Title:** RADIOACTIVE EFFLUENTS BASES DOSE - NOBLE GASES

TEXT B3.11.2.3 0 11/19/2002  
**Title:** RADIOACTIVE EFFLUENTS BASES DOSE - IODINE, TRITIUM, AND RADIONUCLIDES IN PARTICULATES FORM

TEXT B3.11.2.4 0 11/19/2002  
**Title:** RADIOACTIVE EFFLUENTS BASES GASEOUS RADWASTE TREATMENT SYSTEM

TEXT B3.11.2.5 4 11/14/2006  
**Title:** RADIOACTIVE EFFLUENTS BASES VENTILATION EXHAUST TREATMENT SYSTEM

TEXT B3.11.2.6 1 01/27/2004  
**Title:** RADIOACTIVE EFFLUENTS BASES RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

TEXT B3.11.3 0 11/19/2002  
**Title:** RADIOACTIVE EFFLUENTS BASES TOTAL DOSE

TEXT B3.11.4.1 2 01/06/2006  
**Title:** RADIOACTIVE EFFLUENTS BASES MONITORING PROGRAM

TEXT B3.11.4.2 0 11/19/2002  
**Title:** RADIOACTIVE EFFLUENTS BASES LAND USE CENSUS

TEXT B3.11.4.3 0 11/19/2002  
**Title:** RADIOACTIVE EFFLUENTS BASES INTERLABORATORY COMPARISON PROGRAM

TEXT B3.12.1 1 10/04/2007  
**Title:** LOADS CONTROL PROGRAM BASES CRANE TRAVEL-SPENT FUEL STORAGE POOL



## SSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.12.2 0 11/19/2002  
**Title:** LOADS CONTROL PROGRAM BASES HEAVY LOADS REQUIREMENTS

TEXT B3.12.3 0 11/19/2002  
**Title:** LOADS CONTROL PROGRAM BASES LIGHT LOADS REQUIREMENTS

TEXT 4.1 0 09/27/2003  
**Title:** ADMINISTRATIVE CONTROLS ORGANIZATION

TEXT 4.2 0 09/27/2003  
**Title:** ADMINISTRATIVE CONTROLS REPORTABLE EVENT ACTION

TEXT 4.3 0 09/27/2003  
**Title:** ADMINISTRATIVE CONTROLS SAFETY LIMIT VIOLATION

TEXT 4.4 1 12/18/2008  
**Title:** ADMINISTRATIVE CONTROLS PROCEDURES & PROGRAMS

TEXT 4.5 0 09/27/2003  
**Title:** ADMINISTRATIVE CONTROLS REPORTING REQUIREMENTS

TEXT 4.6 0 09/27/2003  
**Title:** ADMINISTRATIVE CONTROLS RADIATION PROTECTION PROGRAM

TEXT 4.7 0 09/27/2003  
**Title:** ADMINISTRATIVE CONTROLS TRAINING

**LIST OF EFFECTIVE SECTIONS** (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
TOC	TABLE OF CONTENTS	04/17/2009
1.0	USE AND APPLICATION	
	Page TRM / 1.0-1	08/31/1998
	Page TRM / 1.0-2	10/04/2002
	Page TRM / 1.0-3	08/31/1998
2.0	PLANT PROGRAMS	
	Page 2.0-1	08/31/1998
	Pages TRM / 2.0-2 and TRM 2.0-3	01/28/2005
	Page TRM / 2.0-4	06/25/2002
	Page TRM / 2.0-5	04/12/1999
	Page TRM / 2.0-6	04/15/2009
	Page TRM / 2.0-7	05/15/2008
	Page TRM / 2.0-8	04/15/2009
	Pages TRM / 2.0-9 through TRM / 2.0-11	11/15/2004
	Page TRM / 2.0-12	04/15/2009
	Pages TRM / 2.0-13 and TRM / 2.0-14	11/15/2004
	Page TRM / 2.0-15	11/15/2005
3.0	APPLICABILITY	
	Pages TRM / 3.0-1 and TRM / 3.0-2	04/14/2008
	Page TRM / 3.0-3	03/15/2002
	Page TRM / 3.0-4	11/30/2005
3.1	REACTIVITY CONTROL SYSTEMS	
	Page TRM / 3.1-1	10/31/2007
	Pages TRM / 3.1-2 through TRM / 3.1-5	08/31/1998
	Page TRM / 3.1-6	03/27/2007
	Page TRM / 3.1-7	04/15/2009
	Page TRM / 3.1-8	03/27/2007
	Pages TRM / 3.1-9 and TRM / 3.1-9a	02/18/1999
	Page TRM / 3.1-10	02/18/1999
3.2	CORE OPERATING LIMITS REPORT	
	Page TRM / 3.2-1	08/31/1998
	Pages TRM / 3.2-2 through TRM / 3.2-54	04/17/2009
3.3	INSTRUMENTATION	
	Pages TRM / 3.3-1 through TRM / 3.3-3	07/16/1999
	Pages TRM / 3.3-4 and TRM / 3.3-5	10/31/2007
	Page 3.3-6	08/31/1998
	Page TRM 3.3-7	10/31/2007
	Page 3.3-8	08/31/1998

**LIST OF EFFECTIVE SECTIONS** (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Page TRM / 3.3-9	04/12/2007
	Page TRM / 3.3-9a	12/17/1998
	Page TRM / 3.3-10	10/31/2007
	Page TRM / 3.3-11	06/02/2005
	Page TRM / 3.3-11a	04/14/2008
	Page TRM / 3.3-12	03/30/2001
	Page TRM / 3.3-13	09/13/2005
	Page TRM / 3.3-14	12/14/1998
	Page TRM / 3.3-15	10/22/2003
	Page TRM / 3.3-16	06/27/2001
	Page TRM / 3.3-17	06/14/2002
	Page TRM / 3.3-18	10/31/2007
	Pages TRM / 3.3-19 and TRM / 3.3-20	10/22/2003
	Page TRM / 3.3-21	04/15/2009
	Page TRM / 3.3-21a	11/15/2004
	Pages TRM / 3.3-21b through TRM / 3.3-21d	03/27/2007
	Page TRM / 3.3-22	12/03/2004
	Pages TRM / 3.3-23 and TRM / 3.3-24	05/16/2003
	Page TRM / 3.3-25	10/22/2003
	Pages TRM / 3.3-26 and TRM / 3.3-27	04/07/2009
3.4	REACTOR COOLANT SYSTEM	
	Page TRM / 3.4-1	03/31/2006
	Pages 3.4-2 through 3.4-5	10/23/1998
	Pages TRM / 3.4-6 through TRM / 3.4-8	04/01/2009
	Page 3.4-9	08/31/1998
	Page 3.4-10	10/31/2007
	Page 3.4-11	08/31/1998
	Page TRM / 3.4-12	04/17/2009
	Page TRM / 3.4-13	03/31/2006
3.5	EMERGENCY CORE COOLING AND RCIC	
	Page TRM / 3.5-1	01/28/2005
	Pages 3.5-2 and 3.5-3	08/31/1998
	Page TRM / 3.5-4	10/31/2007
	Pages 3.5-5 through 3.5-7	08/31/1998
3.6	CONTAINMENT	
	Pages 3.6-1 through 3.6-4	08/31/1998
	Page TRM / 3.6-5	01/07/2002
	Page 3.6-6	08/31/1998
	Pages TRM / 3.6-7 through TRM / 3.6-9	12/31/2002

**LIST OF EFFECTIVE SECTIONS** (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
3.7	PLANT SYSTEMS	
	Pages TRM / 3.7-1 and TRM / 3.7-2	07/29/1999
	Page 3.7-3	08/31/1998
	Page TRM / 3.7-4	03/31/2006
	Page TRM / 3.7-5	04/07/2009
	Pages TRM / 3.7-6 through TRM / 3.7-8	08/02/1999
	Pages TRM / 3.7-9 and TRM / 3.7-10	04/07/2009
	Page TRM / 3.7-11	01/21/2000
	Page TRM / 3.7-12	08/02/1999
	Page TRM / 3.7-13	04/07/2009
	Page TRM / 3.7-14	08/09/2005
	Pages TRM / 3.7-15 and TRM / 3.7-16	08/02/1999
	Page TRM / 3.7-17	04/07/2009
	Page TRM / 3.7-18	08/02/1999
	Page TRM / 3.7-19	04/07/2009
	Pages TRM / 3.7-20 through TRM / 3.7-22	08/02/1999
	Page TRM / 3.7-23	04/07/2009
	Page TRM / 3.7-24	03/31/2006
	Pages TRM / 3.7-25 and TRM / 3.7-26	08/02/1999
	Page TRM / 3.7-27	10/31/2007
	Page TRM / 3.7-28	11/29/2006
	Page TRM / 3.7-29	11/16/2001
	Page TRM / 3.7-30	11/30/2005
	Page TRM / 3.7-31	11/16/2001
	Page TRM / 3.7-32	01/09/2004
	Page TRM / 3.7-33	10/05/2002
	Page TRM / 3.7-34	03/31/2006
	Pages TRM / 3.7-35 and TRM / 3.7-36	02/01/1999
	Pages 3.7-37 through 3.7-38	08/31/1998
	Page TRM / 3.7-39	03/31/2006
	Page TRM / 3.7-40	02/14/2005
	Page TRM / 3.7-40a	06/20/2008
	Page TRM / 3.7-41	09/04/2008
	Page TRM / 3.7-42	08/31/1998
	Pages TRM / 3.7-43 through TRM / 3.7-45	10/05/2006
	Page TRM / 3.7-46	06/07/2007
	Page TRM / 3.7-47	10/05/2006
	Page TRM / 3.7-48	06/07/2007
	Page TRM / 3.7-49	03/09/2001
	Page TRM / 3.7-50	08/16/2006
	Page TRM / 3.7-51	12/03/2004
	Page TRM / 3.7-52	04/15/2003
	Page TRM / 3.7-53	07/29/1999
	Pages TRM / 3.7-54 through TRM / 3.7-56	04/01/2009

**LIST OF EFFECTIVE SECTIONS** (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
3.8	ELECTRICAL POWER	
	Page TRM / 3.8-1	04/02/2002
	Pages TRM / 3.8-2 and TRM / 3.8-3	01/28/2005
	Page TRM / 3.8-4	01/31/2005
	Pages TRM / 3.8-5 and TRM / 3.8-6	04/02/2002
	Pages TRM / 3.8-7 through TRM / 3.8-10	10/31/2007
	Page TRM / 3.8-11	08/10/2004
	Page TRM / 3.8-12	12/03/2004
	Pages 3.8-13 and 3.8-14	08/31/1998
	Page TRM / 3.8-15	01/28/2005
	Pages TRM / 3.8-16 and TRM / 3.8-17	04/02/2002
	Page 3.8-18	02/01/1999
	Page TRM / 3.8-19	04/02/2002
	Page TRM / 3.8-20	02/01/1999
	Pages TRM / 3.8-21 through TRM / 3.8-23	06/06/1999
	Pages 3.8-24 and 3.8-25	08/31/1998
	Page TRM / 3.8-26	05/28/2009
	Page TRM / 3.8-27	11/29/2006
	Pages TRM / 3.8-28 and TRM / 3.8-29	05/28/2009
3.9	REFUELING OPERATIONS	
	Pages 3.9-1 through 3.9-3	08/31/1998
3.10	MISCELLANEOUS	
	Page TRM / 3.10-1	03/31/2006
	Pages 3.10-2 through 3.10-4	08/30/1998
	Pages TRM / 3.10-5 and TRM / 3.10-6	03/27/2007
	Page TRM / 3.10-7	03/31/2006
3.11	RADIOACTIVE EFFLUENTS	
	Page TRM / 3.11-1	03/31/2006
	Pages 3.11-2 through 3.11-3	08/31/1998
	Page TRM / 3.11-4	03/31/2006
	Page 3.11-5	08/31/1998
	Page TRM / 3.11-6	03/31/2006
	Pages 3.11-7 through 3.11-9	08/31/1998
	Page TRM / 3.11-10	12/03/2004
	Pages 3.11-11 and 3.11-12	08/31/1998
	Page TRM / 3.11-13	04/12/2007
	Page TRM / 3.11-14	12/03/2004
	Pages 3.11-15 and 3.11-16	09/01/1998
	Page TRM / 3.11-17	03/31/2006

**LIST OF EFFECTIVE SECTIONS** (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Page 3.11-18	08/31/1998
	Page TRM / 3.11-19	08/15/2005
	Pages TRM / 3.11-20 and TRM / 3.11-21	03/31/2006
	Page TRM / 3.11-22	04/02/2002
	Page TRM / 3.11-23	11/14/2006
	Page TRM / 3.11-24	05/13/2005
	Page TRM / 3.11-25	04/12/2007
	Pages TRM / 3.11-26 through TRM / 3.11-28	01/21/2004
	Page TRM / 3.11-29	12/03/2004
	Pages TRM 3.11-30 through TRM / 3.11-32	01/21/2004
	Page TRM / 3.11-33	03/31/2006
	Page 3.11-34	08/31/1998
	Page TRM / 3.11-35	03/31/2006
	Pages TRM / 3.11-36 through TRM / 3.11-39	11/30/2005
	Pages 3.11-40 through 3.11-44	08/31/1998
	Page TRM / 3.11-45	03/31/2006
	Page 3.11-46	08/31/1998
	Page TRM / 3.11-47	03/31/2006
3.12	LOADS CONTROL PROGRAM	
	Pages TRM / 3.12-1 through TRM / 3.12-3	02/05/1999
	Page TRM / 3.12-4	03/14/2008
	Page TRM / 3.12-5	02/05/1999
4.0	ADMINISTRATIVE CONTROLS	
	Pages TRM / 4.0-1 through TRM / 4.0-3	08/31/1998
	Page TRM / 4.0-4	12/11/2008
	Pages TRM / 4.0-5 through TRM / 4.0-8	08/31/1998

**LIST OF EFFECTIVE SECTIONS** (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
B 3.0	APPLICABILITY BASES	
	Pages TRM / B 3.0-1 through TRM / B 3.0-3	08/31/1998
	Page TRM / B 3.0-4	01/10/2007
	Page TRM / B 3.0-5	04/14/2008
	Page TRM / B 3.0-6	08/31/1998
	Page TRM / B 3.0-7	04/12/2007
	Pages TRM / B 3.0-8 through TRM / B 3.0-10	08/31/1998
	Pages TRM / B 3.0-11 and TRM / B 3.0-12	03/15/2002
	Pages TRM / B 3.0-13 and TRM / B 3.0-14	11/30/2005
	Page TRM / B 3.0-15	03/15/2002
B 3.1	REACTIVITY CONTROL SYSTEMS BASES	
	Page TRM / B 3.1-1	07/13/1999
	Pages TRM / B 3.1-2 and TRM / B 3.1-3	10/31/2007
	Page B 3.1-4	08/31/1998
	Pages TRM / B 3.1-5 through TRM / B 3.1-7	03/27/2007
	Page TRM / B 3.1-8	02/18/1999
B 3.2	CORE OPERATING LIMITS BASES	
	Page B 3.2-1	08/31/1998
B 3.3	INSTRUMENTATION BASES	
	Page TRM / B 3.3-1	04/07/2000
	Pages TRM / B 3.3-2 and TRM / B-3.3-2a	10/31/2007
	Pages TRM / B 3.3-3 and TRM / B 3.3-3a	10/31/2007
	Pages TRM / B 3.3-4 and TRM / B 3.3-5	05/30/2006
	Pages TRM / B 3.3-6 through TRM / B 3.3-9	10/31/2007
	Page B 3.3-10	08/31/1998
	Pages TRM / B 3.3-11 and TRM / B 3.3-12	09/13/2005
	Page TRM / B 3.3-13	12/03/2004
	Page TRM / B 3.3-14	06/25/2002
	Page TRM / B 3.3-14a	10/31/2007
	Page TRM / B 3.3-14b	06/14/2002
	Pages TRM / B 3.3-15 through TRM / B 3.3-17	10/22/2003
	Pages TRM / B 3.3-18 and TRM / B 3.3-19	03/27/2007
	Pages TRM / B 3.3-19a and TRM / B 3.3-19b	03/27/2007
	Page TRM / B 3.3-19c	04/17/2009
	Pages TRM / B 3.3-19d and TRM / B 3.3-19e	03/27/2007
	Page TRM / B 3.3-20	12/11/2008
	Page TRM / B 3.3-21	05/16/2003
	Page TRM / B 3.3-22	10/22/2003
	Page TRM / B 3.3-23	05/16/2003
	Pages TRM / B 3.3-24 and TRM / B 3.3-25	04/07/2009

**LIST OF EFFECTIVE SECTIONS** (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
B 3.4	REACTOR COOLANT SYSTEM BASES	
	Page TRM / B 3.4-1	08/31/1998
	Pages TRM / B 3.4-2 and TRM / B3.4-3	04/01/2009
	Pages TRM / B 3.4-4 and TRM / B 3.4-4a	10/31/2007
	Page TRM / B 3.4-5	10/15/1999
	Page B 3.4-6	08/31/1998
B 3.5	ECCS AND RCIC BASES	
	Pages B 3.5-1 and B 3.5-2	08/31/1998
	Pages TRM / B 3.5-3 and TRM / B 3.5-3a	10/31/2007
	Page B 3.5-4	08/31/1998
	Page TRM / B 3.5-5	10/31/2007
B 3.6	CONTAINMENT BASES	
	Page TRM / B 3.6-1	07/26/2001
	Page TRM / B 3.6-2	02/01/1999
	Page B 3.6-3	08/31/1998
	Page TRM / B 3.6-4	03/29/2007
	Page TRM / B 3.6-5	04/04/2007
	Page TRM / B 3.6-6	12/03/2004
	Pages TRM / B 3.6-7 through TRM / B 3.6-11	12/31/2002
B 3.7	PLANT SYSTEMS BASES	
	Pages B 3.7-1 and B 3.7-2	08/31/1998
	Pages TRM / B 3.7-3 and TRM / B 3.7-3a	12/27/2007
	Page TRM / B 3.7-4	03/31/2006
	Page TRM / B 3.7-5	08/02/1999
	Pages TRM / B 3.7-6 and TRM / B 3.7-6a	03/31/2006
	Pages TRM / B 3.7-7 and TRM / B 3.7-7a	08/02/1999
	Page TRM / B 3.7-8	08/02/1999
	Page TRM / B 3.7-9	03/31/2006
	Page TRM / B 3.7-10	08/02/1999
	Pages TRM / B 3.7-10a through TRM / B 3.7-11a	03/31/2006
	Pages TRM / B 3.7-12 through TRM / B 3.7-14	08/02/1999
	Pages TRM / B 3.7-14a and TRM / B 3.7-14b	01/09/2004
	Pages TRM / B 3.7-15 and TRM / B 3.7-16	02/01/1999
	Pages B 3.7-17 through B 3.7-20	08/31/1998
	Page TRM / B 3.7-21	02/14/2005
	Page TRM / B 3.7-21a	06/20/2008
	Pages TRM / B 3.7-22 and TRM / B 3.7-23	01/30/2008
	Pages TRM / B 3.7-24 through TRM / B 3.7-29	10/05/2006
	Page TRM / B 3.7-30	06/07/2007
	Pages TRM / B 3.7-30a and TRM / B 3.7-30b	10/05/2006
	Page TRM / B 3.7-32	03/09/2001
	Page TRM / B 3.7-33	04/15/2003



**LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)**

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Page TRM / B 3.7-34	12/03/2004
	Page TRM / B 3.7-35	07/05/2000
	Pages TRM / B 3.7-36 through TRM / B 3.7-40	04/01/2009
B 3.8	ELECTRICAL POWER BASES	
	Page TRM / B 3.8-1	04/02/2002
	Pages TRM / B 3.8-2 and TRM / B 3.8-2a	01/28/2005
	Page TRM / B 3.8-3	04/02/2002
	Page TRM / B 3.8-3a	04/02/2002
	Page TRM / B 3.8-4	04/02/2002
	Page TRM / B 3.8-4a	08/10/2004
	Page TRM / B 3.8-5	08/31/1998
	Pages TRM / B 3.8-6 through TRM / B 3.8-16	04/02/2002
	Page TRM / B 3.8-17	01/28/2005
	Pages TRM / B 3.8-18 through TRM / B 3.8-20	11/29/2006
	Pages TRM / B 3.8-21 through TRM / B 3.8-24	05/28/2009
B.3.9	REFUELING OPERATIONS BASES	
	Pages B 3.9-1 and B 3.9-2	08/31/1998
	Pages B 3.9-3 through B 3.9-7	10/23/1998
B 3.10	MISCELLANEOUS BASES	
	Page B 3.10-1	08/31/1998
	Pages TRM / B 3.10-2 and TRM / B 3.10-3	03/27/2007
	Pages TRM / B 3.10-4 and TRM / B 3.10-5	08/23/1999
B 3.11	RADIOACTIVE EFFLUENTS BASES	
	Pages B 3.11-1 through B 3.11-9	08/31/1998
	Page TRM / B 3.11-10	02/01/1999
	Pages TRM/B 3.11-11 and TRM/B 3.11-11a	04/07/2000
	Pages TRM/B 3.11-12 and TRM/B 3.11-13	02/01/1999
	Page TRM / B 3.11-14	12/03/2004
	Page TRM / B 3.11-15	02/01/1999
	Pages B 3.11-16 through B 3.11-19	08/31/1998
	Page TRM / B 3.11-20	04/02/2002
	Page TRM / B 3.11-20a	04/02/2002
	Page TRM / B 3.11-21	05/13/2005
	Pages TRM / B 3.11-22 and TRM / B 3.11-23	11/14/2006
	Page TRM / B 3.11-23a	05/13/2005
	Pages TRM / B 3.11-24 and TRM / B 3.11-25	01/21/2004
	Pages B 3.11-26 through B 3.11-27	08/31/1998
	Pages TRM / B 3.11-28 and TRM / B 3.11-29	11/30/2005
	Page TRM / B 3.11-30	12/03/2004
	Pages B 3.11-31 through B 3.11-35	08/31/1998
	Page TRM / B 3.11-36	02/12/1999

**LIST OF EFFECTIVE SECTIONS** (TECHNICAL REQUIREMENTS MANUAL)

---

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
B.3.12	LOADS CONTROL PROGRAM BASES	
	Page TRM / B 3.12-1	09/19/2007
	Pages TRM / B 3.12-2 and TRM / B 3.12-3	02/05/1999

TRM2 text LOES.doc  
6/5/2009

## 3.8.7 Battery Monitoring and Maintenance Program

TRO 3.8.7 Battery cell parameters for the Class 1E 250 V batteries and Class 1E 125 V batteries shall be within limits.

APPLICABILITY: When associated DC electrical power subsystems are required to be OPERABLE.

## ACTIONS

## -----NOTE-----

Separate Condition entry is allowed for each battery.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more batteries with one or more battery cell parameters not within Category A limits.	A.1 Verify pilot cell electrolyte level and float voltage meet Table 3.8.7-1 Category B limits.	1 hour
	<u>AND</u> A.2 Verify battery cell parameters meet Table 3.8.7-1 Category B limits.	8 hours <u>AND</u> Once per 7 days thereafter
	<u>AND</u> A.3 Restore battery cell parameters to Category A limits of Table 3.8.7-1.	31 Days
B. Required Action A.1 or A.2 and associated Completion Time for Condition A not met.	B.1 Enter TS 3.8.6	Immediately
C. Required Action A.3 and associated Completion Time for Condition A not met.	C.1 Declare associated battery inoperable.	Immediately

(continued)

## ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Entry into TS 3.8.6 Condition C with electrolyte level below the top of the plates.	D.1 Apply equalizing charge to battery/or affected cell.  <u>AND</u>  Verify affected cell meets Table 3.8.7-1 Category A and B Limits for float voltage and temperature.	31 Days
E. Required Action D.1 and associated Completion Time for Condition D not met.  <u>OR</u>  One or more batteries on one 125 VDC electrical power subsystem or on one 250 VDC electrical power subsystem with average electrolyte temperature less than the Table 3.8.7-1 Category B Limits.  <u>OR</u>  One or more batteries on one 125 VDC electrical power subsystem or on one 250 VDC electrical power subsystem with connection resistance $\geq 100.0 \text{ E-6 ohms}$ for any single connection or the calculated average resistance for the battery is $> 50.0 \text{ E-6 ohms}$ .	E.1 Declare associated battery inoperable.	Immediately

## TECHNICAL REQUIREMENT SURVEILLANCE

SURVEILLANCE	FREQUENCY
TRS 3.8.7.1 Verify for each terminal and connector:  No visible corrosion  <u>OR</u>  a. $\leq 50.0\text{E-}6$ ohms;  <u>OR</u>  b. $\leq 100.0\text{E-}6$ ohms with the calculated average resistance for the battery $< 50.0\text{E-}6$ ohms.	92 Days
TRS 3.8.7.2 Verify average electrolyte temperature (minimum of 10% of cells) is within Table 3.8.7-1 Category A limits.	92 Days
TRS 3.8.7.3 Verify the average of the specific gravity (corrected for temperature) of all the connected cells $> 1.195$ and no cell more than 0.020 below the average.	2 Years
TRS 3.8.7.4 Verify Battery cells, cell plates, and racks show no visual indication of physical damage or abnormal deterioration that could potentially degrade battery performance.	2 Years
TRS 3.8.7.5 Verify the battery connection resistance is:  a. $< 100.0\text{E-}6$ ohms for any single connection;  <u>AND</u>  b. The calculated average resistance for the battery is $< 50.0\text{E-}6$ ohms.	2 Years

Table 3.8-7 (page 1 of 1)  
Batter/Battery Cell Parameter Requirements

CELL PARAMETER	CATEGORY A: LIMITS FOR EACH CONNECTED CELL	CATEGORY B: ALLOWABLE LIMITS FOR EACH CONNECTED CELL
Electrolyte Level	$\geq$ Minimum level indication mark, and $\leq \frac{1}{4}$ inch above maximum level indication mark <sup>(a)</sup>	Above top of plates, and not overflowing
Float Voltage	$\geq 2.13$ V	$\geq 2.07$ V
Cell Temperature	$\geq 60$ Degrees F	$\geq 60$ Degrees F

- (a) It is acceptable for the electrolyte level to temporarily increase above the specified maximum level during and immediately following equalizing charges provided it is not overflowing.

## B 3.8.7 Battery Monitoring and Maintenance Program

---

BASES

---

## BACKGROUND

This TRO delineates the limits on electrolyte temperature, electrolyte level, float voltage, and specific gravity for the Unit 1, when common loads are aligned, and Unit 2 DC electrical power subsystems batteries and comprises the "Battery Monitoring and Maintenance Program" as required under Technical Specification 5.5.13. A discussion of these batteries and their OPERABILITY requirements is provided in the Bases for Technical Specification LCO 3.8.4, "DC Sources—Operating," and LCO 3.8.5, "DC Sources—Shutdown."

APPLICABLE  
SAFETY ANALYSES

The initial conditions of Design Basis Accident (DBA) and transient analyses in FSAR, Chapter 6 (Ref. 1) and Chapter 15 (Ref. 2), assume Engineered Safety Feature systems are OPERABLE. The DC electrical power subsystems provide normal and emergency DC electrical power for the diesel generators (DGs), emergency auxiliaries, and control and switching during all MODES of operation.

The OPERABILITY of the DC subsystems is consistent with the initial assumptions of the accident analyses and is based upon meeting the design basis of the unit. This includes maintaining DC sources identified in Technical Specification Table 3.8.4-1 OPERABLE during accident conditions, in the event of:

- a. An assumed loss of all offsite AC or all onsite AC power; and
- b. A worst case single failure.

Since battery cell parameters support the operation of the DC electrical power subsystems, they satisfy Criterion 3 of the NRC Policy Statement (Ref. 3).

## TRO

Battery cell parameters must remain within acceptable limits to ensure availability of the required DC power to shut down the reactor and maintain it in a safe condition after an anticipated operational occurrence or a postulated DBA.

Electrolyte limits are conservatively established, allowing continued DC electrical system function even with Category A and B limits not met.

---

(continued)

---

BASES (continued)

---

## APPLICABILITY

The battery cell parameters are required solely for the support of the associated DC electrical power subsystem. Therefore, battery cell parameters are required to be within required limits only when the associated DC power source is required to be OPERABLE. Refer to the Applicability discussions in Technical Specification Bases for LCO 3.8.4 and LCO 3.8.5.

---

## ACTIONS

A Note has been added to provide clarification that, for the purpose of this TRO, separate Condition entry is allowed for each battery. This is acceptable, since the Required Actions for each Condition provide appropriate compensatory actions for each inoperable battery. Complying with the Required Actions may allow for continued operation, and subsequent inoperable batteries are governed by subsequent Condition entry and application of associated Required Actions.

A.1, A.2, and A.3

With parameters of one or more cells in one or more batteries not within limits (i.e., Category A limits not met or Category B limits not met, or Category A and B limits not met) but within the Category C limits specified in Table 3.8.7-1, the battery is degraded but there is still sufficient capacity to perform the intended function. Therefore, the affected battery is not required to be considered inoperable solely as a result of Category A or B limits not met and continued operation is permitted for a limited period.

The pilot cell electrolyte level and float voltage are required to be verified to meet the Category C limits within 1 hour (Required Action A.1). This check provides a quick indication of the status of the remainder of the battery cells. One hour provides time to inspect the electrolyte level and to confirm the float voltage of the pilot cell. One hour is considered a reasonable amount of time to perform the required verification.

Verification that the Category C limits are met (Required Action A.2) provides assurance that during the time needed to restore the parameters to the Category A and B limits, the battery is still capable of performing its intended function. A period of 8 hours is allowed to complete the initial verification because average temperature measurement must be obtained for the battery. Taking into consideration both the time required to perform the required verification and the assurance that the battery cell parameters are not severely degraded, this time is considered reasonable.

---

(continued)

---



---

BASES

---

## ACTIONS

A.1, A.2, and A.3 (continued)

Verification of the average temperature of the battery within the design bases ensures operability. The verification is repeated at 7-day intervals until the parameters are restored to Category A and B limits.

Continued operation is only permitted for 31 days before battery cell parameters must be restored to within Category A and B limits. Taking into consideration that, while battery capacity is degraded, sufficient capacity exists to perform the intended function and to allow time to fully restore the battery cell parameters to normal limits, this time is acceptable for operation prior to declaring the DC batteries inoperable.

B.1

Failure to complete the checks required for Actions A.1 or A.2 require immediate action. Entry into Technical Specification 3.8.6 must be entered immediately.

C.1

When any battery parameter is outside the Category C limit for any connected cell, sufficient capacity to supply the maximum expected load requirement is not ensured and the corresponding DC electrical power subsystem must be declared inoperable. Additionally, other potentially extreme conditions, such as not completing the Required Action A.3 within the required Completion Time also are cause for immediately declaring the associated DC electrical power subsystem inoperable.

D.1

Cells that have been discovered with electrolyte level below the top of the plates are equalized and tested IAW Technical Specification 5.5.13.

E.1

Required Action E.1 is to ensure that under extreme conditions, such as failure to complete the required Action D.1 within the required completion time, average electrolyte temperature falling below 60° F, or intercell connections found not within required connection resistance also are cause for immediately declaring the associated battery inoperable.

---

(continued)

---

BASES (continued)

---

SURVEILLANCE  
REQUIREMENTSTRS 3.8.7.1

The quarterly inspection for visible corrosion at the terminal and connector is consistent with IEEE-450. The "OR" condition is to ensure, if there is visible corrosion, intercell connection resistance is not impacted.

TRS 3.8.7.2

The quarterly inspection of average electrolyte temperature is consistent with IEEE-450 recommendation to check 10% of the connected cells. Lower than normal temperatures act to inhibit or reduce battery capacity. This TRS ensures that the operating temperatures remain within an acceptable operating range. This limit is based on manufacturer's recommendations and battery sizing calculations.

TRS 3.8.7.3

IEEE-450 (Ref. 4) recommends a check of specific gravity every year. The Frequency of the TRS (every 2 years) is acceptable because other administrative controls ensure adequate battery performance during the 2-year interval and aligns performance during refueling outages. Further, operating experience has shown this component usually pass the TRS when performed at the 2-year Frequency; therefore, the frequency is acceptable from a reliability standpoint.

The limit specified for specific gravity for each connected cell is no more than 0.020 below the average of all connected cells with the temperature corrected average  $\geq 1.195$ . These values are based on manufacturer's recommendations for the minimum required value. The minimum specific gravity value required for each cell ensures that the effects of a highly charged or newly installed cell do not mask overall degradation of the battery.

Specific gravity gradients produced during the recharging process may result in delays of several days until the specific gravity stabilizes. However, a minor battery recharge (such as equalizing charge that does not follow a deep discharge) does not produce specific gravity gradients that are significant.

---

(continued)

---

BASES

---

SURVEILLANCE  
REQUIREMENTS  
(continued)TRS 3.8.7.4

Visual inspection of the battery cells, cell plates, and battery racks provides an indication of physical damage or abnormal deterioration that could potentially degrade battery performance. The presence of physical damage or deterioration does not represent a failure of the TRS, provided an evaluation determines that the physical damage or deterioration does not affect the OPERABILITY of the battery (its ability to perform its design function). The Frequency of the TRS is acceptable because other administrative controls ensure adequate battery performance during the 2-year interval and aligns performance during refueling outages. Further, operating experience has shown these components usually pass the TRS when performed at the 2-year Frequency; therefore, the frequency is acceptable from a reliability standpoint.

TRS 3.8.7.5

The connection resistance limits for this SR must be below the limits specified in the SR. The calculated average resistance limit ensure that the total voltage drop across the battery connections is consistent to those assumed in the battery calculations, while the upper limit for battery resistance prevents the possibility of battery damage due to overheating of the connections.

The Frequency of this SR is acceptable because other administrative controls ensure adequate battery performance during the 2-year interval and aligns performance with refueling outage intervals. Furthermore, operating experience has shown these components usually pass the Surveillance when performed at the 2-year Frequency; therefore, the Frequency is acceptable from a reliability standpoint.

Table 3.8.7-1

This table delineates the limits on electrolyte level, float voltage, and temperature for two different categories. The meaning of each category is discussed below.

Category A defines the normal parameter limits for each connected cell. The term "connected cell" excludes any battery cell that may be jumpered out.

---

(continued)

BASES

---

SURVEILLANCE  
REQUIREMENTSTable 3.8.7-1 (continued)

The Category A limits specified for electrolyte level are based on manufacturer's recommendations and are consistent with the guidance in IEEE-450 (Ref. 4), with the extra ¼ inch allowance above the high water level indication for operating margin to account for temperature and charge effects. In addition to this allowance, footnote (a) to Table 3.8.7-1 permits the electrolyte level to be above the specified maximum level during equalizing charge, provided it is not overflowing. These limits ensure that the plates suffer no physical damage, and that adequate electron transfer capability is maintained in the event of transient conditions. IEEE-450 (Ref. 4) recommends that electrolyte level readings should be made only after the battery has been at float charge for at least 72 hours.

The Category A limit specified for float voltage is  $\geq 2.13$  V per cell. This value is based on the recommendation of IEEE-450 (Ref. 4) which states that prolonged operation of cells below 2.13 V can reduce the life expectancy of cells.

Category B defines the limits for each connected cell. These values, although reduced, provide assurance that sufficient capacity exists to perform the intended function and maintain a margin of safety. When any battery parameter is outside the Category B limits, the assurance of sufficient capacity described above no longer exists, and the battery must be declared inoperable.

The Category B limit specified for electrolyte level (above the top of the plates and not overflowing) ensures that the plates suffer no physical damage and maintain adequate electron transfer capability. The Category B allowable limit for voltage is based on IEEE-450 (Ref. 4), which states that a cell voltage of 2.07 V or below, under float conditions and not caused by elevated temperature of the cell, indicates internal cell problems and may require cell replacement.

---

(continued)

BASES

---

REFERENCES

1. FSAR, Chapter 6
  2. FSAR, Chapter 15
  3. Final Policy Statement on Technical Specifications Improvements,  
July 22, 1993 (58 FR 39132)
  4. IEEE Standard 450-1995
-