

9.11 DETAILED RESULTS FOR SURVEY UNIT 011

Room 2007 Walls & Ceiling (Class 2 Interior Area)

INDEX

SU-011 Survey Package Worksheet	1
SU-011 Survey Maps	4
SU-011 Alpha Fixed Point Survey Reports	5
SU-011 Alpha Scan Survey Reports	10
SU-011 Smear Survey Reports	15
SU-011 Instrument Efficiencies and MDC Worksheets	16
SU-011 COMPASS Survey Plan	18
SU-011 Survey Location Calculations	20



Survey Package Worksheet for NIST Boulder SU011

Package Identification No.: SU11F/SU11S	Prepared by: Paul C. Ely
Location: Room 2007 Walls & Ceiling (Class 2 Interior Area)	Date Prepared: 2/17/2009
Area Classification: Class 2	Signature: <i>Paul Ely</i>

Area Description

The survey area includes all wall areas and ceiling.

Historical Information

On June 9, 2008, researchers ruptured a glass vial of 0.25 grams of mixed plutonium isotopes in the form of $\text{PuSO}_4 \cdot 4\text{H}_2\text{O}$ resulting in the contamination of laboratory rooms 2124, 2124A, 2120, 2120A and 2007 in Building 1 on the NIST campus in Boulder, Colorado. Room 2124 is the room where the glass vial ruptured and is the room that was the most contaminated. This room is a Class 2 area because it had activity in excess of the release limit of 696 dpm/100 cm² (44 cpm/100 cm²). The isotopes of concern are Pu-238, Pu-239, Pu-240, Pu-241, Pu-242 and Am-241.

General Survey Instructions

1. Use gas proportional detector model numbers 43-68, or equivalent detector as approved by the ES PM for alpha surface activity surveys. The total instrument efficiency should use the following factors:
 - ϵ_i , 2π instrument efficiency from calibration papers. If a 4π efficiency is reported, calculate the 2π efficiency as follows using a 5% alpha Back Scatter factor (BS). $\epsilon_i = (2 * \epsilon_{4\pi}) \setminus (1 + \text{BS})$
 - ϵ_s , the alpha surface efficiency is 25%.
 - ϵ_f , the fraction of radionuclides detected in the survey, 52% for the NIST-Boulder broken vial material.
 - ϵ_t , the total alpha efficiency = $\epsilon_i * \epsilon_s * \epsilon_f$
2. Perform surface scans at a scan speed of 1 probe width per four seconds or less for the 43-68. Any locations that exceed 35 cpm alpha must be marked with a felt tip pen or equivalent and the extent of the elevated area recorded. Alternatively the 43-37 large area detector may be used for scanning at a scan speed of 1 probe width per four seconds or less and any locations that exceed 256 cpm alpha must be marked with a felt tip pen or equivalent and the extent of the elevated area recorded.
 - 20% scan of walls and ceiling for alpha contamination.
 - Complete a FSS Grid Scan Record to document scan data.
3. Perform direct alpha surface activity measurements at each measurement location provided on survey map(s).
4. Collect a removable surface activity sample over an area of 100 cm² in size at each measurement location provided on survey maps. Removable activity results are for information only and the same limits apply as for fixed contamination as a 10% smear activity removal factor is incorporated into the smear counting results. Notify the Project Manager if alpha smear results exceed 696 dpm/100 cm².
5. Irregular structure and fixed equipment flat surfaces are surveyed as above, curved surfaces are scanned using 43-68 probes (126 cm²) with additional smear samples obtained and documented on a judgmental basis with a least one sample per two (2) square meters of irregular surface area.

Special Instructions

- Source check instrumentation to Th-230 for alpha measurements.
- The static MDC for total alpha activity measurements shall be less than 345 dpm/100 cm².
- Perform a minimum of three one-minute field backgrounds using the plastic shield on the survey surface.
- Record maximum scan measurement results in cpm on a FSS Grid Scan Record.

- Measurement and sampling locations are based on a random-start rectangular pattern. If any location is inaccessible, offset the measurement location to the nearest usable location and document the x and y coordinates for the location used.
- The attached map provides measurement and sampling locations.
- Notify the ES Project Manager of locations that exceed 44 cpm/100 cm² total alpha surface activity.
- Attach photographic records if available and provide descriptive comments for each image under Survey Comments.

Survey performance (Initial and date as each survey is complete)

Package ID	Location Code				General Description	Beta Scan	Direct Beta	Direct Alpha	Alpha Scan	Direct Gamma	Smear Gross
	L1	L2	L6	L7							
NIST Boulder SU011 Class 2 Area											
SU11F					Wall	N/A	N/A	@60 sec	20%	@100 cm	α
SU11F					Wall	N/A	N/A	4 Sm 3-31-09	N/A	N/A	4 Sm 3-31-09
SU11F					Wall	N/A	N/A	4 Sm 3-31-09	N/A	N/A	4 Sm 3-31-09
SU11F					Wall	N/A	N/A	6 Sm 3-31-09	N/A	N/A	6 Sm 3-31-09
SU11F					Wall	N/A	N/A	4 Sm 3-31-09	N/A	N/A	4 Sm 3-31-09
SU11F					Ceiling	N/A	N/A	6 Sm 3-31-09	N/A	N/A	6 Sm 3-31-09
SU11S					Wall	N/A	N/A	N/A	∞ 7/1/09	N/A	N/A
SU11S					Wall	N/A	N/A	N/A	∞ 7/1/09	N/A	N/A
SU11S					Wall	N/A	N/A	N/A	∞ 7/1/09	N/A	N/A

Survey Package Worksheet SU11F/SU11S (cont'd)

SU11S	W04	B0010	A thru B	8 thru 9	Wall	N/A	N/A	N/A	N/A	N/A	N/A	N/A
SU11S	C01	B0010	A thru C	10 thru 11	Ceiling	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ACE 3-30-09
N/A
DO 4-1-09

Survey Comments


Blank area for survey comments.

Package Review

Surveyor(s) Signatures: *Sharon McChorney* *Ed L. E. Seaman*
 Date Package Completed: *4/1/09*
 Package Reviewed by and Date (Signature): *Paul Ely 4/1/09*

2007 Ceiling
C01

(Mark Ceiling Survey
Locations on Floor)



NIST Survey Unit 011

ATTACHMENT 14 - SURVEY DOWNLOAD DATA SHEET

Download Technician: Print Name: Sean McChesney Signature: [Signature] Date: 3/20/09

Download Station #: 3 Download File #: 30
 Serial # Verification: Model 2350-1 Detector: Problems: (See Comments)

Survey Technician(s):
 Print Name: Sharon McChesney User ID: SYM1098 Signature: [Signature] Date: 3-20-09

Print Name: _____ User ID: _____ Signature: _____ Date: _____

Instrument Serial #(s): Model 2350-1: 117566

Survey Unit Description: 5407F 5411F Rm2007 Points on Floor A1-A20, Walls A1-B18, Ceiling A19-C24
 (Example: Survey Package + description i.e. D16, Building 43, Area 09, Room 100, Floor - Grid Locations A1 through A7)

Instrument Calibration Due Date: 10-8-09 Detector Calibration Due Date: 8-8-09

Type Of Survey: Term Survey Characterization Information Only
 Other (explain): Prely 3-21-09

Type of Measurement	Detector Serial Number	Detector Model Number	Detector Efficiency	Source Mean BKG Value	Pre & Post Use Info	
					Pre File#	Post File#
<input type="checkbox"/> Alpha α		43-37				
<input type="checkbox"/> Beta β		43-68B				
<input checked="" type="checkbox"/> Alpha α	<u>092508</u>	43-68A	<u>.0414</u>		<u>28</u>	
<input type="checkbox"/> Gamma γ		44-2	N/A	N/A		
<input type="checkbox"/> Alpha α		43-93				

Local Area Background Measurements

MEAN Value in cpm ↓


	1	2	3	4	5	6	
β Beta							
α Alpha	<u>1</u>	<u>3</u>	<u>2</u>	<u>11</u>			<u>4.3</u>

COMMENTS: _____

Download Name: 00000030

Survey Description: SU11F Room 2007 Points on Floor, Walls and Ceiling

M2350-1 Sample Results



2 of 4

Duratek Alpha Survey Report

Download File Name: 00000030

Package ID(L1)	Surface (L2)	Sample #	Counts	Time (sec)	Count Type (L5)	Material Type (L6)	Grid ID(L7)	Location # (L8)	Bkgd	Net DPM/100cm2
SU07F	FL01	0	1.0	60	FLDBK	B0002	ZZZZZ	1	4	-58
SU07F	FL01	1	7.0	60	FLDCT	B0002	A	1	4	<u>58</u>
SU07F	FL01	2	9.0	60	FLDCT	B0002	A	2	4	<u>96</u>
SU07F	FL01	3	1.0	60	FLDCT	B0002	A	3	4	-58
SU07F	FL01	4	6.0	60	FLDCT	B0002	A	4	4	38
SU07F	FL01	5	6.0	60	FLDCT	B0002	B	5	4	38
SU07F	FL01	6	3.0	60	FLDCT	B0002	B	6	4	-19
SU07F	FL01	7	2.0	60	FLDCT	B0002	B	7	4	-38
SU07F	FL01	8	4.0	60	FLDCT	B0002	B	8	4	0
SU07F	FL01	9	7.0	60	FLDCT	B0002	C	9	4	<u>58</u>
SU07F	FL01	10	0.0	60	FLDCT	B0002	C	10	4	-77
SU07F	FL01	11	2.0	60	FLDCT	B0002	C	11	4	-38
SU07F	FL01	12	0.0	60	FLDCT	B0002	C	12	4	-77
SU07F	FL01	13	4.0	60	FLDCT	B0002	D	13	4	0
SU07F	FL01	14	7.0	60	FLDCT	B0002	D	14	4	<u>58</u>
SU07F	FL01	15	8.0	60	FLDCT	B0002	D	15	4	<u>77</u>
SU07F	FL01	16	2.0	60	FLDCT	B0002	D	16	4	-38
SU07F	FL01	17	1.0	60	FLDCT	B0002	E	17	4	-58
SU07F	FL01	18	6.0	60	FLDCT	B0002	E	18	4	38
SU07F	FL01	19	10.0	60	FLDCT	B0002	E	19	4	115
SU07F	FL01	20	4.0	60	FLDCT	B0002	E	20	4	0
SU07F	FL01	21	3.0	60	FLDBK	B0002	ZZZZZ	2	4	-19
SU11F	W01	22	5.0	60	FLDCT	B0010	A	1	4	19
SU11F	W01	23	3.0	60	FLDCT	B0010	A	2	4	-19
SU11F	W01	24	9.0	60	FLDCT	B0010	B	3	4	<u>96</u>
SU11F	W01	25	7.0	60	FLDCT	B0010	B	4	4	<u>58</u>
SU11F	W02	26	5.0	60	FLDCT	B0010	A	5	4	19
SU11F	W02	27	7.0	60	FLDCT	B0010	A	6	4	<u>58</u>
SU11F	W02	28	3.0	60	FLDCT	B0010	B	7	4	-19
SU11F	W02	29	6.0	60	FLDCT	B0010	B	8	4	38
SU11F	W03	30	9.0	60	FLDCT	B0010	A	9	4	<u>96</u>
SU11F	W03	31	6.0	60	FLDCT	B0010	A	10	4	38
SU11F	W03	32	2.0	60	FLDCT	B0010	A	11	4	-38
SU11F	W03	33	9.0	60	FLDCT	B0010	B	12	4	<u>96</u>
SU11F	W03	34	7.0	60	FLDCT	B0010	B	13	4	<u>58</u>
SU11F	W03	35	9.0	60	FLDCT	B0010	B	14	4	<u>96</u>
SU11F	W04	36	3.0	60	FLDCT	B0010	A	15	4	-19
SU11F	W04	37	5.0	60	FLDCT	B0010	A	16	4	19

<i>Alpha Flag</i>	50 - _____
<i>Alpha Max Flag</i>	100 <input style="width: 80px; height: 15px;" type="text"/>

Package ID(L1)	Surface (L2)	Sample #	Counts	Time (sec)	Count Type (L5)	Material Type (L6)	Grid ID(L7)	Location # (L8)	Bkgd	Net DPM/100cm2
SU11F	W04	38	12.0	60	FLDCT	B0010	B	17	4	153
SU11F	W04	39	6.0	60	FLDCT	B0010	B	18	4	38
SU11F	W04	40	2.0	60	FLDBK	B0010	ZZZZZ	3	4	-38
SU11F	C01	41	12.0	60	FLDCT	B0010	A	19	4	153
SU11F	C01	42	12.0	60	FLDCT	B0010	A	20	4	153
SU11F	C01	43	15.0	60	FLDCT	B0010	B	21	4	211
SU11F	C01	44	13.0	60	FLDCT	B0010	B	22	4	173
SU11F	C01	45	17.0	60	FLDCT	B0010	C	23	4	249
SU11F	C01	46	15.0	60	FLDCT	B0010	C	24	4	211
SU11F	C01	47	11.0	60	FLDBK	B0010	ZZZZZ	4	4	134
ZZZZZ	ZZZZZ	48	68.0	600	PTABK	B9999	ZZZZZ	1	0	130
ZZZZZ	ZZZZZ	49	5,461.0	60	PTSC1	B9999	ZZZZZ	1	0	104,689

Alpha Flag	50	-	_____
Alpha Max Flag	100		<input type="text"/>

Friday, March 20, 2009

Page 4 of 4

2007
ATTACHMENT 14 - SURVEY DOWNLOAD DATA SHEET ✓

Download Technician: Print Name: Sean McChesney Signature: *Sean McChesney* Date: 3/20/09
 Download Station #: 3 Download File #: 29
 Serial # Verification: Model 2350-1 Detector: Problems: (See Comments)

Survey Technician(s):
 Print Name: Siemens User ID ees 658 Signature: *S* Date: 3.20.09
 Print Name: _____ User ID _____ Signature: _____ Date: _____

Instrument Serial #(s): Model 2350-1: 80502

Survey Unit Description: Rm 2007 walls 1, 2, 3 / ceiling B-21
 (Example: Survey Package + description i.e. D16, Building 43, Area 09, Room 100, Floor - Grid Locations A1 through A7)

Instrument Calibration Due Date: 9.12.09 Detector Calibration Due Date: 2.10.10

Type Of Survey: Term Survey Characterization Information Only
 Other (explain): FSS

Type of Measurement	Detector Serial Number	Detector Model Number	Detector Efficiency	Source Mean BKG Value	Pre & Post Use Info	
					Pre File#	Post File#
<input type="checkbox"/> Alpha α		43-37				
<input type="checkbox"/> Beta β		43-68B				
<input checked="" type="checkbox"/> Alpha α	<u>75614</u>	43-68A	<u>.0428</u>			
<input type="checkbox"/> Gamma γ		44-2	N/A	N/A		
<input type="checkbox"/> Alpha α		43-93				


Local Area Background Measurements							MEAN Value in cpm ↓
β Beta	1	2	3	4	5	6	<u>5</u>
α Alpha	1	2	3	4	5	6	<u>5</u>

COMMENTS: _____

Download Name: 00000029

Survey Description: Room 2007 wall 1,2,3,ceiling B-21

M2350-1 Sample Results



Duratek Alpha Survey Report

Download File Name: 00000029

Package ID(L1)	Surface (L2)	Sample #	Counts	Time (sec)	Count Type (L5)	Material Type (L6)	Grid ID(L7)	Location # (L8)	Bkgd	Net DPM/100cm2
ZZZZZ	ZZZZZ	0	32.0	600	PRABK	B0002	ZZZZZ	1	0	53
ZZZZZ	ZZZZZ	1	4,363.0	60	PRSC1	B0002	ZZZZZ	1	0	71,840
SU11S	W1	2	3.0	60	FLDBK	B0010	B	3	5	-33
SU11S	W2	3	5.0	60	FLDBK	B0010	B	7	5	0
SU11S	W2	4	8.0	60	FLDBK	B0010	B	8	5	49
SU11S	W3	5	5.0	60	FLDBK	B0010	B	13	5	0
SU11S	C01	6	7.0	60	FLDBK	B0010	B	21	5	33
SU11S	C01	7	58.0	600	PTABK	B0010	B	21	5	13
SU11S	C01	8	4,319.0	60	PTSC1	B0010	B	21	5	71,033

Alpha Flag

50 - _____

Alpha Max Flag

100

Friday, March 20, 2009

Page 3 of 3

NIST BOULDER FSS GRID RECORD

Survey Package: <u>54113</u>	Room / Surface: <u>2007-walls</u>
Instrument Model No: <u>2350-1</u>	Instrument Serial No: <u>80502</u>
Detector Model No: <u>4368A</u>	Detector Serial No: <u>75164</u>
Detector Area (cm ²): <u>125</u>	Detector Total α Eff: <u>.0428</u>
Technician Name: <u>Siemens</u>	

GRID	MAX READING (cpm)	INITIALS	DATE
B-3	9	es	3.20.09
B7	15	es	3.20.09
B-8	11	es	3.20.09
B-13	6	es	3-20-09
B-21	7	es	3.20.09

Tennelec XLB Series 5 - NIST Boulder - FSS Smear Analysis (Fixed Activity Equivalent)

Report Revision: NIST-2 NIST09-0424

Date: 3/20/2009 2:38:24PM
Counting Unit ID: Tennelec 84920
Batch Name: FSS Smears 3 min - 200903201438
Batch Start Time: Fri, March 20, 2009 02:38:24 PM
Geometry: 1/8" Stainless Steel
Alpha Surface Eff. (including self Absorption) %: 0.25
Beta Surface Eff. (including self Absorption) %: 0.25
Alpha Detection Factor: 0.52 **Beta Detection Factor:** 1.00
Alpha BS: 0.05 **Background Subtract:** Background Subtracted
Beta BS: 0.30 **Batch ID:** 54011

Alpha Eff. Std:	060101 Alpha Th-230
4 π Alpha Eff. %:	34.29 ± 0.30
2 π Alpha Eff. %:	65.32 ± 0.58
Alpha BG CPM:	0.08 ± 0.04
Beta Eff. Std:	079706 Beta Tc-99
4 π Beta Eff. %:	24.19 ± 0.32
2 π Beta Eff. %:	37.22 ± 0.49
Beta BG CPM:	1.52 ± 0.16

Cal Due: Aug 15 2009

Carrier	Sample ID	Alpha Activity				Beta Activity				Count time (min)	Alpha CPM	Beta CPM	Count Start
		DPM	2 Sigma	Fla	MDA	DPM	2 Sigma	Fla	MDA				
46	1	-9.81	8.78	<MDA	172.40	159.40	217.67	<MDA	354.52	3.00	0.00	3.00	3/20/2009 4:46:08PM
47	2	-9.81	8.78	<MDA	172.40	-91.34	106.95	<MDA	354.52	3.00	0.00	3.00	3/20/2009 4:49:20PM
48	3	29.44	79.01	<MDA	172.40	123.58	205.52	<MDA	354.52	3.00	0.33	3.00	3/20/2009 4:52:33PM
49	4	-9.81	8.78	<MDA	172.40	159.40	217.67	<MDA	354.52	3.00	0.00	3.00	3/20/2009 4:55:46PM
50	5	29.44	79.01	<MDA	172.40	51.94	178.79	<MDA	354.52	3.00	0.33	3.00	3/20/2009 4:58:59PM
51	6	29.44	79.01	<MDA	172.40	123.58	205.52	<MDA	354.52	3.00	0.33	3.00	3/20/2009 5:02:12PM
52	7	29.44	79.01	<MDA	172.40	266.87	250.62	<MDA	354.52	3.00	0.33	3.00	3/20/2009 5:05:25PM
53	8	-9.81	8.78	<MDA	172.40	-55.52	128.72	<MDA	354.52	3.00	0.00	3.00	3/20/2009 5:08:38PM
54	9	29.44	79.01	<MDA	172.40	16.12	163.80	<MDA	354.52	3.00	0.33	3.00	3/20/2009 5:11:51PM
55	10	-9.81	8.78	<MDA	172.40	51.94	178.79	<MDA	354.52	3.00	0.00	3.00	3/20/2009 5:15:04PM
56	11	-9.81	8.78	<MDA	172.40	123.58	205.52	<MDA	354.52	3.00	0.00	3.00	3/20/2009 5:18:17PM
57	12	-9.81	8.78	<MDA	172.40	159.40	217.67	<MDA	354.52	3.00	0.00	3.00	3/20/2009 5:21:30PM
58	13	-9.81	8.78	<MDA	172.40	195.22	229.17	<MDA	354.52	3.00	0.00	3.00	3/20/2009 5:24:43PM
59	14	29.44	79.01	<MDA	172.40	87.76	192.62	<MDA	354.52	3.00	0.33	3.00	3/20/2009 5:27:55PM
60	15	-9.81	8.78	<MDA	172.40	123.58	205.52	<MDA	354.52	3.00	0.00	3.00	3/20/2009 5:31:08PM
61	16	-9.81	8.78	<MDA	172.40	51.94	178.79	<MDA	354.52	3.00	0.33	3.00	3/20/2009 5:34:21PM
62	17	29.44	79.01	<MDA	172.40	159.40	217.67	<MDA	354.52	3.00	0.33	3.00	3/20/2009 5:37:34PM
63	18	29.44	79.01	<MDA	172.40	195.22	229.17	<MDA	354.52	3.00	0.33	3.00	3/20/2009 5:40:47PM
64	19	68.70	111.39	<MDA	172.40	195.22	229.17	<MDA	354.52	3.00	0.67	3.00	3/20/2009 5:44:00PM
65	20	-9.81	8.78	<MDA	172.40	87.76	192.62	<MDA	354.52	3.00	0.00	3.00	3/20/2009 5:47:13PM
66	21	-9.81	8.78	<MDA	172.40	16.12	163.80	<MDA	354.52	3.00	0.00	3.00	3/20/2009 5:50:26PM
67	22	-9.81	8.78	<MDA	172.40	16.12	163.80	<MDA	354.52	3.00	0.00	3.00	3/20/2009 5:53:39PM
68	23	29.44	79.01	<MDA	172.40	159.40	217.67	<MDA	354.52	3.00	0.33	3.00	3/20/2009 5:56:52PM
	24	-9.81	8.78	<MDA	172.40	87.76	192.62	<MDA	354.52	3.00	0.00	3.00	3/20/2009 6:00:05PM

QA Reviewer: Paul Eg
Date: 3-30-09
Technician: LC Finn
Date: 3-23-09

Static and Scan MDC Worksheet for 43-68 Gas Flow Proportional Detectors

Static MDC (43-68)

$$MDC_{\alpha} = \frac{\frac{3}{t_s} + 3.29 * \sqrt{\left(\frac{R_b}{t_s} + \frac{R_b}{t_b}\right)}}{\epsilon_i * \epsilon_s * \frac{A}{100}}$$

CS-FO-PR-001 Rev. 1, Section 4.8.1.2

Scan MDC (43-68)

$$MDC_{Scan} = \frac{d' * \sqrt{b_i} * \frac{60}{i}}{\sqrt{p} * \epsilon_i * \epsilon_s * \frac{A}{100}}$$

CS-FO-PR-001 Rev. 1, Section 4.8.3.3 to 4.8.3.5

Inputs

INST#	80502	Instrument Serial Number
DET#	75164	Detector Serial Number
R _B	2.6	Background Count Rate (cpm)
t _b	10	Background Count Time (min)
t _s	1	Sample Count Time (min)
A	126	Area of Detector (cm ²)
ε _{4π}	0.192	Detector Efficiency (4π)
BS	0.05	Backscatter
ε _i	0.366	Detector Efficiency (2π)
ε _s	0.25	Surface Efficiency
S _e	0.52	source efficiency (radionuclide detectability)

Outputs

ε _t	0.0475	Total Detection Efficiency
MDC	143	dpm/100 cm ²
Enter data		
Formula, enter 2π efficiency data directly if available		
Change if necessary		

Inputs

INST#	80502	Instrument Serial Number
DET#	75164	Detector Serial Number
d'	1.38	Index of Sensitivity
p	0.50	Surveyor Efficiency
Scan ε _i	0.33	Scanning Instrument Efficiency (2π)
Scan ε _s	0.25	Scanning Surface Efficiency
S _e	0.52	source efficiency (radionuclide detectability)

43-68

Scan Speed	2.2	(cm/sec)
R _B	2.6	Background Count Rate (cpm)
b _i	0.173333	Background counts per observation interval
Detector Width	8.8	width of detector in direction of scan (cm)
A	126	Area of Detector (cm ²)

Outputs

ε _t	0.0428	Total Detection Efficiency
i	4.00	Observation interval in seconds (detector width divided by the scan speed)
Scan MDC	226	dpm/100 cm ²

Reviewed by: Paul Eley

Date: 3-21-09

Static and Scan MDC Worksheet for 43-68 Gas Flow Proportional Detectors

Static MDC (43-68)

$$MDC_{\alpha} = \frac{\frac{3}{t_s} + 3.29 * \sqrt{\left(\frac{R_b}{t_s} + \frac{R_b}{t_b} \right)}}{\epsilon_i * \epsilon_s * \frac{A}{100}}$$

CS-FO-PR-001 Rev. 1, Section 4.8.1.2

Scan MDC (43-68)

$$MDC_{Scan} = \frac{d' * \sqrt{b_i} * \frac{60}{i}}{\sqrt{p} * \epsilon_i * \epsilon_s * \frac{A}{100}}$$

CS-FO-PR-001 Rev. 1, Section 4.8.3.3 to 4.8.3.5

Inputs

INST#	117566	Instrument Serial Number
DET#	92508	Detector Serial Number
R _B	1.6	Background Count Rate (cpm)
t _b	10	Background Count Time (min)
t _s	1	Sample Count Time (min)
A	126	Area of Detector (cm ²)
ε _{4π}	0.167	Detector Efficiency (4π)
BS	0.05	Backscatter
ε _i	0.318	Detector Efficiency (2π)
ε _s	0.25	Surface Efficiency
S _e	0.52	source efficiency (radionuclide detectability)

Outputs

ε _t	0.0414	Total Detection Efficiency
MDC	141	dpm/100 cm ²
Enter data		
Formula, enter 2π efficiency data directly if available		
Change if necessary		

Inputs

INST#	117566	Instrument Serial Number
DET#	92508	Detector Serial Number
d'	1.38	Index of Sensitivity
p	0.50	Surveyor Efficiency
Scan ε _i	0.29	Scanning Instrument Efficiency (2π)
Scan ε _s	0.25	Scanning Surface Efficiency
S _e	0.52	source efficiency (radionuclide detectability)

43-68

Scan Speed	2.2	(cm/sec)
R _B	1.6	Background Count Rate (cpm)
b _i	0.106667	Background counts per observation interval
Detector Width	8.8	width of detector in direction of scan (cm)
A	126	Area of Detector (cm ²)

Outputs

ε _t	0.0372	Total Detection Efficiency
i	4.00	Observation interval in seconds (detector width divided by the scan speed)
Scan MDC	204	dpm/100 cm ²

Reviewed by: Paul Cly

Date: 3-18-09



BUILDING SURFACE SURVEY PLAN


Survey Plan Summary

Site Name: NIST Boulder Campus
 Planner(s): p ely
 Survey Unit Name: SU011 Room 2007 Walls & Ceiling
 Comments: N/A

Statistical Design Details

Area (m ²):	60	Classification:	2
Selected Test:	Sign	Estimated Sigma (cpm/100 cm ²):	1.2
DCGL (cpm/100 cm ²):	44	Sample Size (N):	14
LBGR (cpm/100 cm ²):	41	Estimated Conc. (cpm/100 cm ²):	1.4
Alpha:	0.050	Estimated Power:	1.0
Beta:	0.050		

Prospective Power Curve



Gross Activity Efficiency Data

Instrument Description: Ludlum 43-68 Gas Flow Proportional
 Physical Detector Area (cm²): 126
 DCGLw (dpm/100 cm²): 696
 Total Efficiency: 0.05
 DCGLw (cpm/100 cm²): 44

Contaminant	HTDC ^a	Energy ^b	Fract ^c	Inst. Eff.	Surf. Eff.	Total Eff.
Am-241	No	N/A	0.10	0.36	0.25	0.01
Pu-238	No	N/A	0.01	0.36	0.25	0.00
Pu-239	No	N/A	0.31	0.36	0.25	0.03
Pu-240	No	N/A	0.10	0.36	0.25	0.01
Pu-241	Yes	5.23	0.48	0.00	0.00	0.00

^aHard-to-detect contaminant ^bAverage beta energy (keV) [N/A indicates alpha emission] ^cActivity fraction

Gross Activity Mean and Sigma Data

Count Time (min): 1
 Sign Test Sigma (cpm/100 cm²): 1.2

Data/Material	Mean (cpm/100 cm ²)	Std. Dev. (cpm/100 cm ²)	MDC (dpm/100 cm ²)
SU	1.4	1.2	135

Report Created 02/18/2009 1038 (COMPASS v1.1.0)

Survey Unit 011
Class 2
Walls & Ceiling in Room 2007

X (Max):	68.0	feet	20.7	meters	Estimated dimension
Y (Max):	16.0	feet	4.9	meters	Estimated dimension
A (Area):	1,088	ft ²	101	m ²	Area of Survey area
Actual Survey Area:	640	ft ²			
Required Survey Points:	14	41%			Percent void area
N (Points):	32	24			Estimated Minimum Points

$$L = \left[\frac{A}{N} \right]^{1/2}$$

Spacing for a square grid

L= 1.8 meters (distance between measurement points)

X (Random):	5.5	random generated number
Y (Random):	0.9	random generated number
X (Origin):	17.7	initially generated random number
Y (Origin):	2.0	initially generated random number