

CCNPP3COLA PEmails

From: Rycyna, John
Sent: Tuesday, July 14, 2009 4:05 PM
To: Poche, Robert; katie.thurstin@unistarnuclear.com; McQueeney, Jennifer; michael.stevenson@unistarnuclear.com
Cc: CCNPP3COL Resource; Arora, Surinder; Curran, Gordon; Segala, John; Hearn, Peter; Colaccino, Joseph; Biggins, James; Vrahoretis, Susan; Simon, Marcia
Subject: Draft RAI No 132 SBPA 2721.doc
Attachments: Draft RAI No 132 SBPA 2721.doc

Rob,

Attached is DRAFT RAI No. 132. You have until July 29, 2009 to review it and to decide whether you need a conference call to discuss it. After the call or after July 29, 2009 the RAI will be finalized and sent to you. You then have 30 days to respond.

John Rycyna, PE
Sr. Project Manager
Division of New Reactor Licensing
Office of New Reactors
U.S. Nuclear Regulatory Commission
301-415-4122

Hearing Identifier: CalvertCliffs_Unit3Cola_Public_EX
Email Number: 779

Mail Envelope Properties (499C2FC6BB962446994CA8682D8ADF33188C2493BE)

Subject: Draft RAI No 132 SBPA 2721.doc
Sent Date: 7/14/2009 4:04:57 PM
Received Date: 7/14/2009 4:04:59 PM
From: Rycyna, John

Created By: John.Rycyna@nrc.gov

Recipients:

"CCNPP3COL Resource" <CCNPP3COL.Resource@nrc.gov>
Tracking Status: None
"Arora, Surinder" <Surinder.Arora@nrc.gov>
Tracking Status: None
"Curran, Gordon" <Gordon.Curran@nrc.gov>
Tracking Status: None
"Segala, John" <John.Segala@nrc.gov>
Tracking Status: None
"Hearn, Peter" <Peter.Hearn@nrc.gov>
Tracking Status: None
"Colaccino, Joseph" <Joseph.Colaccino@nrc.gov>
Tracking Status: None
"Biggins, James" <James.Biggins@nrc.gov>
Tracking Status: None
"Vrahoretis, Susan" <Susan.Vrahoretis@nrc.gov>
Tracking Status: None
"Simon, Marcia" <Marcia.Simon@nrc.gov>
Tracking Status: None
"Poche, Robert" <Robert.Poche@constellation.com>
Tracking Status: None
"katie.thurstin@unistarnuclear.com" <katie.thurstin@unistarnuclear.com>
Tracking Status: None
"McQueeney, Jennifer" <Jennifer.McQueeney@unistarnuclear.com>
Tracking Status: None
"michael.stevenson@unistarnuclear.com" <michael.stevenson@unistarnuclear.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	434	7/14/2009 4:04:59 PM
Draft RAI No 132 SBPA 2721.doc		28270

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 132

DRAFT

7/14/2009

Calvert Cliffs Unit 3

UniStar

Docket No. 52-016

SRP Section: 09.01.05 - Overhead Heavy Load Handling Systems

Application Section: 9.1.5

QUESTIONS for Balance of Plant Branch 1 (AP1000/EPR Projects) (SBPA)

09.01.05-1

Calvert Cliffs Nuclear Power Plant (CCNPP) Unit 3 FSAR Section 9.1.5.2.5 contains a "Procedures" paragraph that provides a commitment for the applicant to provide a site-specific procedure for overhead heavy load handling. The "Procedures" paragraph provides a detailed outline of information that will be included in the heavy load handling procedures. Section 9.1.5.2.5 also contains a requirement for procedure development prior to fuel load for heavy load lifts in the vicinity of irradiated fuel or safe shutdown equipment. Section C.I.9.1.5, "Overhead Heavy Load Handling System," of Regulatory Guide (RG) 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)," Regulatory Position C.III.1, "Information Needed for a Combined License Application Referencing a Certified Design" (page C.III.1-112) provides a list of criteria to be included in the heavy load handling program. One of the criteria listed in RG 1.206 states that the applicant is to provide a listing of all heavy loads and heavy load handling equipment outside the scope of loads described in the referenced certified design and the associated heavy load attributes (load weight and typical load paths). This section of RG 1.206 also requests a safety evaluation for heavy loads outside the scope of loads described in the referenced certified design that are handled by non-single-failure-proof handling systems. Provide the location of this content in the CCNPP Unit 3 FSAR or provide justification for excluding these RG 1.206 items.

09.01.05-2

CCNPP Unit 3 FSAR Section 9.1.5.2.5 contains a paragraph titled "Inspection and Testing" describing the inspection, test and maintenance in accordance with ASME B30.2, "Overhead and Gantry Cranes." This is consistent with Standard Review Plan (SRP) Section 9.1.5, "Overhead Heavy Load Handling Systems," guidance for cranes to be inspected, tested, and maintained prior to use, in accordance with Chapter 2-2 of ASME B30.2-2005.

However, Section 9.1.5.2.5 of the FSAR appears to have included an exception that indicates tests and inspections may be performed prior to use for infrequently used cranes. ASME B30.2 states that inspections shall be performed prior to use. Section 2-2.1.4 of ASME B30.2-2005 states:

2-2.1.4 Cranes Not in Regular Service

(a) A crane that is used in infrequent service, which has been idle for a period of 1 month or more, but less than 1 year, shall be inspected before

being placed in service in accordance with the requirements listed in para. 2-2.1.2.

(b) A crane that is used in infrequent service, which has been idle for a period of 1 year or more, shall be inspected before being placed in service in accordance with the requirements listed in para. 2-2.1.3.

Provide justification for this exception of not requiring inspections of infrequently used cranes prior to use.

09.01.05-3

In the CCNPP Unit 3 FSAR, there appears to be an inconsistency with the edition of ASME B30.2 that personnel involved in crane operation shall be qualified to.

- FSAR Section 13.5.1.1.5 refers to ANSI B30.2-1976.
- FSAR Section 9.1.5.2.5 refers to ASME B30.2-2005.

Resolve this inconsistency or provide the edition of code which is correct.