

PMNorthAnna3COLPEmails Resource

From: Barry Bryant [barry.bryant@dom.com]
Sent: Wednesday, July 08, 2009 2:57 PM
To: Berrios, Ilka
Cc: Regina Borsh; NorthAnna3COL Resource
Subject: RE: Questions re: Response to RAI 02.04.02-3

Hello Ilka,

I'm writing as a follow-up to the two questions we have regarding Dominion's response to RAI 02.04.02-3:

1. Will our preliminary proposal to increase the height of the dike approximately 6 inches resolve the reviewer's concerns? If necessary, we will schedule another conference call to answer any questions.
2. When will the new RAI be issued?

Thank you.

Barry

Barry C. Bryant, P.E.

*North Anna 3 Project
Dominion Resources Services, Inc.
5000 Dominion Boulevard
Glen Allen, VA 23060
804.273.3279
barry.bryant@dom.com*

From: Berrios, Ilka [mailto:Ilka.Berrios@nrc.gov]
Sent: Friday, June 26, 2009 3:21 PM
To: Barry Bryant (Generation - 6)
Cc: Regina Borsh (Generation - 6); NorthAnna3COL Resource
Subject: RE: Questions re: Response to RAI 02.04.02-3

I'll follow up with the reviewer, but he is out of the office until June 30th.

From: Barry Bryant (Generation - 6) [mailto:barry.bryant@dom.com]
Sent: Friday, June 26, 2009 3:12 PM
To: Berrios, Ilka
Cc: Regina Borsh (Generation - 6)
Subject: FW: Questions re: Response to RAI 02.04.02-3

Ilka,

I am writing as a follow-up to the June 23rd email below. We have a couple of questions:

3. Will our preliminary proposal to increase the height of the dike approximately 6 inches resolve the reviewer's concerns? If necessary, we will schedule another conference call to answer any questions.
4. When will the new RAI be issued?

Regards,

Barry

Barry C. Bryant, P.E.

North Anna 3 Project
Dominion Resources Services, Inc.
5000 Dominion Boulevard
Glen Allen, VA 23060
804.273.3279
barry.bryant@dom.com

From: Barry Bryant (Generation - 6)
Sent: Tuesday, June 23, 2009 3:44 PM
To: ilka.berrios@nrc.gov
Cc: Regina Borsh (Generation - 6); Joseph Hegner (Generation - 6); gquinn@bechtel.com
Subject: Questions re: Response to RAI 02.04.02-3

Ilka,

We have considered various means of addressing the Staff's concerns regarding the potential for North Anna Unit 3 stormwaters to flow over the top of the existing flood dike, as expressed in the June 22 conference call. While there are several options to resolve this concern, we have preliminarily determined that the margin can best be increased by raising the height of dike.

We are requesting that the NRC issue an RAI to document the Staff's concern and provide a way to document Dominion's resolution/response.

Regards,

Barry

Barry C. Bryant, P.E.
North Anna 3 Project
Dominion Resources Services, Inc.
5000 Dominion Boulevard
Glen Allen, VA 23060
804.273.3279
barry.bryant@dom.com

CONFIDENTIALITY NOTICE: This electronic message contains information which may be legally confidential and or privileged and does not in any case represent a firm ENERGY COMMODITY bid or offer relating thereto which binds the sender without an additional express written confirmation to that effect. The information is intended solely for the individual or entity named above and access by anyone else is unauthorized. If you are not the intended recipient, any disclosure, copying, distribution, or use of the contents of this information is prohibited and may be unlawful. If you have received this electronic transmission in error, please reply immediately to the sender that you have received the message in error, and delete it. Thank you.

CONFIDENTIALITY NOTICE: This electronic message contains information which may be legally confidential and or privileged and does not in any case represent a firm ENERGY COMMODITY bid or offer relating thereto which binds the sender without an additional express written confirmation to that effect. The information is intended solely for the individual or entity named above and access by anyone else is unauthorized. If you are not the intended recipient, any disclosure, copying, distribution, or use of the contents

of this information is prohibited and may be unlawful. If you have received this electronic transmission in error, please reply immediately to the sender that you have received the message in error, and delete it. Thank you.

Hearing Identifier: NorthAnna3_Public_EX
Email Number: 757

Mail Envelope Properties (8DB1AA266B41F7449D9A753E1D379BB305C4FEF5)

Subject: RE: Questions re: Response to RAI 02.04.02-3
Sent Date: 7/8/2009 2:56:58 PM
Received Date: 7/8/2009 2:57:23 PM
From: Barry Bryant

Created By: barry.bryant@dom.com

Recipients:

"Regina Borsh" <regina.borsh@dom.com>
Tracking Status: None
"NorthAnna3COL Resource" <NorthAnna3COL.Resource@nrc.gov>
Tracking Status: None
"Berrios, Ilka" <Ilka.Berrios@nrc.gov>
Tracking Status: None

Post Office: DOM-MBX05.mbu.ad.dominionnet.com

Files	Size	Date & Time
MESSAGE	4276	7/8/2009 2:57:23 PM

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: