

## BellBendCOLPEm Resource

---

**From:** Canova, Michael  
**Sent:** Monday, July 06, 2009 10:10 AM  
**To:** Sgarro, Rocco R; BBNPP@pplweb.com; jennifer.mcqueeney@unistarnuclear.com; Katie.Thurstin@unistarnuclear.com  
**Cc:** BellBendCOL Resource; Weisman, Robert; Miernicki, Michael; Som, Swagata; Jenkins, Ronaldo  
**Subject:** Bell Bend COLA - Draft Request for Information No. 35 (RAI No. 35)- EEB - 2766  
**Attachments:** Letter 35 - RAI 2766.doc

Attached is DRAFT RAI No. 35 for the Bell Bend COL Application. You have ten working days to review this request and to decide whether you need a conference call to discuss it. Please notify me of your decision in this regard.

After the call, or after ten days, the RAI will be finalized and sent to you. You will then have 30 days to respond. These durations are factored into your review schedule. If additional time is required to respond, please inform me of your proposed schedule to respond at your earliest opportunity.

If you have any questions, please contact me.

*Michael A. Canova*

Project Manager - Bell Bend COL Application

Docket 52-039

EPR Project Branch

Division of New Reactor Licensing

Office of New Reactors

301-415-0737

**Hearing Identifier:** BellBend\_COL\_Public  
**Email Number:** 108

**Mail Envelope Properties** (D9892A42664D3D4690E88C2F48D7C08E20E98C04C9)

**Subject:** Bell Bend COLA - Draft Request for Information No. 35 (RAI No. 35)- EEB - 2766  
**Sent Date:** 7/6/2009 10:10:01 AM  
**Received Date:** 7/6/2009 10:10:02 AM  
**From:** Canova, Michael

**Created By:** Michael.Canova@nrc.gov

**Recipients:**

"BellBendCOL Resource" <BellBendCOL.Resource@nrc.gov>  
Tracking Status: None  
"Weisman, Robert" <Robert.Weisman@nrc.gov>  
Tracking Status: None  
"Miernicki, Michael" <Michael.Miernicki@nrc.gov>  
Tracking Status: None  
"Som, Swagata" <Swagata.Som@nrc.gov>  
Tracking Status: None  
"Jenkins, Ronaldo" <Ronaldo.Jenkins@nrc.gov>  
Tracking Status: None  
"Sgarro, Rocco R" <rrsgarro@pplweb.com>  
Tracking Status: None  
"BBNPP@pplweb.com" <BBNPP@pplweb.com>  
Tracking Status: None  
"jennifer.mcqueeney@unistarnuclear.com" <jennifer.mcqueeney@unistarnuclear.com>  
Tracking Status: None  
"Katie.Thurstin@unistarnuclear.com" <Katie.Thurstin@unistarnuclear.com>  
Tracking Status: None

**Post Office:** HQCLSTR01.nrc.gov

| Files                    | Size | Date & Time          |
|--------------------------|------|----------------------|
| MESSAGE                  | 786  | 7/6/2009 10:10:02 AM |
| Letter 35 - RAI 2766.doc |      | 28154                |

**Options**

**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**

Request for Additional Information No. 35

DRAFT

7/6/2009

Bell Bend  
PPL Bell Bend LLC.  
Docket No. 52-039

SRP Section: 03.11 - Environmental Qualification of Mechanical and Electrical Equipment  
Application Section: 3.11

QUESTIONS for Electrical Engineering Branch (EEB)

03.11-2

Section 3.11 of FSAR Rev.1:

10 CFR 50.49(j) states that "A record of the qualification....must be maintained in an auditable form ..." Please describe how the records shall be maintained in an auditable form so that the documents are readily accessible for audit. Make appropriate changes to the FSAR regarding record retention under 10 CFR 50.49(j).

03.11-3

Section 3.11.1.1.3, Table 3.11-1:

Verify and correct the equipment Tag Numbers of the ESWEMS Pumphouse Class 1E 6.9 kV-480 V transformers and ESWEMS Class 1E Motor Control Centers. These are inconsistent with the Tag Numbers for the same equipment shown in Figure 8.3-1, EPSS Single Line Diagram.