

IPRenewal NPEmails

From: STROUD, MICHAEL D [MSTROUD@entergy.com]
Sent: Monday, June 22, 2009 12:22 PM
To: Green, Kimberly
Subject: FW: Confirmation needed

From: STROUD, MICHAEL D
Sent: Monday, June 22, 2009 9:17 AM
To: Green, Kimberly
Subject: RE: Confirmation needed

Kim,

The LRA Table 3.3.2-18-IP2 should be just like the LRA Table 3.3.2-18-IP3 for valve body with gray cast iron in air-indoor (int). The aging effect should be Loss of Material and the AMP should be External Surfaces Monitoring. The rest of the table is correct.

Thanks
Mike

From: Green, Kimberly [mailto:Kimberly.Green@nrc.gov]
Sent: Friday, June 19, 2009 10:10 AM
To: STROUD, MICHAEL D
Subject: Confirmation needed

Hi Mike,

Could you please confirm if the following two entries (from May 15, 2009) letter are accurate?

From LRA Table 3.3.2-18-IP2

Valve body	Pressure boundary	Gray cast iron	Air - indoor (int)	None	None	V.A-19 (E-29)	3.2.1-32
------------	-------------------	----------------	--------------------	------	------	---------------	----------

From LRA Table 3.3.2-18-IP3

Valve body	Pressure boundary	Gray cast iron	Air - indoor (int)	Loss of material	External Surfaces Monitoring	V.A-19 (E-29)	3.2.1-32
------------	-------------------	----------------	--------------------	------------------	------------------------------	---------------	----------

I would think that the two entries should be the same, but am not sure which one Entergy meant to use.

Also, don't forget to ask about the changes to LRA Section 2.3.3.12 for IP2 regarding the deletion of the CO2 references.

Thanks,
Kim

Hearing Identifier: IndianPointUnits2and3NonPublic_EX
Email Number: 1485

Mail Envelope Properties (A79A58994C541C48BBCFB319610763CB0578E905)

Subject: FW: Confirmation needed
Sent Date: 6/22/2009 12:21:43 PM
Received Date: 6/22/2009 12:22:02 PM
From: STROUD, MICHAEL D

Created By: MSTROUD@entergy.com

Recipients:
"Green, Kimberly" <Kimberly.Green@nrc.gov>
Tracking Status: None

Post Office: LITEXETSP002.etrsouth.corp.entergy.com

Files	Size	Date & Time
MESSAGE	1376	6/22/2009 12:22:02 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: