

INTENTIONALLY LEFT BLANK

Table F5.4-1. Ignition Source Population by Room (Continued)

Ignition Source Room Number	Electrical Equipment	Mechanical/ Electrical HVAC Equipment	Mechanical Process Equipment	Heat Generating Process Equipment	Torches, Welders, Burners	Internal Combustion Engines	Office/Kitchen Equipment	Portable and Special Equipment
2004 (Canister Transfer Room)			<b>CTM Maintenance Crane</b> 050-HTC0-CRN-00001 <ul style="list-style-type: none"> <li>• <b>2+1</b> motors @ 35, 2, &amp; 7.5 hp</li> </ul> <b>Canister Transfer Machine</b> 050-HTC0-FHM-00001 <ul style="list-style-type: none"> <li>• <b>5+1</b> motors @ 45, 3, 7.5, 7.5, <b>60</b>, &amp; 5 hp</li> </ul> <b>2 Port Slide Gates</b> 050-HTC0-HTCH-00001 050-HTC0-HTCH-00002 <ul style="list-style-type: none"> <li>• 2 motors each @ 0.5 hp each</li> </ul>		<b>Portable Welding Receptacle – WWF = 5 points</b>			Assume 4% of all such eq. • <b>2</b> points
2005A (Corridor)								
2005B (Corridor)								
2006 (Corridor)								
2007A (Corridor)								
2007B (Corridor)								
2008 (Crane Maint. Area)					<b>Portable Welding Receptacle – WWF = 5 points</b>			
2010 (HVAC Room S)		<b>2 Air Handling Units, 4 motors</b> 050-VN10-AHU-00001 050-VN10-AHU-00002 <ul style="list-style-type: none"> <li>• 60 hp (supply)</li> <li>• 25 hp (return)</li> </ul>						Assume 7.7% of all such eq. • <b>4</b> points
2011A (Backup Central Comm. Room)							Assume 10% of all such equipment • <b>2</b> points	
2011B (Backup Central Comm. Room)							Assume 10% of all such equipment • <b>2</b> points	
2012 (Operations Room)	<b>6 Control Consoles</b>						Assume 10% of all such equipment • <b>2</b> points	
2013 (Operations Supervisor Room)								

INTENTIONALLY LEFT BLANK

Table F5.4-1. Ignition Source Population by Room (Continued)

<b>Ignition Source Room Number</b>	<b>Electrical Equipment</b>	<b>Mechanical/ Electrical HVAC Equipment</b>	<b>Mechanical Process Equipment</b>	<b>Heat Generating Process Equipment</b>	<b>Torches, Welders, Burners</b>	<b>Internal Combustion Engines</b>	<b>Office/Kitchen Equipment</b>	<b>Portable and Special Equipment</b>
2024 (Stair #1)								
2025 (Stair #2)								
2026 (Stair #3)								
2027 (Stair #4)								
2029 (Elevator Lobby)								
2030 (Elevator Machine Room)								
2032 (Corridor)								
2033 (Elevator Lobby)								
2034 (Corridor)								
2201 (Briefing Room)							<b>Assume 5% of all such equipment</b> • <b>1 point</b>	
2202 (RP Staff Work Room)							<b>Assume 5% of all such equipment</b> • <b>1 point</b>	
2203 (Break/Vending Room)							<b>Assume 15% of all such equipment</b> • <b>3 points</b>	
2204 (Womens Restroom)								

INTENTIONALLY LEFT BLANK

Table F5.4-1. Ignition Source Population by Room (Continued)

Ignition Source Room Number	Electrical Equipment	Mechanical/ Electrical HVAC Equipment	Mechanical Process Equipment	Heat Generating Process Equipment	Torches, Welders, Burners	Internal Combustion Engines	Office/Kitchen Equipment	Portable and Special Equipment
2205 (Mens Restroom)								
2206 (Janitor Room)								

NOTE: <sup>1</sup>Residence weighting factor (RWF) is for equipment that can be in multiple rooms. Factor represents the percent of exposure (i.e., waste residence) time that the piece of equipment spends in the particular room. For the office/kitchen equipment and for the portable/process equipment, these were distributed across various locations of the building where such equipment is likely to be used. The results of the analysis are largely insensitive to this distribution. For the other types of major equipment used in the facility to move waste forms around, the residence fraction is based on the facility throughput analysis.

<sup>2</sup>Welding weighting factor (WWF) represents the relative number of total welding activity (hours/year) that occurs in each location where welding is performed. The number of hours for maintenance-related welding is based on about 8 hours/week in the primary maintenance welding location and 5 hours per year in each satellite welding location (for repairs that must be performed locally). Waste Package Closure Room welding is estimated based in the IHF throughput Gantt chart and the total number of waste packages expected to be handled, as follows: (1) the preclosure period is 50 years; (2) the welding machine actually operates for about 15 hours per TAD canister; (3) the WHF will produce 1165 TAD canisters;  $1165 \times 15 / 50 = 350$  hours per year. Note that for any given WP being processed, the total welding score is "at" the WP.

<sup>3</sup>Power ratings are for each motor unless otherwise noted.

<sup>4</sup>The blank cells in this table are intentional and have been verified. Information that would appear in the blank locations is not applicable for the room/location identified in the first column.

<sup>5</sup>Ignition sources are shown in bold red text. Motors not considered as ignition sources (<5 hp) are shown in grey text, and are not further considered in the fire ignition frequency analysis.

cabs = cabinet; Comm. = communications; CTM = canister transfer machine; DCIMS = digital control and management information system; Decon = decontamination; Dist. = distribution; DPC = dual-purpose canister; eq. = equipment; HEPA = high-efficiency particulate air; HVAC = heating, ventilation, and air conditioning; kVA = kilovolt amperes; LLW = low-level radioactive waste; Maint = maintenance; MCC = motor control center; MP = mechanical process; Plat. = platform; PLC = programmable logic controller; RP = radiation protection; TAD = transportation, aging, and disposal (canister); WP = waste package; hp = horsepower; UPS = uninterruptable power supply; V = volt; WWF = welding weighting factor; XFMR = transformer.

Source: Original

INTENTIONALLY LEFT BLANK

Table F5.5-1. Fire Ignition Frequencies by Room

Room	Ignition Source Category and Room-by-Room Population									Room Ignition Frequency
	Electrical	HVAC	Mechanical Equipment	Heat-Generating Equipment	Torches, Welders, Burners	Internal Combustion Engines	Office/Kitchen Equipment	Portable Equipment	No Equipment Involved	
B001									69	1.81E-03
B002				2					65	1.46E-02
B003									38	1.01E-03
B004									68	1.80E-03
B005									35	9.32E-04
B006									3	7.35E-05
B007									7	1.77E-04
B008									62	1.63E-03
B009									65	1.71E-03
P001 (incl. in 1016)									0	0.00E+00
1001			4	3		10	22		1630	9.66E-02
1002		22		2		5		4	186	6.76E-02
1003		1		4					30	2.14E-02
1004			4			5		4	216	5.23E-02
1005									9	2.43E-04
1006			6					4	160	5.66E-02
1007							61		182	2.38E-02
1008				0.03				2	133	1.53E-02
1009						5			228	1.00E-02
1010									38	9.93E-04
1011A									51	1.35E-03
1011B									137	3.63E-03
1012A									49	1.30E-03
1012B									100	2.65E-03
1013				1		5			315	1.88E-02
1014									18	4.85E-04
1015									6	1.54E-04
1016				36.97		365	78	8	4097	7.09E-01
1017		5							269	3.87E-02
1018			2			400			21	3.31E-01
1018A									14	3.82E-04
1018B									14	3.82E-04

Table F5.5-1. Fire Ignition Frequencies by Room (Continued)

Room	Ignition Source Category and Room-by-Room Population									Room Ignition Frequency
	Electrical	HVAC	Mechanical Equipment	Heat-Generating Equipment	Torches, Welders, Burners	Internal Combustion Engines	Office/Kitchen Equipment	Portable Equipment	No Equipment Involved	
1019	23	2			5			4	186	6.87E-02
1020	1	4							30	2.14E-02
1021		4						4	216	4.83E-02
1022									6	1.54E-04
1023		3	4			39			434	6.39E-02
1024									20	5.30E-04
1025									29	7.65E-04
1026									31	8.24E-04
1027									31	8.24E-04
1028				1					56	7.91E-03
1029									28	7.35E-04
1030									17	4.41E-04
1031									31	8.09E-04
1032									27	7.06E-04
1032A									22	5.88E-04
1033									32	8.53E-04
1034									29	7.65E-04
1035									17	4.41E-04
1036				1					17	6.88E-03
1037									7	1.91E-04
1038									7	6.61E-03
1039									7	1.72E-04
1042A				1					19	6.95E-03
1042B				1					19	6.95E-03
1042C				1					19	6.95E-03
1043A									30	7.97E-04
1043B									30	7.97E-04
1043C									30	7.97E-04
1044A									25	6.69E-04
1044B									25	6.69E-04
1044C									25	6.69E-04

Table F5.5-1. Fire Ignition Frequencies by Room (Continued)

Room	Ignition Source Category and Room-by-Room Population									Room Ignition Frequency	
	Electrical	HVAC	Mechanical Equipment	Heat-Generating Equipment	Torches, Welders, Burners	Internal Combustion Engines	Office/Kitchen Equipment	Portable Equipment	No Equipment Involved		
1045A									33	8.83E-04	
1045B									33	8.83E-04	
1045C			1						100	9.08E-03	
1045D									99	2.61E-03	
1046	92								158	1.12E-01	
1201									8	2.21E-04	
1202						1			21	1.00E-02	
1203									34	9.02E-04	
1204									40	1.06E-03	
1205							1		44	1.06E-02	
1206									12	3.14E-04	
1207									51	1.33E-03	
1208									9	2.35E-04	
1209							1		39	1.05E-02	
1210									1	22	1.01E-02
1211									12	9.80E-03	
1212									1	21	1.00E-02
1213										15	3.92E-04
1214										15	3.92E-04
1215								1		70	1.13E-02
1216									1	25	1.01E-02
1217									1	25	1.01E-02
1218A										60	1.59E-03
1218B										30	7.80E-04
1218C										58	1.53E-03
M001		3							4	474	5.03E-02
2001	66								4	140	1.04E-01
2001A	1	4								46	2.18E-02
2002		2							4	216	3.86E-02
2003		1							4	134	3.16E-02
2004				7		5			2	1017	8.75E-02

Table F5.5-1. Fire Ignition Frequencies by Room (Continued)

Room	Ignition Source Category and Room-by-Room Population									Room Ignition Frequency
	Electrical	HVAC	Mechanical Equipment	Heat-Generating Equipment	Torches, Welders, Burners	Internal Combustion Engines	Office/Kitchen Equipment	Portable Equipment	No Equipment Involved	
2005A									142	3.76E-03
2005B									90	2.38E-03
2006									136	3.58E-03
2007A									52	1.37E-03
2007B									197	5.20E-03
2008						5			522	1.78E-02
2010		4						4	216	4.83E-02
2011A							2		95	2.15E-02
2011B							2		120	2.21E-02
2012	6						2		241	3.23E-02
2013									14	3.82E-04
2024									18	4.85E-04
2025									45	1.19E-03
2026									31	8.24E-04
2027									31	8.24E-04
2029									17	4.41E-04
2030									14	3.68E-04
2032									9	2.50E-04
2033									12	3.09E-04
2034									29	7.65E-04
2201							1		19	9.99E-03
2202							1		30	1.03E-02
2203							3		52	2.98E-02
2204									12	3.09E-04
2205									13	3.43E-04
2206									8	2.06E-04
TOTAL	217	49	64	0	810	200	20	52		2.51E+00

NOTE: The blank cells in this table are intentional and have been verified. Information that would appear in the blank locations is not applicable for the room identified in the first column.

HVAC = heating, ventilation, and air conditioning.

Source: Original

Table F5.6-1. Fire Propagation Probabilities

	Conditional Probability		Sampled Value	Mean Fraction	97.5% Value	97.5th percentile add
<b>Alternative Definition</b>						
No Propagation	0.551		0.551	0.551	0.667	0.117
Spreads Through Part of Room of Origin	0.317		0.317	0.317	0.426	0.109
Spreads Throughout Room of Origin	0.028		0.028	0.028	0.066	0.038
Spreads Throughout Fire-Rated Area of Origin	0.005		0.005	0.005	0.020	0.016
Spreads Throughout Floor of Origin	0.069		0.069	0.069	0.128	0.059
Spreads Throughout Building	0.028		0.028	0.028	0.055	0.028
Breaches Building Boundary	0.005		0.005	0.005	0.020	0.016
	1.000		1.000			
<b>Alternative Definition</b>						
No Propagation	0.621		0.621	0.621	0.725	0.104
Spreads Through Part of Room of Origin	0.149		0.149	0.149	0.226	0.076
Spreads Throughout Room of Origin	0.004		0.004	0.004	0.017	0.013
Spreads Throughout Fire-Rated Area of Origin	0.057		0.057	0.057	0.107	0.050
Spreads Throughout Floor of Origin	0.004		0.004	0.004	0.017	0.013
Spreads Throughout Building	0.161		0.161	0.161	0.240	0.079
Breaches Building Boundary	0.004		0.004	0.004	0.017	0.013
	1.000		1.000			

Source: Original

INTENTIONALLY LEFT BLANK

Table F5.7-1. TAD canister, DPC, and SNF Residence Fractions

WHF Residence Times and Fractions											
Section I - Localized Fires											
BFD Task	Steps (if needed)	Time (m)	Fraction	BFD Task	Steps (if needed)	Time (m)	Fraction	BFD Task	Steps (if needed)	Time (m)	Fraction
<b>TC/SNF on Truck Trailer in Receipt Area w/Tractor (Diesel Present)</b>				<b>TC/DPC (TTC) on Railcar/Trailer in Receipt Area w/Tractor/SPM (Diesel Present)</b>				<b>TC/DPC on Truck Trailer in Receipt Area w/Tractor (Diesel Present)</b>			
1.1.1		44		1.1.1		44		1.1.1	Steps 1-4	44	
<b>Total</b>		<b>44</b>	<b>1.7E-06</b>	<b>Total</b>		<b>44</b>	<b>1.7E-06</b>	<b>Total</b>		<b>44</b>	<b>1.7E-06</b>
<b>TC/SNF on Truck Trailer in Receipt Area w/o Tractor (No Diesel)</b>				<b>TC/DPC (TTC) on Railcar/Trailer in Receipt Area w/o Tractor/SPM (No Diesel)</b>				<b>TC/DPC on Truck Trailer in Receipt Area w/o Tractor (No Diesel)</b>			
1.1.2		15		1.1.2		15		1.1.1	Step 5	75	
1.1.10		160		Not in BFD		170		1.1.2		15	
Not in BFD	Prepare CHC	15		1.1.3		90		1.1.10		206	
1.1.11		60		1.1.4	Prepare CHC	80		Not in BFD	Prepare CHC	15	
1.1.12		15		1.1.5		220		1.1.11		60	
1.1.13	Step 1	5		1.1.6		95		1.1.12		30	
<b>Total</b>		<b>270</b>	<b>1.0E-05</b>	1.1.7		40		1.1.24		20	
				Not in BFD	Prepare CHC	25		1.1.26	Step 1	5	
				1.1.8		15		<b>Total</b>		<b>426</b>	<b>1.6E-05</b>
				1.1.9		40					
				1.1.24		20					
				1.1.26	Step 1	5					
				<b>Total</b>		<b>815</b>	<b>3.1E-05</b>				
<b>TC/SNF in Preparation Station (Dry Cavity)</b>				<b>TC/DPC (TTC) on CTT in Preparation Station</b>				<b>TC/DPC on CTT in Preparation Station</b>			
1.1.13	Steps 2-4	50		1.1.26	Steps 2-4	35		(Same as TTC)			
Not in BFD	Remove/Store Platform	15		1.1.27		200					
1.1.15	Steps 1-8	38		1.1.28		202					
<b>Total</b>		<b>103</b>	<b>3.9E-06</b>	1.1.29		30					
				1.1.30		20					
<b>TC/SNF in Preparation Station (Wet Cavity)</b>				1.1.31		40					
1.1.15	Steps 9-13	46		1.1.32		40					
1.1.16		36		1.1.33		40					
1.1.17		45		1.1.34		20					
Not in BFD	Prepare CHC	20		<b>Total</b>		<b>627</b>	<b>2.4E-05</b>				
1.1.18	Steps 1-6	55									
<b>Total</b>		<b>38</b>	<b>202</b>	<b>7.7E-06</b>							

INTENTIONALLY LEFT BLANK

Table F5.7-1. TAD canister, DPC, and SNF  
Residence Fractions  
(Continued)

BFD Task	Steps (if needed)	Time (m)	Fraction	BFD Task	Steps (if needed)	Time (m)	Fraction	BFD Task	Steps (if needed)	Time (m)	Fraction
<b>TC/DPC (TTC) on CTT in Unloading Room</b>											
	1.1.34	again				20			<b>TC/DPC on CTT in Unloading Room</b>		
	5.2.11					5			(Same as TTC)		
	5.2.12					2					
	5.2.13					25					
	<b>Total</b>					<b>52</b>	<b>2.0E-06</b>				
<b>DPC (TTC) in CTM in Transfer Room</b>											
	5.2.13	Step 3 (again)				10			<b>DPC in CTM in Transfer Room</b>		
	5.2.14					2			(Same as TTC)		
	5.2.15					5					
	5.2.27					5					
	5.2.28					2					
	5.2.29	Step 1				5					
	<b>Total</b>					<b>29</b>	<b>1.1E-06</b>				
<b>STC/DPC (TTC) on CTT in Unloading Room</b>											
	5.2.29	again				35			<b>STC/DPC on CTT in Unloading Room</b>		
	5.2.30					2			(Same as TTC)		
	5.2.31					75					
	5.2.32					20					
	<b>Total</b>					<b>132</b>	<b>5.0E-06</b>				
<b>STC/DPC (TTC) on CTT in Preparation Station</b>											
	5.2.32	Again				20			<b>STC/DPC on CTT in Preparation Station</b>		
	5.2.33					35			(Same as TTC)		
	5.2.34					40					
	5.2.35					69					
	5.2.36					40					
	5.2.37					75					
	5.2.38					270					
	5.2.39					220					
	5.2.40	Steps 1-6				35					
	<b>Total</b>					<b>804</b>	<b>3.1E-05</b>				
<b>STC/DPC (TTC) in DPC Cutting Station (Dry Cavity, Dry Annulus)</b>											
	5.2.40	Steps 7-12				55			<b>STC/DPC in DPC Cutting Station (Dry Cavity, Dry Annulus)</b>		
	3.1.1					105			(Same as TTC)		
	<b>Total</b>					<b>160</b>	<b>6.1E-06</b>				

INTENTIONALLY LEFT BLANK

Table F5.7-1. TAD canister, DPC, and SNF  
Residence Fractions  
(Continued)

BFD Task	Steps (if needed)	Time (m)	Fraction	BFD Task	Steps (if needed)	Time (m)	Fraction	BFD Task	Steps (if needed)	Time (m)	Fraction
<b>STC/DPC (TTC) in DPC Cutting Station (Dry Cavity, Wet Annulus)</b>											
	3.1.2					5					
	3.1.3					12					
	3.1.4					65					
	3.1.5					40					
	3.1.6					30					
	3.1.7					10					
	3.1.8					75					
	3.1.9					250					
	3.1.10					160					
	3.1.11					10					
	3.1.12					30					
	3.1.13					250					
	3.1.14					55					
	3.1.15					60					
	3.1.16					40					
	<b>Total</b>					<b>1092</b>	<b>4.2E-05</b>				
<b>STC/DPC (TTC) in DPC Cutting Station (Wet Cavity, Wet Annulus)</b>											
	3.1.17					5					
	3.1.21					480					
	3.1.22					30					
	3.1.23					15					
	3.1.24					10					
	3.1.25					30					
	3.1.26					25					
	3.1.27					15					
	3.1.28					40					
	3.1.29					55					
	3.1.30					101					
	3.1.31					5					
	Not in BFD	Prepare CHC				20					
	3.1.32	Steps 1-6				55					
	<b>Total</b>					<b>886</b>	<b>3.4E-05</b>				

INTENTIONALLY LEFT BLANK

Table F5.7-1. TAD canister, DPC, and SNF  
Residence Fractions  
(Continued)

BFD Task	Steps (if needed)	Time (m)	Fraction	BFD Task	Steps (if needed)	Time (m)	Fraction	BFD Task	Steps (if needed)	Time (m)	Fraction
STC/TAD in TAD Closure Station (Wet Cavity)				STC/TAD in TAD Closure Station (Wet Cavity)				STC/TAD in TAD Closure Station (Wet Cavity)			
4.1.8	Step 4		15	(Same)				(Same)			
4.1.9			30								
4.1.10			20								
Not in BFD	Clean up CHC		25								
Not in BFD	PPE/Temp Shielding		90								
4.1.11			34								
4.1.12			12								
4.1.13			35								
4.1.14			35								
4.1.15			32								
4.1.16			15								
4.1.17			50								
4.1.18			440								
Not in BFD	Inspect weld		200								
4.1.19			34								
<b>Total</b>		<b>1067</b>	<b>4.1E-05</b>								
STC/TAD in TAD Closure Station (Dry Cavity, Wet Annulus)				STC/TAD in TAD Closure Station (Dry Cavity, Wet Annulus)				STC/TAD in TAD Closure Station (Dry Cavity, Wet Annulus)			
4.1.20			325	(Same)				(Same)			
4.1.21			200								
Not in BFD	Inspect weld		140								
4.1.22			35								
4.1.23			45								
4.1.24			65								
4.1.25			440								
Not in BFD	Inspect weld		200								
4.1.26			35								
4.1.27			35								
4.1.28			40								
4.1.29			240								
4.1.30			6								
4.1.31			38								
<b>Total</b>		<b>1844</b>	<b>7.0E-05</b>								
STC/TAD in TAD Closure Station (Dry Cavity, Dry Annulus)				STC/TAD in TAD Closure Station (Dry Cavity, Dry Annulus)				STC/TAD in TAD Closure Station (Dry Cavity, Dry Annulus)			
4.1.32			110	(Same)				(Same)			
Not in BFD	Close STC Drain Port		11								
1.5.6	Prepare CHC		45								
1.5.7			200								
1.5.8			12								
1.5.9			32								
<b>Total</b>		<b>410</b>	<b>1.6E-05</b>								

INTENTIONALLY LEFT BLANK

Table F5.7-1. TAD canister, DPC, and SNF  
Residence Fractions  
(Continued)

BFD Task	Steps (if needed)	Time (m)	Fraction		BFD Task	Steps (if needed)	Time (m)	Fraction		BFD Task	Steps (if needed)	Time (m)	Fraction
<b>STC/TAD on CTT in Unloading Room</b>													
1.5.9	Steps 2-4 (again)	20											
5.1.1		30											
5.1.2		5											
5.1.3		30											
5.1.4		2											
5.1.5		25											
<b>Total</b>		<b>112</b>	<b>4.3E-06</b>										
<b>TAD in CTM in Transfer Room</b>													
5.1.5	Step 3 (again)	10											
5.1.6		2											
5.1.7		5											
5.1.8		2											
5.1.9	Step 1	5											
<b>Total</b>		<b>24</b>	<b>9.1E-07</b>										
<b>TAD in AO in Loading Room</b>													
5.1.9	Again	35											
5.1.10		2											
1.6.1		45											
1.6.2		14											
<b>Total</b>		<b>96</b>	<b>3.7E-06</b>										
<b>TAD in AO in Bolting Room</b>													
1.6.2	Again	14											
1.6.3		240											
<b>Total</b>		<b>254</b>	<b>9.7E-06</b>										
<b>Section II - Large Fire</b>													
<b>TC/SNF or TC/DPC (incl. TTC) w/Tractor/SPM (Diesel Present)</b>													
1.1.1		44											
<b>Total</b>		<b>44</b>	<b>1.7E-06</b>										

INTENTIONALLY LEFT BLANK

Table F5.7-1. TAD canister, DPC, and SNF  
Residence Fractions  
(Continued)

BFD Task	Steps (if needed)	Time (m)	Fraction		BFD Task	Steps (if needed)	Time (m)	Fraction		BFD Task	Steps (if needed)	Time (m)	Fraction
<b>TC/SNF (No Diesel)</b>													
1.1.2		15			1.1.2		15			1.1.1	Step 5	75	
1.1.10		160			Not in BFD		170			1.1.2		15	
Not in BFD	Prepare CHC	15			1.1.3		90			1.1.10		206	
1.1.11		60			1.1.4	Prepare CHC	80			Not in BFD	Prepare CHC	15	
1.1.12		15			1.1.5		220			1.1.11		60	
1.1.13		55			1.1.6		95			1.1.12		30	
Not in BFD	Remove/Store Platform	15			1.1.7		40			1.1.24		20	
1.1.15	Steps 1-8	38			Not in BFD	Prepare CHC	25			1.1.26		40	
<b>Total</b>		<b>373</b>	<b>1.4E-05</b>		1.1.8		15			1.1.27		200	
					1.1.9		40			1.1.28		202	
					1.1.24		20			1.1.29		30	
					1.1.26		40			1.1.30		20	
					1.1.27		200			1.1.31		40	
					1.1.28		202			1.1.32		20	
					1.1.29		30			1.1.26		5	
					1.1.30		20			1.1.32	again	20	
					1.1.31		40			5.2.11		5	
					1.1.32		40			5.2.12		2	
					1.1.33		40			5.2.13		25	
					1.1.34		20			<b>Total</b>		<b>1030</b>	<b>3.9E-05</b>
					5.2.11		5						
					5.2.12		2						
					5.2.13		25						
					<b>Total</b>		<b>1474</b>	<b>5.6E-05</b>					
<b>DPC (incl TTC) in CTM</b>													
					5.2.13	Step 3 (again)	10						
					5.2.14		2						
					5.2.15		5						
					5.2.27		5						
					5.2.28		2						
					5.2.29	Step 1	5						
					<b>Total</b>		<b>29</b>	<b>1.1E-06</b>					

INTENTIONALLY LEFT BLANK

Table F5.7-1. TAD canister, DPC, and SNF Residence Fractions (Continued)

BFD Task	Steps (if needed)	Time (m)	Fraction	BFD Task	Steps (if needed)	Time (m)	Fraction
<b>STC/DPC (incl TTC)</b>							
5.2.29	again					35	
5.2.30						2	
5.2.31						75	
5.2.32						20	
5.2.33						35	
5.2.34						40	
5.2.35						69	
5.2.36						40	
5.2.37						75	
5.2.38						270	
5.2.39						220	
5.2.40						90	
3.1.1						105	
	<b>Total</b>					<b>1076</b>	<b>4.1E-05</b>
<b>STC/DPC (incl TTC) (Dry Cavity, Wet Annulus)</b>							
3.1.2						5	
3.1.3						12	
3.1.4						65	
3.1.5						40	
3.1.6						30	
3.1.7						10	
3.1.8						75	
3.1.9						250	
3.1.10						160	
3.1.11						10	
3.1.12						30	
3.1.13						250	
3.1.14						55	
3.1.15						60	
3.1.16						40	
	<b>Total</b>					<b>1092</b>	<b>4.2E-05</b>

Table F5.7-1. TAD canister, DPC, and SNF Residence Fractions (Continued)

BFD Task	Steps (if needed)	Time (m)	Fraction	BFD Task	Steps (if needed)	Time (m)	Fraction
<b>STC/DPC (incl TTC) (Wet Cavity, Wet Annulus)</b>							
	3.1.17					5	
	3.1.21					480	
	3.1.22					30	
	3.1.23					15	
	3.1.24					10	
	3.1.25					30	
	3.1.26					25	
	3.1.27					15	
	3.1.28					40	
	3.1.29					55	
	3.1.30					101	
	3.1.31					5	
	Not in BFD			Prepare CHC		20	
				3.1.32		55	
				<b>Total</b>		<b>886</b>	<b>3.4E-05</b>
<b>TC/SNF (Wet Cavity)</b>							
1.1.15	Steps 9-13		46				
1.1.16			36				
1.1.17			45				
Not in BFD	Prepare CHC		20				
1.1.18	Steps 1-6		55				
<b>Total</b>		<b>202</b>	<b>7.7E-06</b>				

Table F5.7-1. TAD canister, DPC, and SNF Residence Fractions (Continued)

BFD Task	Steps (if needed)	Time (m)	Fraction		BFD Task	Steps (if needed)	Time (m)
<b>STC/TAD (Wet Cavity)</b>							
4.1.8	Step 4	15			TC/DPC (incl TTC) same as TC/SNF from here down)		
4.1.9		30					
4.1.10		20					
Not in BFD	Clean up CHC	25					
Not in BFD	PPE/Temp Shielding	90					
4.1.11		34					
4.1.12		12					
4.1.13		35					
4.1.14		35					
4.1.15		32					
4.1.16		15					
4.1.17		50					
4.1.18		440					
Not in BFD	Inspect weld	200					
4.1.19		34					
<b>Total</b>		<b>1067</b>	<b>4.1E-05</b>				
<b>STC/TAD (Dry Cavity, Wet Annulus)</b>							
4.1.20		325					
4.1.21		200					
Not in BFD	Inspect weld	140					
4.1.22		35					
4.1.23		45					
4.1.24		65					
4.1.25		440					
Not in BFD	Inspect weld	200					
4.1.26		35					
4.1.27		35					
4.1.28		40					
4.1.29		240					
4.1.30		6					
4.1.31		38					
<b>Total</b>		<b>1844</b>	<b>7.0E-05</b>				

Table F5.7-1. TAD canister, DPC, and SNF Residence Fractions (Continued)

BFD Task	Steps (if needed)	Time (m)	Fraction
<b>STC/TAD (Dry Cavity, Dry Annulus)</b>			
4.1.32		110	
Not in BFD	Close STC Drain Port	11	
1.5.6	Prepare CHC	45	
1.5.7		200	
1.5.8		12	
1.5.9		32	
5.1.1		30	
5.1.2		5	
5.1.3		30	
5.1.4		2	
5.1.5	Steps 1-2	15	
<b>Total</b>		<b>492</b>	<b>1.9E-05</b>
<b>TAD in CTM</b>			
5.1.5	Step 3	10	
5.1.6		2	
5.1.7		5	
5.1.8		2	
5.1.9	Step 1	5	
<b>Total</b>		<b>24</b>	<b>9.1E-07</b>
<b>TAD in AO</b>			
5.1.9	Steps 2+	30	
5.1.10		2	
1.6.1		45	
1.6.2		14	
1.6.3		240	
<b>Total</b>		<b>331</b>	<b>1.3E-05</b>

NOTE: The blank cells in this table are intentional and have been verified.

AO = aging overpack; BFD = block flow diagram; CHC = cask handling crane; CTM = canister transfer machine; CTT = cask transfer trolley; DPC = dual-purpose canister; PPE = personnel protective equipment; SNF = spent nuclear fuel; SPM = site prime mover; STC = shielded transfer cask; TAD = transportation, aging, and disposal canister; TC = transportation cask; TTC = a transportation cask that is upended using a tilt frame.

Source: Original

Table F5.7-2. Localized Fire Initiating Event Frequencies

Localized Fire Threatens Waste Form												
Contributions from Rooms Containing Waste Form												
Room of Origin (includes comments field as needed)	Ignition Source (If Applicable)	Number in Room	Frequency per Unit (50 years)	Number at Target	Number Near Target	Propagation Probability to Target	Number Away from Target	Propagation Probability to Target	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)
Entry represents a vulnerability due to the Railcar/Truck (Diesel Present)												
1001	Electrical	0	1.17E-03			0.211		0.061	1.7E-06	0.0E+00		
1016	HVAC	4	4.85E-03	4		0.211		0.061	1.7E-06	3.2E-08		
B001	Mechanical Equipment	39.97	6.44E-03	9	11.97	0.211	19	0.061	1.7E-06	1.4E-07		
B007	Heat Generating Equipment	0	0.00E+00			0.211		0.061	1.7E-06	0.0E+00		
B009	Torches, welders, burners	375	8.01E-04			0.211	375	0.061	1.7E-06	3.1E-08		
	Internal combustion engines	100	3.11E-04	100		0.211		0.061	1.7E-06	5.2E-08		
	Office/kitchen equipment	0	9.48E-03			0.211		0.061	1.7E-06	0.0E+00		
	Portable Equipment	8	5.81E-03	1	2	0.211	5	0.061	1.7E-06	1.7E-08		
	No equipment involved	5866	2.64E-05	2808	120	0.211	2938	0.061	1.7E-06	1.3E-07		
Propagation from rooms in Fire Zone FA-00-01												
1022			1.54E-04			0.057			1.7E-06	1.5E-11		
B002			1.46E-02			0.057			1.7E-06	1.4E-09		
B003			1.01E-03			0.057			1.7E-06	9.8E-11		
B004			1.80E-03			0.057			1.7E-06	1.7E-10		
B006			7.35E-05			0.057			1.7E-06	7.1E-12		
B008			1.63E-03			0.057			1.7E-06	1.6E-10		
P001			0.00E+00			0.057			1.7E-06	0.0E+00		
Localized Fire Threatens TC/SNF or TC/DPC (incl. TTC) on Railcar/Trailer in Receipt Area w/Tractor (Diesel Present)												
										4.0E-07		

INTENTIONALLY LEFT BLANK

Table F5.7-2. Localized Fire Initiating Event Frequencies (Continued)

Room of Origin (includes comments field as needed)	Ignition Source (If Applicable)	Number in Room	Frequency per Unit (50 years)	Number at Target	Number Near Target	Propagation Probability to Target	Number Away from Target	Propagation Probability to Target	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)				
TC/SNF															TC/DPC (TTC)		TC/DPC	
<b>Entry represents a vulnerability due to the Railcar/Truck (Diesel Present)</b>																		
1001	Electrical	0	1.17E-03			0.211			0.061	1.0E-05	0.0E+00	3.1E-05	0.0E+00	1.6E-05	0.0E+00			
1016	HVAC	4	4.85E-03	4		0.211			0.061	1.0E-05	2.0E-07	3.1E-05	6.0E-07	1.6E-05	3.1E-07			
B001	Mechanical Equipment	39.97	6.44E-03	9	11.97	0.211	19	0.061	1.0E-05	8.4E-07	3.1E-05	2.5E-06	1.6E-05	1.3E-06				
B007	Heat Generating Equipment	0	0.00E+00			0.211			0.061	1.0E-05	0.0E+00	3.1E-05	0.0E+00	1.6E-05	0.0E+00			
B009	Torches, welders, burners	375	8.01E-04			0.211	375	0.061	1.0E-05	1.9E-07	3.1E-05	5.7E-07	1.6E-05	3.0E-07				
	Internal combustion engines	100	3.11E-04			0.211	100	0.061	1.0E-05	2.0E-08	3.1E-05	5.9E-08	1.6E-05	3.1E-08				
	Office/kitchen equipment	0	9.48E-03			0.211		0.061	1.0E-05	0.0E+00	3.1E-05	0.0E+00	1.6E-05	0.0E+00				
	Portable Equipment	8	5.81E-03	1	2	0.211	5	0.061	1.0E-05	1.0E-07	3.1E-05	3.1E-07	1.6E-05	1.6E-07				
	No equipment involved	5866	2.64E-05	2808	120	0.211	2938	0.061	1.0E-05	8.2E-07	3.1E-05	2.5E-06	1.6E-05	1.3E-06				
<b>Propagation from rooms in Fire Zone FA-00-01</b>																		
1022			1.54E-04			0.057			1.0E-05	9.1E-11	3.1E-05	2.8E-10	1.6E-05	1.4E-10				
B002			1.46E-02			0.057			1.0E-05	8.6E-09	3.1E-05	2.6E-08	1.6E-05	1.4E-08				
B003			1.01E-03			0.057			1.0E-05	6.0E-10	3.1E-05	1.8E-09	1.6E-05	9.5E-10				
B004			1.80E-03			0.057			1.0E-05	1.1E-09	3.1E-05	3.2E-09	1.6E-05	1.7E-09				
B006			7.35E-05			0.057			1.0E-05	4.3E-11	3.1E-05	1.3E-10	1.6E-05	6.9E-11				
B008			1.63E-03			0.057			1.0E-05	9.6E-10	3.1E-05	2.9E-09	1.6E-05	1.5E-09				
P001			0.00E+00			0.057			1.0E-05	0.0E+00	3.1E-05	0.0E+00	1.6E-05	0.0E+00				
<b>Localized Fire Threatens Waste Form on Railcar/Trailer in Receipt Area w/o Tractor/SPM (No Diesel Present)</b>																		
	<b>Localized Fire Threatens TC/SNF on Truck Trailer in Receipt Area w/o Tractor (No Diesel Present)</b>															<b>2.2E-06</b>		
	<b>Localized Fire Threatens TC/DPC (TTC) on Railcar/Trailer in Receipt Area w/o Tractor/SPM (No Diesel Present)</b>															<b>6.6E-06</b>		
	<b>Localized Fire Threatens TC/DPC on Truck Trailer in Receipt Area w/o Tractor (No Diesel Present)</b>															<b>3.4E-06</b>		
<b>Entry represents a vulnerability due to the Preparation Station</b>																		
1016	Electrical	0	1.17E-03			0.211			0.061	3.9E-06	0.0E+00	7.7E-06	0.0E+00					
B001	HVAC	0	4.85E-03			0.211			0.061	3.9E-06	0.0E+00	7.7E-06	0.0E+00					
B007	Mechanical Equipment	36.97	6.44E-03	13	9	0.211	14.97	0.061	3.9E-06	4.0E-07	7.7E-06	7.8E-07						
B009	Heat Generating Equipment	0	0.00E+00			0.211			0.061	3.9E-06	0.0E+00	7.7E-06	0.0E+00					
	Torches, welders, burners	365	8.01E-04	365		0.211		0.061	3.9E-06	1.1E-06	7.7E-06	2.2E-06						
	Internal combustion engines	78	3.11E-04			0.211	78	0.061	3.9E-06	5.8E-09	7.7E-06	1.1E-08						
	Office/kitchen equipment	0	9.48E-03			0.211		0.061	3.9E-06	0.0E+00	7.7E-06	0.0E+00						
	Portable Equipment	8	5.81E-03		3	0.211	5	0.061	3.9E-06	2.1E-08	7.7E-06	4.2E-08						
	No equipment involved	4237	2.64E-05	30	120	0.211	4087	0.061	3.9E-06	3.2E-08	7.7E-06	6.2E-08						
<b>Propagation from rooms in Fire Zone FA-00-01</b>																		
1001			9.66E-02			0.057			3.9E-06	2.2E-08	7.7E-06	4.3E-08						
1022			1.54E-04			0.057			3.9E-06	3.5E-11	7.7E-06	6.8E-11						
B002			1.46E-02			0.057			3.9E-06	3.3E-09	7.7E-06	6.4E-09						
B003			1.01E-03			0.057			3.9E-06	2.3E-10	7.7E-06	4.5E-10						
B004			1.80E-03			0.057			3.9E-06	4.1E-10	7.7E-06	8.0E-10						
B006			7.35E-05			0.057			3.9E-06	1.7E-11	7.7E-06	3.2E-11						
B008			1.63E-03			0.057			3.9E-06	3.7E-10	7.7E-06	7.2E-10						
P001			0.00E+00			0.057			3.9E-06	0.0E+00	7.7E-06	0.0E+00						
<b>Localized Fire Threatens TC/SNF in the Preparation Area</b>																		
	<b>Localized Fire Threatens TC/SNF (Dry Cavity) in the Preparation Station in the Preparation Area</b>															<b>1.6E-06</b>		
	<b>Localized Fire Threatens TC/SNF (Wet Cavity) in the Preparation Station in the Preparation Area</b>															<b>3.2E-06</b>		

INTENTIONALLY LEFT BLANK

Table F5.7-2. Localized Fire Initiating Event Frequencies (Continued)

Room of Origin (includes comments field as needed)	Ignition Source (If Applicable)	Number in Room	Frequency per Unit (50 years)	Number at Target	Number Near Target	Propagation Probability to Target	Number Away from Target	Propagation Probability to Target	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)
Entry represents a vulnerability due to the CTT and Preparation Station														
1016	Electrical	0	1.17E-03			0.211		0.061	2.4E-05	0.0E+00	3.1E-05	0.0E+00		
B001	HVAC	0	4.85E-03			0.211		0.061	2.4E-05	0.0E+00	3.1E-05	0.0E+00		
B007	Mechanical Equipment	36.97	6.44E-03	13.97	9	0.211	14	0.061	2.4E-05	2.6E-06	3.1E-05	3.3E-06		
B009	Heat Generating Equipment	0	0.00E+00			0.211		0.061	2.4E-05	0.0E+00	3.1E-05	0.0E+00		
	Torches, welders, burners	365	8.01E-04			0.211	365	0.061	2.4E-05	4.3E-07	3.1E-05	5.5E-07		
	Internal combustion engines	78	3.11E-04			0.211	78	0.061	2.4E-05	3.5E-08	3.1E-05	4.5E-08		
	Office/kitchen equipment	0	9.48E-03			0.211		0.061	2.4E-05	0.0E+00	3.1E-05	0.0E+00		
	Portable Equipment	8	5.81E-03		3	0.211	5	0.061	2.4E-05	1.3E-07	3.1E-05	1.7E-07		
	No equipment involved	4237	2.64E-05	30	120	0.211	4087	0.061	2.4E-05	1.9E-07	3.1E-05	2.5E-07		
Propagation from rooms in Fire Zone FA-00-01														
1001			9.66E-02			0.057			2.4E-05	1.3E-07	3.1E-05	1.7E-07		
1022			1.54E-04			0.057			2.4E-05	2.1E-10	3.1E-05	2.7E-10		
B002			1.46E-02			0.057			2.4E-05	2.0E-08	3.1E-05	2.6E-08		
B003			1.01E-03			0.057			2.4E-05	1.4E-09	3.1E-05	1.8E-09		
B004			1.80E-03			0.057			2.4E-05	2.5E-09	3.1E-05	3.2E-09		
B006			7.35E-05			0.057			2.4E-05	1.0E-10	3.1E-05	1.3E-10		
B008			1.63E-03			0.057			2.4E-05	2.2E-09	3.1E-05	2.9E-09		
P001			0.00E+00			0.057			2.4E-05	0.0E+00	3.1E-05	0.0E+00		
Localized Fire Threatens TC/DPC or STC/DPC on CTT in the Preparation Station														
Localized Fire Threatens TC/DPC (all) on CTT in the Preparation Station in the Preparation Area										3.5E-06				
Localized Fire Threatens STC/DPC (all) on CTT in the Preparation Station in the Preparation Area										4.5E-06				
Entry represents a vulnerability due to the Cask Transfer Trolley														
1008	Electrical	0	1.17E-03			0.211		0.061	2.0E-06	0.0E+00	5.0E-06	0.0E+00	4.3E-06	0.0E+00
2004	HVAC	0	4.85E-03			0.211		0.061	2.0E-06	0.0E+00	5.0E-06	0.0E+00	4.3E-06	0.0E+00
	Mechanical Equipment	7.98	6.44E-03	7.98	0	0.211		0.061	2.0E-06	1.0E-07	5.0E-06	2.6E-07	4.3E-06	2.2E-07
	Heat Generating Equipment	0	0.00E+00			0.211		0.061	2.0E-06	0.0E+00	5.0E-06	0.0E+00	4.3E-06	0.0E+00
	Torches, welders, burners	5	8.01E-04			0.211	5	0.061	2.0E-06	4.9E-06	5.0E-06	1.2E-09	4.3E-06	1.0E-09
	Internal combustion engines	0	3.11E-04			0.211		0.061	2.0E-06	0.0E+00	5.0E-06	0.0E+00	4.3E-06	0.0E+00
	Office/kitchen equipment	0	9.48E-03			0.211		0.061	2.0E-06	0.0E+00	5.0E-06	0.0E+00	4.3E-06	0.0E+00
	Portable Equipment	4	5.81E-03		2	0.211	2	0.061	2.0E-06	6.3E-09	5.0E-06	1.6E-08	4.3E-06	1.3E-08
	No equipment involved	1150	2.64E-05	150	120	0.211	880	0.061	2.0E-06	1.2E-08	5.0E-06	3.0E-08	4.3E-06	2.6E-08
Propagation from rooms in Fire Zone FA-32-01														
2003			3.16E-02			0.057			2.0E-06	3.6E-09	5.0E-06	9.1E-09	4.3E-06	7.7E-09
2006			3.58E-03			0.057			2.0E-06	4.1E-10	5.0E-06	1.0E-09	4.3E-06	8.8E-10
2032			2.50E-04			0.057			2.0E-06	2.8E-11	5.0E-06	7.2E-11	4.3E-06	6.1E-11
Localized Fire Threatens Waste Form on CTT in the Unloading Room														
Localized Fire Threatens TC/DPC (all) on CTT in the Unloading Room										1.2E-07				
Localized Fire Threatens STC/DPC (all) on CTT in the Unloading Room										3.2E-07				
Localized Fire Threatens STC/TAD on CTT in the Unloading Room										2.7E-07				

INTENTIONALLY LEFT BLANK

Table F5.7-2. Localized Fire Initiating Event Frequencies (Continued)

Room of Origin (includes comments field as needed)	Ignition Source (If Applicable)	Number in Room	Frequency per Unit (50 years)	Number at Target	Number Near Target	Propagation Probability to Target	Number Away from Target	Propagation Probability to Target	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)
Entry represents a vulnerability due to the Canister Transfer Machine														
2004	Electrical	0	1.17E-03			0.211		0.061	1.1E-06	0.0E+00	9.1E-07	0.0E+00		
	HVAC	0	4.85E-03			0.211		0.061	1.1E-06	0.0E+00	9.1E-07	0.0E+00		
	Mechanical Equipment	7.95	6.44E-03	7.95		0.211		0.061	1.1E-06	5.6E-08	9.1E-07	4.7E-08		
	Heat Generating Equipment	0	0.00E+00			0.211		0.061	1.1E-06	0.0E+00	9.1E-07	0.0E+00		
	Torches, welders, burners	5	8.01E-04			0.211	5	0.061	1.1E-06	2.7E-10	9.1E-07	2.2E-10		
	Internal combustion engines	0	3.11E-04			0.211		0.061	1.1E-06	0.0E+00	9.1E-07	0.0E+00		
	Office/kitchen equipment	0	9.48E-03			0.211		0.061	1.1E-06	0.0E+00	9.1E-07	0.0E+00		
	Portable Equipment	2	5.81E-03		1	0.211	1	0.061	1.1E-06	1.7E-09	9.1E-07	1.4E-09		
	No equipment involved	1017	2.64E-05	163	120	0.211	734	0.061	1.1E-06	6.8E-09	9.1E-07	5.6E-09		
Propagation from rooms in Fire Zone FA-32-01														
2003			3.16E-02			0.057			1.1E-06	2.0E-09	9.1E-07	1.7E-09		
2006			3.58E-03			0.057			1.1E-06	2.3E-10	9.1E-07	1.9E-10		
2032			2.50E-04			0.057			1.1E-06	1.6E-11	9.1E-07	1.3E-11		
Localized Fire Threatens DPC or TAD in the Transfer Room														
	Localized Fire Threatens DPC (all) in the Transfer Room										6.8E-08			
	Localized Fire Threatens TAD in the Transfer Room											5.6E-08		
Entry represents a vulnerability due to the DPC Cutting Station														
1016	Electrical	0	1.17E-03			0.211		0.061	6.1E-06	0.0E+00	4.2E-05	0.0E+00	3.4E-05	0.0E+00
B001	HVAC	0	4.85E-03			0.211		0.061	6.1E-06	0.0E+00	4.2E-05	0.0E+00	3.4E-05	0.0E+00
B007	Mechanical Equipment	36.97	6.44E-03	13.97	7	0.211	16	0.061	6.1E-06	6.4E-07	4.2E-05	4.4E-06	3.4E-05	3.6E-06
B009	Heat Generating Equipment	0	0.00E+00			0.211		0.061	6.1E-06	0.0E+00	4.2E-05	0.0E+00	3.4E-05	0.0E+00
	Torches, welders, burners	365	8.01E-04	365	211	0.211		0.061	6.1E-06	3.8E-07	4.2E-05	2.6E-06	3.4E-05	2.1E-06
	Internal combustion engines	78	3.11E-04			0.211	78	0.061	6.1E-06	9.1E-09	4.2E-05	6.2E-08	3.4E-05	5.0E-08
	Office/kitchen equipment	0	9.48E-03			0.211		0.061	6.1E-06	0.0E+00	4.2E-05	0.0E+00	3.4E-05	0.0E+00
	Portable Equipment	8	5.81E-03		3	0.211	5	0.061	6.1E-06	3.3E-08	4.2E-05	2.3E-07	3.4E-05	1.8E-07
	No equipment involved	4237	2.64E-05	30	120	0.211	4087	0.061	6.1E-06	4.9E-08	4.2E-05	3.4E-07	3.4E-05	2.7E-07
Propagation from rooms in Fire Zone FA-00-01														
1001			9.66E-02			0.057			6.1E-06	3.4E-08	4.2E-05	2.3E-07	3.4E-05	1.9E-07
1022			1.54E-04			0.057			6.1E-06	5.4E-11	4.2E-05	3.7E-10	3.4E-05	3.0E-10
B002			1.46E-02			0.057			6.1E-06	5.1E-09	4.2E-05	3.5E-08	3.4E-05	2.8E-08
B003			1.01E-03			0.057			6.1E-06	3.6E-10	4.2E-05	2.4E-09	3.4E-05	2.0E-09
B004			1.80E-03			0.057			6.1E-06	6.3E-10	4.2E-05	4.3E-09	3.4E-05	3.5E-09
B006			7.35E-05			0.057			6.1E-06	2.6E-11	4.2E-05	1.8E-10	3.4E-05	1.4E-10
B008			1.63E-03			0.057			6.1E-06	5.7E-10	4.2E-05	3.9E-09	3.4E-05	3.1E-09
P001			0.00E+00			0.057			6.1E-06	0.0E+00	4.2E-05	0.0E+00	3.4E-05	0.0E+00
Localized Fire Threatens STC/DPC in DPC Cutting Station in the Preparation Area														
	Localized Fire Threatens STC/DPC (all) in DPC Cutting Station (Dry Cavity, Dry Annulus) in the Preparation Area										1.2E-06			
	Localized Fire Threatens STC/DPC (all) in DPC Cutting Station (Dry Cavity, Wet Annulus) in the Preparation Area											7.9E-06		
	Localized Fire Threatens STC/DPC (all) in DPC Cutting Station (Wet Cavity, Wet Annulus) in the Preparation Area												6.4E-06	

INTENTIONALLY LEFT BLANK

Table F5.7-2. Localized Fire Initiating Event Frequencies (Continued)

Room of Origin (includes comments field as needed)	Ignition Source (If Applicable)	Number in Room	Frequency per Unit (50 years)	Number at Target	Number Near Target	Propagation Probability to Target	Number Away from Target	Propagation Probability to Target	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)
<b>Entry represents a vulnerability due to the TAD Closure Station</b>														
1016	Electrical	0	1.17E-03			0.211		0.061	1.6E-05	0.0E+00	7.0E-05	0.0E+00	4.1E-05	0.0E+00
B001	HVAC	0	4.85E-03			0.211		0.061	1.6E-05	0.0E+00	7.0E-05	0.0E+00	4.1E-05	0.0E+00
B007	Mechanical Equipment	36.97	6.44E-03	14	9.97	0.211	13	0.061	1.6E-05	1.7E-06	7.0E-05	4.4E-06	4.1E-05	3.6E-06
B009	Heat Generating Equipment	0	0.00E+00			0.211		0.061	1.6E-05	0.0E+00	7.0E-05	0.0E+00	4.1E-05	0.0E+00
	Torches, welders, burners	365	8.01E-04	365		0.211		0.061	1.6E-05	4.6E-06	7.0E-05	2.6E-06	4.1E-05	2.1E-06
	Internal combustion engines	78	3.11E-04			0.211	78	0.061	1.6E-05	2.3E-08	7.0E-05	6.2E-08	4.1E-05	5.0E-08
	Office/kitchen equipment	0	9.48E-03			0.211		0.061	1.6E-05	0.0E+00	7.0E-05	0.0E+00	4.1E-05	0.0E+00
	Portable Equipment	8	5.81E-03		3	0.211	5	0.061	1.6E-05	8.5E-08	7.0E-05	2.3E-07	4.1E-05	1.8E-07
	No equipment involved	4237	2.64E-05	30	120	0.211	4087	0.061	1.6E-05	1.3E-07	7.0E-05	3.4E-07	4.1E-05	2.7E-07
<b>Propagation from rooms in Fire Zone FA-00-01</b>														
1001			9.66E-02			0.057			1.6E-05	8.7E-08	7.0E-05	3.9E-07	4.1E-05	2.3E-07
1022			1.54E-04			0.057			1.6E-05	1.4E-10	7.0E-05	6.2E-10	4.1E-05	3.6E-10
B002			1.46E-02			0.057			1.6E-05	1.3E-08	7.0E-05	5.9E-08	4.1E-05	3.4E-08
B003			1.01E-03			0.057			1.6E-05	9.1E-10	7.0E-05	4.1E-09	4.1E-05	2.4E-09
B004			1.80E-03			0.057			1.6E-05	1.6E-09	7.0E-05	7.3E-09	4.1E-05	4.2E-09
B006			7.35E-05			0.057			1.6E-05	6.6E-11	7.0E-05	3.0E-10	4.1E-05	1.7E-10
B008			1.63E-03			0.057			1.6E-05	1.5E-09	7.0E-05	6.6E-09	4.1E-05	3.8E-09
<b>Localized Fire Threatens STC/TAD in TAD Closure Station in the Preparation Area</b>														
	<b>Localized Fire Threatens STC/TAD in TAD Closure Station (Dry Cavity, Dry Annulus) in the Preparation Area</b>										6.6E-06			
	<b>Localized Fire Threatens STC/TAD in TAD Closure Station (Dry Cavity, Wet Annulus) in the Preparation Area</b>										8.0E-06			
	<b>Localized Fire Threatens STC/TAD in TAD Closure Station (Wet Cavity, Wet Annulus) in the Preparation Area</b>										6.4E-06			
<b>Entry represents a vulnerability due to the Site Transporter</b>														
1007	Electrical	0	1.17E-03			0.211		0.061	3.7E-06	0.0E+00				
2004	HVAC	0	4.85E-03			0.211		0.061	3.7E-06	0.0E+00				
	Mechanical Equipment	7	6.44E-03	5		0.211	2	0.061	3.7E-06	1.2E-07				
	Heat Generating Equipment	0	0.00E+00			0.211		0.061	3.7E-06	0.0E+00				
	Torches, welders, burners	5	8.01E-04			0.211	5	0.061	3.7E-06	9.0E-10				
	Internal combustion engines	61	3.11E-04	61		0.211		0.061	3.7E-06	6.9E-08				
	Office/kitchen equipment	0	9.48E-03			0.211		0.061	3.7E-06	0.0E+00				
	Portable Equipment	2	5.81E-03	1		0.211	1	0.061	3.7E-06	2.3E-08				
	No equipment involved	1199	2.64E-05	182	120	0.211	897	0.061	3.7E-06	2.5E-08				
<b>Propagation from rooms in Fire Zone FA-32-01</b>														
2003			3.16E-02			0.057			3.7E-06	6.6E-09				
2006			3.58E-03			0.057			3.7E-06	7.5E-10				
2032			2.50E-04			0.057			3.7E-06	5.3E-11				
	<b>Localized Fire Threatens TAD in AO in Loading Room</b>										2.5E-07			

INTENTIONALLY LEFT BLANK

Table F5.7-2. Localized Fire Initiating Event Frequencies (Continued)

Room of Origin (includes comments field as needed)	Ignition Source (If Applicable)	Number in Room	Frequency per Unit (50 years)	Number at Target	Number Near Target	Propagation Probability to Target	Number Away from Target	Propagation Probability to Target	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)	Target Exposure Time (Fraction)	Contribution to IE Frequency (50 years)
Entry represents a vulnerability due to the Site Transporter														
1023	Electrical	0	1.17E-03			0.211		0.061	9.7E-06	0.0E+00				
	HVAC	3	4.85E-03		3	0.211		0.061	9.7E-06	3.0E-08				
	Mechanical Equipment	4	6.44E-03	2	2	0.211		0.061	9.7E-06	1.5E-07				
	Heat Generating Equipment	0	0.00E+00			0.211		0.061	9.7E-06	0.0E+00				
	Torches, welders, burners	0	8.01E-04			0.211		0.061	9.7E-06	0.0E+00				
	Internal combustion engines	39	3.11E-04	39		0.211		0.061	9.7E-06	1.2E-07				
	Office/kitchen equipment	0	9.48E-03			0.211		0.061	9.7E-06	0.0E+00				
	Portable Equipment	0	5.81E-03			0.211		0.061	9.7E-06	0.0E+00				
	No equipment involved	434	2.64E-05	280	120	0.211	34	0.061	9.7E-06	7.8E-08				
<b>Localized Fire Threatens TAD in AO in Bolting Room</b>														
														<b>3.8E-07</b>

NOTE: The blank cells in this table are intentional and have been verified.

AO = aging overpack; CTT = cask transfer trolley; DPC = dual-purpose canister; HVAC = heating, ventilation, and air conditioning; IE = initiating event; SNF = spent nuclear fuel; SPM = site prime mover; STC = shielded transfer cask; TAD = transportation, aging, and disposal canister; TC = transportation cask; TTC = a transportation cask that is upended using a tilt frame.

Source: Original

INTENTIONALLY LEFT BLANK

Table F5.7-3. Localized Fire Initiating Events with Multiple Rooms of Origin

<b>Rooms</b>	<b>Vulnerability</b>	<b>Justification</b>	
1001	Railcar/Truck (Diesel)	Rooms 1001 and 1016 are open to each other due to open doors as the Railcar/Truck moves from 1001 to 1016. Room 1016 is open to rooms B001, B007, and B009.	
1016			
B001			
B007			
B009			
1016	Railcar/Truck (Diesel)	Room 1016 is open to rooms B001, B007, and B009 at all times.	
B001	Preparation Station		
B007	DPC Cutting Station		
B009	Cask Transfer Trolley	Rooms open to each other through the port slide gates as the cask is accessed from room 2004	
1008	Cask Transfer Trolley		
2004			

Source: Original

Table F5.7-4. Large Fire Initiating Event Frequencies

<b>Large Fire Threatens Waste Form In Fire Zones Containing Vulnerable Waste Forms</b>		Total Ignition Frequency	Propagation Probability Beyond Fire-rated Area	Target Exposure Time (Fraction)	Contribution to IE Frequency
Large fires are those that spread beyond the boundaries of a fire area, up through those that breach the building boundary.					
Large Fire Threatens TC/SNF or TC/DPC (all) (Diesel Present)		2.51E+00	0.169	1.7E-06	7.1E-07
Large Fire Threatens TC/SNF (No Diesel)		2.51E+00	0.169	1.4E-05	6.0E-06
Large Fire Threatens TC/DPC (TTC) (No Diesel)		2.51E+00	0.169	5.6E-05	2.4E-05
Large Fire Threatens TC/DPC (No Diesel)		2.51E+00	0.169	3.9E-05	1.7E-05
Large Fire Threatens DPC (all) in CTM		2.51E+00	0.169	1.1E-06	4.7E-07
Large Fire Threatens STC/DPC (all)		2.51E+00	0.169	4.1E-05	1.7E-05
Large Fire Threatens STC/DPC (all) (Dry Cavity, Wet Annulus)		2.51E+00	0.169	4.2E-05	1.8E-05
Large Fire Threatens STC/DPC (all) (Wet Cavity, Wet Annulus)		2.51E+00	0.169	3.4E-05	1.4E-05
Large Fire Threatens TC/SNF (Wet Cavity)		2.51E+00	0.169	7.7E-06	3.3E-06
Large Fire Threatens STC/TAD (Wet Cavity, Wet Annulus)		2.51E+00	0.169	4.1E-05	1.7E-05
Large Fire Threatens STC/TAD (Dry Cavity, Wet Annulus)		2.51E+00	0.169	7.0E-05	3.0E-05
Large Fire Threatens STC/TAD (Dry Cavity, Dry Annulus)		2.51E+00	0.169	1.9E-05	7.9E-06
Large Fire Threatens TAD in CTM		2.51E+00	0.169	9.1E-07	3.9E-07
Large Fire Threatens TAD in AO		2.51E+00	0.169	1.3E-05	5.3E-06

NOTE: AO = aging overpack; CTM = canister transfer machine; DPC = dual-purpose canister; IE = initiating event; SNF = spent nuclear fuel; STC = shielded transfer cask; TAD = transportation, aging, and disposal canister; TC = transportation cask.

Source: Original

Table F5.7-5. Fire Initiating Events Results Summary

<b>Initiating Event</b>	<b>Equipment</b>	<b>Mean</b>	<b>Median</b>	<b>97.5% Value</b>	<b>Error Factor</b>	<b>Type</b>
<b>Localized Fire Threatens TC/SNF or TC/DPC (incl. TTC) on Railcar/Trailer in Receipt Area w/Tractor (Diesel Present)</b>	Railcar/Truck					
Localized Fire Threatens TC/SNF or TC/DPC (incl. TTC) on Railcar/Trailer in Receipt Area w/Tractor (Diesel Present)		4.7E-07	4.2E-07	1.1E-06	2.2E+00	Lognormal
<b>Railcar/Trailer in Receipt Area w/o Tractor/SPM (No Diesel Present)</b>	Railcar/Truck					
Localized Fire Threatens TC/SNF on Truck Trailer in Receipt Area w/o Tractor (No Diesel Present)		2.5E-06	2.3E-06	5.7E-06	2.2E+00	Lognormal
Localized Fire Threatens TC/DPC (TTC) on Railcar/Trailer in Receipt Area w/o Tractor/SPM (No Diesel Present)		7.6E-06	6.8E-06	1.7E-05	2.2E+00	Lognormal
Localized Fire Threatens TC/DPC on Truck Trailer in Receipt Area w/o Tractor (No Diesel Present)		4.0E-06	3.6E-06	9.0E-06	2.2E+00	Lognormal
<b>Localized Fire Threatens TC/SNF in the Preparation Area</b>	Preparation Station					
Localized Fire Threatens TC/SNF (Dry Cavity) in the Preparation Station in the Preparation Area		1.9E-06	1.7E-06	4.2E-06	2.1E+00	Lognormal
Localized Fire Threatens TC/SNF (Wet Cavity) in the Preparation Station in the Preparation Area		3.6E-06	3.3E-06	8.2E-06	2.1E+00	Lognormal
<b>Localized Fire Threatens TC/DPC or STC/DPC on CTT in the Preparation Station</b>	Cask Transfer Trolley					
Localized Fire Threatens TC/DPC (all) on CTT in the Preparation Station in the Preparation Area		4.2E-06	3.8E-06	9.8E-06	2.2E+00	Lognormal
Localized Fire Threatens STC/DPC (all) on CTT in the Preparation Station in the Preparation Area		5.4E-06	4.8E-06	1.3E-05	2.2E+00	Lognormal
<b>Localized Fire Threatens Waste Form on CTT in the Unloading Room</b>	Cask Transfer Trolley					
Localized Fire Threatens TC/DPC (all) on CTT in the Unloading Room		1.5E-07	1.4E-07	3.5E-07	2.2E+00	Lognormal
Localized Fire Threatens STC/DPC (all) on CTT in the Unloading Room		3.9E-07	3.5E-07	8.9E-07	2.2E+00	Lognormal
Localized Fire Threatens STC/TAD on CTT in the Unloading Room		3.3E-07	3.0E-07	7.6E-07	2.2E+00	Lognormal
<b>Localized Fire Threatens DPC or TAD in the Transfer Room</b>	Canister Transfer Machine					
Localized Fire Threatens DPC (all) in the Transfer Room		8.3E-08	7.4E-08	1.9E-07	2.2E+00	Lognormal
Localized Fire Threatens TAD in the Transfer Room		6.9E-08	6.2E-08	1.6E-07	2.2E+00	Lognormal
<b>Localized Fire Threatens STC/DPC in DPC Cutting Station in the Preparation Area</b>	DPC Cutting Station					
Localized Fire Threatens STC/DPC (all) in DPC Cutting Station (Dry Cavity, Dry Annulus) in the Preparation Area		1.2E-06	1.1E-06	2.8E-06	2.2E+00	Lognormal
Localized Fire Threatens STC/DPC (all) in DPC Cutting Station (Dry Cavity, Wet Annulus) in the Preparation Area		8.3E-06	7.4E-06	1.9E-05	2.2E+00	Lognormal
Localized Fire Threatens STC/DPC (all) in DPC Cutting Station (Wet Cavity, Wet Annulus) in the Preparation Area		6.8E-06	6.0E-06	1.5E-05	2.2E+00	Lognormal
<b>Localized Fire Threatens STC/TAD in TAD Closure Station in the Preparation Area</b>	TAD Closure Station					
Localized Fire Threatens STC/TAD in TAD Closure Station (Dry Cavity, Dry Annulus) in the Preparation Area		7.5E-06	6.8E-06	1.7E-05	2.1E+00	Lognormal
Localized Fire Threatens STC/TAD in TAD Closure Station (Dry Cavity, Wet Annulus) in the Preparation Area		8.6E-06	7.6E-06	2.0E-05	2.2E+00	Lognormal
Localized Fire Threatens STC/TAD in TAD Closure Station (Wet Cavity, Wet Annulus) in the Preparation Area		6.8E-06	6.1E-06	1.6E-05	2.2E+00	Lognormal
<b>Localized Fire Threatens TAD in AO in Loading Room</b>	Site Transporter					
Localized Fire Threatens TAD in AO in Loading Room		2.9E-07	2.6E-07	6.8E-07	2.2E+00	Lognormal
<b>Localized Fire Threatens TAD in AO in Bolting Room</b>	Site Transporter					
Localized Fire Threatens TAD in AO in Bolting Room		3.5E-07	3.1E-07	8.3E-07	2.2E+00	Lognormal

Table F5.7-5. Fire Initiating Events Results Summary (Continued)

Initiating Event	Mean	Median	97.5% Value	Error Factor	Type
Large Fire Threatens TC/SNF or TC/DPC (all) (Diesel Present)	7.9E-07	7.0E-07	1.8E-06	2.2E+00	Lognormal
Large Fire Threatens TC/SNF (No Diesel)	6.7E-06	5.9E-06	1.6E-05	2.2E+00	Lognormal
Large Fire Threatens TC/DPC (TTC) (No Diesel)	2.6E-05	2.3E-05	6.1E-05	2.2E+00	Lognormal
Large Fire Threatens TC/DPC (No Diesel)	1.8E-05	1.6E-05	4.3E-05	2.2E+00	Lognormal
Large Fire Threatens DPC (all) in CTM	5.2E-07	4.6E-07	1.2E-06	2.3E+00	Lognormal
Large Fire Threatens STC/DPC (all)	1.9E-05	1.7E-05	4.5E-05	2.1E+00	Lognormal
Large Fire Threatens STC/DPC (all) (Dry Cavity, Wet Annulus)	2.0E-05	1.7E-05	4.6E-05	2.4E+00	Lognormal
Large Fire Threatens STC/DPC (all) (Wet Cavity, Wet Annulus)	1.6E-05	1.4E-05	3.7E-05	2.3E+00	Lognormal
Large Fire Threatens TC/SNF (Wet Cavity)	3.6E-06	3.2E-06	8.4E-06	2.2E+00	Lognormal
Large Fire Threatens STC/TAD (Wet Cavity, Wet Annulus)	1.9E-05	1.7E-05	4.4E-05	2.2E+00	Lognormal
Large Fire Threatens STC/TAD (Dry Cavity, Wet Annulus)	3.3E-05	2.9E-05	7.7E-05	2.2E+00	Lognormal
Large Fire Threatens STC/TAD (Dry Cavity, Dry Annulus)	8.8E-06	7.8E-06	2.1E-05	2.2E+00	Lognormal
Large Fire Threatens TAD in CTM	4.3E-07	3.8E-07	1.0E-06	2.2E+00	Lognormal
Large Fire Threatens TAD in AO	5.9E-06	5.3E-06	1.4E-05	2.2E+00	Lognormal

NOTE: AO = aging overpack; CTM = canister transfer machine; CTT = cask transfer trolley; DPC = dual-purpose canister; SNF = spent nuclear fuel; SPM = site prime mover; STC = shielded transfer cask; TAD = transportation, aging, and disposal canister; TC = transportation cask; TTC = a transportation cask that is upended using a tilt frame.

Source: Original

**Forecast: Localized Fire Threatens TAD in AO in Bolting Room**


Cell: K213

Summary:

Entire range is from 4.8E-08 to 1.7E-06

Base case is 3.1E-07

After 10,000 trials, the std. error of the mean is 1.8E-09



Statistics:

	Forecast values
Trials	10,000
Mean	3.5E-07
Median	3.1E-07
Mode	---
Standard Deviation	1.8E-07
Variance	3.4E-14
Skewness	1.57
Kurtosis	6.98
Coeff. of Variability	0.5229
Minimum	4.8E-08
Maximum	1.7E-06
Range Width	1.7E-06
Mean Std. Error	1.8E-09

**Forecast: Localized Fire Threatens TAD in AO in Bolting Room (cont'd)**

Cell: K213

Percentiles:

	Forecast values
0%	4.8E-08
10%	1.7E-07
20%	2.1E-07
30%	2.4E-07
40%	2.8E-07
50%	3.1E-07
60%	3.5E-07
70%	4.0E-07
80%	4.7E-07
90%	5.8E-07
100%	1.7E-06

Figure F5.7-1. Example of Crystal Ball Output for a Fire Initiating Event

Source: Original

INTENTIONALLY LEFT BLANK

## APPENDIX F.I

### DEFINITION OF IGNITION SOURCE CATEGORY

Table F.I-1. Ignition Source Categories

Ignition Source Category	NFPA Equipment Categories Included
Electrical Equipment	<b>Fixed wiring; transformer, associated over current or disconnect equipment; meter, meter box;</b> power switch gear, over current protection devices; switch, receptacle, outlet; lighting fixture, lamp holder, ballast, sign; cord, plug; lamp, light bulb; unclassified or <b>unknown-type electrical distribution equipment</b> ; electronic equipment; rectifier, charger
Mechanical and Electrical HVAC Equipment	<b>Central heating unit; water heater; fixed, stationary local heating unit; central air conditioning, refrigeration equipment; water cooling device, tower; fixed, stationary local refrigeration unit;</b> fixed, stationary local air conditioning unit; chimney, gas vent flue; chimney connector, vent connector; <b>heat transfer system;</b> unclassified heating systems; <b>other HVAC equipment;</b> and unclassified air conditioning, refrigeration systems
Mechanical Equipment	Chemical process equipment; <b>waste recovery equipment; working, shaping machine;</b> coating machine; painting machine; unclassified process equipment; <b>separate motor or generator;</b> separate pump or compressor; conveyor, and <b>unknown mechanical equipment</b>
Fixed Heat-Generating Process Equipment	<b>Casting, molding, or forging equipment;</b> heat treating equipment; <b>dryers; furnaces; and incinerators.</b>
Torches/Welders	<b>Torches, welders, and burners</b>
Internal Combustion Engines	<b>Internal combustion engines</b>
Office and Kitchen Equipment	<b>Television, radio, stereo; fixed food warming appliance; fixed or stationary oven;</b> and all other categories
Portable and Special Equipment	<b>Portable local heating unit; hand tools;</b> portable appliance designed to produce controlled heat; <b>portable appliance designed not to produce heat; unclassified special equipment; unclassified service or maintenance equipment; biomedical equipment or device</b>
No Equipment Involved	<b>No equipment</b>

NOTE: The entries shown in bold in the table were those that had caused fires in the data set. The other entries were included in the data set retrieval, but no fires were attributed to them. Given that there were only a total of 188 fires in the entire data set, the fact that certain items had not been associated with an observed fire cannot be taken to mean that they can be eliminated as potential ignition sources.

Source: Ref. F2.65

**APPENDIX F.II**  
**DERIVATION OF IGNITION SOURCE DISTRIBUTION AND FIRE PROPAGATION**  
**PROBABILITIES**

Three independent data sets concerning fires in radioactive material working facilities (Tables F.II-1 through F.II-3) have been analyzed for statistical confidence. The data sets are in the format of a tally; each sample (fire) is placed in the appropriate category (e.g., equipment type, extent of flame damage), and the reported figure for each category is the number of fires that pertained to the category. All of these data sets reflect the operating history of nuclear facilities of non-combustible construction as defined by the NFPA. The NFPA data is taken from *Structure Fires in Radioactive Material Working Facilities and Nuclear Energy Plants of Non-Combustible Construction* (Ref. F2.65).

The first data set provides a distribution of fire ignition as a function of the ignition source category, as defined in Appendix .FI. Table F.II -1 provides a summary of that data.

Table F.II-1 Fires in Radioactive Material Working Facilities by Originating Equipment

Ignition Source Category	Fires	
Electrical	16	9%
Mechanical/Electrical HVAC	15	8%
Mechanical	26	14%
Heat Generating	29	16%
Torches/Welders	41	22%
Internal Combustion	4	2%
Offices/Kitchen Equipment	12	6%
Portable Equipment	19	10%
No Equipment	25	13%
Total	187	100%

NOTE: HVAC = heating, ventilation, and air conditioning.

Source: Ref. F2.65

Table F.II-2 Structure Fires in Radioactive Material Working Facilities and Nuclear Energy Plants of Non-Combustible Construction and in which No Automatic Suppression System Was Present or the Automatic Suppression System Failed to Operate

Extent of Flame Damage	Fires	
Confined to object of origin	54	63%
Confined to part of room/area of origin	13	15%
Confined to room of origin	0	0
Confined to fire-rated compartment of origin	5	6%
Confined to floor of origin	0	0
Confined to structure of origin	14	16%
Extended beyond structure of origin	0	0
Total	86	100%

Source: Ref. F2.65

Table F.II-3 Structure Fires in Radioactive Material Working Facilities and Nuclear Energy Plants of Non-Combustible Construction and in which the Fire Was Too Small to Activate the Automatic Suppression System or the Automatic System Operated Properly

Extent of Flame Damage	Fires	
Confined to object of origin	40	56%
Confined to part of room/area of origin	23	32%
Confined to room of origin	2	3%
Confined to fire-rated compartment of origin	0	0%
Confined to floor of origin	5	7%
Confined to structure of origin	2	3%
Extended beyond structure of origin	0	0
Total	72	100%

Source: Ref. F2.65

The method chosen for calculating the confidence interval of the data is the margin of error calculation:

$$ME = \sqrt{\frac{p(1-p)}{n}} \times t \quad (\text{Eq. F.II-1})$$

where:

**ME** = Margin of Error

**p** = Event Probability

**n** = Number of Samples

**t** = *t*-distribution value (see Table F.II-4)