

PMSTPCOL PEmails

From: Tai, Tom
Sent: Thursday, July 02, 2009 2:55 PM
To: John Price (jeprice@stpegs.com)
Cc: Mookhoek, William; STPCOL
Subject: STP RAI 2927 for Chapter 3.10 - Letter 141
Attachments: ML0918302433 3.10-1.pdf

John,

Attached for your use is an advance copy of Letter 141 transmitting RAI 2927 for Chapter 3.10. A formal copy is in the mail.

Regards

Tom Tai
DNRL/NRO
(301) 415-8484
Tom.Tai@NRC.GOV

Hearing Identifier: SouthTexas34Public_EX
Email Number: 1419

Mail Envelope Properties (C56E360E9D804F4B95BC673F886381E71FBC21C99D)

Subject: STP RAI 2927 for Chapter 3.10 - Letter 141
Sent Date: 7/2/2009 2:55:26 PM
Received Date: 7/2/2009 2:55:28 PM
From: Tai, Tom

Created By: Tom.Tai@nrc.gov

Recipients:

"Mookhoek, William" <wemookhoek@STPEGS.COM>
Tracking Status: None
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"John Price (jeprice@stpegs.com)" <jeprice@stpegs.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	227	7/2/2009 2:55:28 PM
ML0918302433 3.10-1.pdf	85559	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

July 2, 2009

Mr. Scott Head, Manager
Regulatory Affairs
STP Nuclear Operating Company
P. O. Box 289
Wadsworth, TX 77483

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 141 RELATED TO
SRP SECTION 3.10 FOR THE SOUTH TEXAS PROJECT COMBINED
LICENSE APPLICATION

Dear Mr. Head

By letter dated September 20, 2007, STP Nuclear Operating Company (STP) submitted for approval a combined license application pursuant to 10 CFR Part 52. The U. S. Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

To support the review schedule, you are requested to respond within **30** days of the date of this letter. If changes are needed to the safety analysis report, the staff requests that the RAI response include the proposed wording changes.

S. Head

-2-

If you have any questions or comments concerning this matter, I can be reached at 301-415-8484 or by e-mail at Tom.Tai@nrc.gov or you may contact George Wunder at 301-415-1494 or George.Wunder@nrc.gov.

Sincerely,

/RA/

Tom M. Tai, Senior Project Manager
ABWR Projects Branch
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-012
52-013

eRAI Tracking No. 2927

Enclosure:
Request for Additional Information

cc: William Mookhoek
John Price

S. Head

-2-

If you have any questions or comments concerning this matter, I can be reached at 301-415-8484 or by e-mail at Tom.Tai@nrc.gov or you may contact George Wunder at 301-415-1494 or George.Wunder@nrc.gov.

Sincerely,

/RA/

Tom M. Tai, Senior Project Manager
ABWR Projects Branch
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-012
52-013

eRAI Tracking No. 2927

Enclosure:
Request for Additional Information

cc: William Mookhoek
John Price

Distribution:
PUBLIC
NGE 1/2 R/F
GWunder, NRO
BAbeywickrama, NRO
PYChen, NRO
JDHerrity, NRO
SKirkwood, OGC
RidsNroDeEmb2
RidsNroDnrlNge2

ADAMS Accession No. ML091830243

NRO-002

OFFICE	EMB2/TR	EMB2/BC	NGE2/PM	OGC	NGE2/L-PM
NAME	PYChen	JDHerrity	TTai	SKirkwood	GWunder
DATE	5/21/09	5/26/09	7/2/09	6/16/09	6/16/09

***Approval captured electronically in the electronic RAI system.**

OFFICIAL RECORD COPY

Request for Additional Information No. 2927 Revision 2

**South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013**

**SRP Section: 03.10 - Seismic and Dynamic Qualification of Mechanical and Electrical Equipment
Application Section: 3.10**

QUESTIONS for Engineering Mechanics Branch 2 (ESBWR/ABWR Projects) (EMB2)

03.10-1

In Section 3.10.5 of the STP 3&4 FSAR, descriptions for COL License Information Items 3.37 and 3.38 are not totally acceptable. The applicant is requested to provide an implementation program for seismic qualification of mechanical and electrical equipment, including milestones and completion dates for the dynamic qualification report (DQR).

Section C.I.3.10.4 of RG 1.206 calls for this to be done prior to installation of equipment, **not prior to fuel loading**. The applicant is requested to either provide an implementation program that meets Reg Guide 1.206 or justify an alternative approach that allow the staff enough time to audit the DQR.

Enclosure